



Bi- annual inspection form for PCB encapsulated areas

**Date:** 04/09/09

**Building:** Gage Hall

**Condition of encapsulated area:** Good

**Comments:** None

**Recommendations:** None at this time, re-inspect in Oct 2009

**Date:** 04/09/09

**Building:** Bliss Hall

**Condition of encapsulated area:** Good

**Comments:** None

**Recommendations:** None at this time, re-inspect in Oct 2009

**Date:** 04/07/09

**Building:** Scudder Hall

**Condition of encapsulated area:** Good

**Comments:** plywood outer encasement coming loose, hammered in boards, place WO 10075 to have carpenter shop add screws to plywood

**Recommendations:** See above re-inspect in Oct 2009



Bi- annual inspection form for PCB encapsulated areas

**Date** 04/08/09

**Building:** Coykendall Science Building

**Condition of encapsulated area:** Good

**Comments:** .New Encapsulant applied to new HTHW line penetration under supervision of Clean Harbors. Will re-inspect in Oct/Nov 2009. Slight staining on encapsulant outside of enclosed room, will complete a PCB wipe sample by May.

**Recommendations:**

- 1) Require that encapsulated walls remain free of any item (leaning against the wall), as storage against these walls may damage the encapsulant. Re-inspect in Oct 2009

**04/09 Galson Lab Testing attached ... No PCB found staining from HTHW line contractor activity**

**Date:** 04/07/09

**Building:** Parker Theater

**Condition of encapsulated area:** Good

**Blacktop integrity Southeast corner Driveway:** Good

**Comments:** Slight staining on wall near light switch in room re-inspect in Oct 2009

The staining was from duct tape glue , no need to test.

**Recommendations:** see above

Inspections by \_\_\_\_\_ Michael Malloy \_\_\_\_\_



Mr. Mike Malloy  
SUNY - New Paltz  
75 S. Manheim Blvd.  
Service Building, 2nd FL Rm 10A  
New Paltz, NY 12561

April 21, 2009

DOH ELAP# 11626

Account# 13491

Login# L191497

Dear Mr. Malloy:

Enclosed are the analytical results for the samples received by our laboratory on April 15, 2009. All test results meet the quality control requirements of AIHA and NELAC unless otherwise stated in this report. All samples on the chain of custody were received in good condition unless otherwise noted.

Results in this report are based on the sampling data provided by the client and refer only to the samples as they were received at the laboratory. Unless otherwise requested, all samples will be discarded 14 days from the date of this report.

Please contact Amanda Frateschi at (877) 482-5227, if you would like any additional information regarding this report.

Thank you for using Galson Laboratories.

Sincerely,

Galson Laboratories

A handwritten signature in cursive script that reads "Mary G. Unangst". The signature is written in black ink and is positioned below the typed name.

Mary G. Unangst  
Laboratory Director

Enclosure(s)



6601 Kirkville Road  
 East Syracuse, NY 13057  
 (315) 432-5227  
 FAX: (315) 437-0571  
 www.galsonlabs.com

Client : SUNY - New Paltz  
 Site : SUNY NP  
 Date Sampled : 13-APR-09  
 Date Received : 15-APR-09  
 Date Analyzed : 18-APR-09  
 Report ID : 608317

Account No.: 13491  
 Login No. : L191497

**Polychlorinated Biphenyls**

<u>Sample ID</u>	<u>Lab ID</u>	<u>Area</u> <u>100cm2</u>	<u>Raw</u> <u>ug</u>	<u>Total</u> <u>ug</u>	<u>Conc</u> <u>ug/100cm2</u>
#1 CSBCEILDRPS	L191497-1	1	<0.5	<0.5	<0.5
#2 CSBCEILNODRPS	L191497-2	1	<0.5	<0.5	<0.5
#3 CSBCEILDRPS2	L191497-3	1	<0.5	<0.5	<0.5
#4 CSBFB	L191497-4	NA	<0.5	<0.5	NA

COMMENTS: Please see attached lab footnote report for any applicable footnotes.

Level of quantitation: 0.5 ug	Submitted by: mln
Analytical Method : mod. 40 CFR 761	Approved by : nkp
OSHA PEL (TWA) : NA	Date : 21-APR-09 NYS DOH # : 11626
Collection Media : Wipe	QC by: Tony D'Amico

< -Less Than	mg -Milligrams	m3 -Cubic Meters	kg -Kilograms
> -Greater Than	ug -Micrograms	l -Liters	NS -Not Specified
NA -Not Applicable	ND -Not Detected	ppm -Parts per Million	



Client Name : SUNY - New Paltz  
 Site : SUNY NP

6601 Kirkville Road  
 East Syracuse, NY 13057  
 (315) 432-5227  
 FAX: (315) 437-0571  
 www.galsonlabs.com

Date Sampled : 13-APR-09  
 Date Received: 15-APR-09  
 Date Analyzed: 18-APR-09

Account No.: 13491  
 Login No. : L191497

Unless otherwise noted below, all quality control results associated with the samples were within established control limits.

Unrounded results are carried through the calculations that yield the final result and the final result is rounded to the number of significant figures appropriate to the accuracy of the analytical method. Please note that results appearing in the columns preceding the final result column may have been rounded in order to fit the report format and therefore, if carried through the calculations, may not yield an identical final result to the one reported.

The stated LOQs for each analyte represent the demonstrated LOQ concentrations prior to correction for desorption efficiency (if applicable).

L191497 (Report ID: 608317) : Total ug corrected for a desorption efficiency of 100%.

Samples were analyzed for the following seven Aroclors: 1016, 1221, 1232, 1242, 1248, 1254, and 1260.

SOPs: GC-SOP-10(2), GC-SOP-18(3)

< -Less Than	mg -Milligrams	m3 -Cubic Meters	kg -Kilograms
> -Greater Than	ug -Micrograms	l -Liters	NS -Not Specified
NA -Not Applicable	ND -Not Detected	ppm -Parts per Million	



6601 Kirkville Rd  
 East Syracuse, NY 13057  
 Tel: (315) 432-5227  
 Fax: (315) 437-0571  
 www.galsonlabs.com

Check if change of address *fr*  
 New Client?  yes  no

Report To: Michael Malloy  
Service Bldg, Floor 2 Room 1104  
1 Hawk drive  
New Paltz, NY 12561-2447  
 Invoice To: same  
 Phone No.: \_\_\_\_\_  
 Fax No.: \_\_\_\_\_

Site Name: SUNY UP Project: \_\_\_\_\_  
 Samples submitted using the FreePumpLoan™ Program.  Samples submitted using the FreeSamplingBadges™ Program.  
 Client Account No.: 13491  
 Purchase Order No.: \_\_\_\_\_  
 Credit Card No.: \_\_\_\_\_  
 Card Holder Name: \_\_\_\_\_  
 Exp.: \_\_\_\_\_

Email / Fax Results To: malloy@mnewpaltz.edu  
 Email Address: \_\_\_\_\_  
 Fax No.: 845-257-6915

Need Results By: (surcharge)  
 5 Business Days 0%  
 4 Business Days 35%  
 3 Business Days 50%  
 2 Business Days 75%  
 4 Next Day by 6pm 100%  
 Next Day by Noon 150%  
 Same day 200%

Sample Identification	Date Sampled	Collection Medium	Air Volume (Liters)	Passive Monitors (Min)	Analysis Requested	Method Reference	Specific DL Needed
1. #1 CSB CELL DRPS	4/13/09	gauze <sup>in vial</sup>	100 cm <sup>2</sup>		PCB		
2. #2 CSB CELL DRPS	S		100 cm <sup>2</sup>				
3. #3 CSB CELL DRPS 2			100 cm <sup>2</sup>				
4. #4 CSB FB			100 cm <sup>2</sup>				
5.							
6.							
7.							
8.							
9.							
10.							
11.							

Yes  No We normally add a laboratory blank for each analyte. We will charge you for this at our normal rate. If you agree please check "Yes" otherwise check "No".  
 List description of industry or process / interference's present in sampling area:

Comments:

Chain of Custody  
 Relinquished by: Michael Malloy Signature  
 Received by LAB: M. Krause Signature  
 Date/Time: 4/13/09 2:30p  
4/15/09 @ 0730