

CAPER HALL - AIR SAMPLES

LOCATION	ID #	DATE	TYPE	RESULT	COMMENTS
CAPEN	9B1492-18	01/04/92	AIR	.14 AS 1260	BASEMENT
CAPEN	921492-20	01/04/92	AIR	N/D	2ND FLOOR
CAPEN	911492-19	01/04/92	AIR	N/D	1ST FLOOR
CAPEN	931492-21	01/04/92	AIR	N/D	3RD FLOOR
CAPEN	911792-1	01/21/92	AIR	N/D	POST OUT SIDE VAULT
CAPEN	91B12892	01/28/92	AIR	0.06 AS 1260	IN FRONT OF TRANS VAULT
CAPEN	91112892	01/28/92	AIR	0	IN FRONT OF ELEV - 1ST FLOOR
CAPEN	91212892	01/28/92	AIR	N/D	IN FRONT OF ELEV - 2ND FLOOR
CAPEN	91312892	01/28/92	AIR	N/D	IN FRONT OF ELEV - 3RD FLOOR