

ST PARAX BY SAMPLE BY PARAMETER MATRIX CLIENT ID LOCATION REF: RESULT POL ID,SUP LPTR 10:14:37 01-20-92 PAGE

MATRIX	CLIENT ID	LOCATION	REF	RESULT	UNIT	POL
R	91812892/CAPER	BASEMENT/FRONT OF TRANS VAULT	PCB-1221	ND	MCG/MS	0.05
R	91812892/CAPER	BASEMENT/FRONT OF TRANS VAULT	PCB-1221	ND	MCG/MS	0.05
R	91812892/CAPER	BASEMENT/FRONT OF TRANS VAULT	PCB-1232	D	MCG/MS	0.05
R	91812892/CAPER	BASEMENT/FRONT OF TRANS VAULT	PCB-1242	ND	MCG/MS	0.05
R	91812892/CAPER	BASEMENT/FRONT OF TRANS VAULT	PCB-1242	ND	MCG/MS	0.05
R	91812892/CAPER	BASEMENT/FRONT OF TRANS VAULT	PCB-1254	ND	MCG/MS	0.05
R	91812892/CAPER	BASEMENT/FRONT OF TRANS VAULT	PCB-1260	0.05	MCG/MS	0.05
R	91112892/CAPER	FRONT OF ELEVATOR 1ST FLOOR	PCB-1216	ND	MCG/MS	0.05
R	91112892/CAPER	FRONT OF ELEVATOR 1ST FLOOR	PCB-1221	ND	MCG/MS	0.05
R	91112892/CAPER	FRONT OF ELEVATOR 1ST FLOOR	PCB-1232	ND	MCG/MS	0.05
R	91112892/CAPER	FRONT OF ELEVATOR 1ST FLOOR	PCB-1242	ND	MCG/MS	0.05
R	91112892/CAPER	FRONT OF ELEVATOR 1ST FLOOR	PCB-1242	ND	MCG/MS	0.05
R	91112892/CAPER	FRONT OF ELEVATOR 1ST FLOOR	PCB-1254	ND	MCG/MS	0.05
R	91112892/CAPER	FRONT OF ELEVATOR 1ST FLOOR	PCB-1260	0	MCG/MS	0.05
R	91212892/CAPER	FRONT OF ELEVATOR 2ND FLOOR	PCB-1216	ND	MCG/MS	0.05
R	91212892/CAPER	FRONT OF ELEVATOR 2ND FLOOR	PCB-1221	ND	MCG/MS	0.05
R	91212892/CAPER	FRONT OF ELEVATOR 2ND FLOOR	PCB-1232	ND	MCG/MS	0.05
R	91212892/CAPER	FRONT OF ELEVATOR 2ND FLOOR	PCB-1242	ND	MCG/MS	0.05
R	91212892/CAPER	FRONT OF ELEVATOR 2ND FLOOR	PCB-1242	ND	MCG/MS	0.05
R	91212892/CAPER	FRONT OF ELEVATOR 2ND FLOOR	PCB-1254	ND	MCG/MS	0.05
R	91212892/CAPER	FRONT OF ELEVATOR 2ND FLOOR	PCB-1260	ND	MCG/MS	0.05
R	91312892/CAPER	FRONT OF ELEVATOR 3RD FLOOR	PCB-1216	ND	MCG/MS	0.05
R	91312892/CAPER	FRONT OF ELEVATOR 3RD FLOOR	PCB-1221	ND	MCG/MS	0.05
R	91312892/CAPER	FRONT OF ELEVATOR 3RD FLOOR	PCB-1232	ND	MCG/MS	0.05
R	91312892/CAPER	FRONT OF ELEVATOR 3RD FLOOR	PCB-1242	ND	MCG/MS	0.05
R	91312892/CAPER	FRONT OF ELEVATOR 3RD FLOOR	PCB-1242	ND	MCG/MS	0.05
R	91312892/CAPER	FRONT OF ELEVATOR 3RD FLOOR	PCB-1254	ND	MCG/MS	0.05
R	91312892/CAPER	FRONT OF ELEVATOR 3RD FLOOR	PCB-1260	ND	MCG/MS	0.05



