

CAPEN HALL - WIPE SAMPLES

LOCATION	ID #	DATE	TYPE	RESULT	COMMENTS
CAPEN	B-1	12/31/91	WIPE	N/D	LIGHT OUSIDE BS
CAPEN	B-2	12/31/91	WIPE	2.2 as 1260	TOP OF LIGHT-HALLWAY OUTSIDE TRANSFORMER ROOM
CAPEN	B-2A	12/31/91	WIPE	N/D	REKN3
CAPEN	B-3	12/31/91	WIPE	N/D	B7
CAPEN	1-1	12/31/91	WIPE	N/D	SRNO3
CAPEN	1-2	12/31/91	WIPE	N/D	ROOM 110
CAPEN	1-3	12/31/91	WIPE	N/D	LOBBY - BASEMENT
CAPEN	1-4	12/31/91	WIPE	N/D	DIRECTOR OFFICE
CAPEN	2-1	12/31/91	WIPE	N/D	ROOM 208
CAPEN	2-2	12/31/91	WIPE	N/D	SRN06
CAPEN	3-1	12/31/91	WIPE	N/D	SRN07
CAPEN	SWS-9	01/01/92	WIPE	31 as 1260	BOTTOM OF FLOOR B-2
CAPEN	BLDG 9 VAULT	01/04/92	WIPE	830 as 1260	INSIDE VAULT
CAPEN	BLDG 9, ROOM B-2	01/04/92	WIPE	N/D	ROOM B-2
CAPEN	0901010592	01/05/92	WIPE	N/D	1ST FLOOR WINDOW SILL ACROSS FROM STAIRS
CAPEN	0902010592	01/05/92	WIPE	N/D	2ND FLOOR WINDOW SILL ACROSS FROM STAIRS
CAPEN	0903010592	01/05/92	WIPE	N/D	3RD FLOOR WINDOW SILL ACROSS FROM STAIRS
CAPEN	09B1010592	01/05/92	WIPE	1.4 as 1260	OUTSIDE VAULT, TOP OF DOOR SILLS & JAMS
CAPEN	09B2010592	01/05/92	WIPE	N/D	INSIDE VAULTS, 2 RED BOTTOM CONTROL BOXES
CAPEN	911892	01/08/92	WIPE	N/D	ROOM B-9, ON FLOOR UNDER RIGHT BED
CAPEN	92A1892	01/08/92	WIPE	N/D	ROOM B-8, ON FLOOR UNDER RIGHT BED
CAPEN	91A11392	01/13/92	WIPE	N/D	SAGGING MOLDING ACROSS B2
CAPEN	91B11392	01/13/82	WIPE	N/D	LIGHT ABOVE BOARD NEAR B2
CAPEN	91C11392	01/13/92	WIPE	N/D	WATER FOUNTAIN NEAR B4
CAPEN	91D11392	01/13/92	WIPE	.9 as 1260	HAND RAILS OUTSIDE VAULT
CAPEN	9A11692	01/16/92	WIPE	N/D	ELECTRICAL BOX
CAPEN	9C11692	01/16/92	WIPE	N/D	POST OUTSIDE OF VAULT
CAPEN	9B11792B1	01/17/92	WIPE	N/D	ROOM B1
CAPEN	9B11792B2	01/17/92	WIPE	N/D	ROOM B2
CAPEN	9B11792B3	01/17/92	WIPE	N/D	ROOM B3
CAPEN	9B11792B4	01/17/92	WIPE	N/D	ROOM B4
CAPEN	9B11792B5	01/17/92	WIPE	N/D	ROOM B5
CAPEN	9B11792B6	01/17/92	WIPE	N/D	ROOM B6
CAPEN	9B11792B7	01/17/92	WIPE	N/D	ROOM B7
CAPEN	9B11792B8	01/17/92	WIPE	N/D	ROOM B8
CAPEN	9B11792B9	01/17/92	WIPE	N/D	ROOM B9
CAPEN	9B11792B10	01/17/92	WIPE	N/D	ROOM B10
CAPEN	9B11792B11	01/17/92	WIPE	N/D	ROOM B11
CAPEN	9B11792B12	01/17/92	WIPE	N/D	ROOM B12
CAPEN	9B11792B13	01/17/92	WIPE	N/D	ROOM B13
CAPEN	9B11792B14	01/17/92	WIPE	N/D	ROOM B14
CAPEN	9B11792B15	01/17/92	WIPE	N/D	ROOM B15
CAPEN	9B11792B16	01/17/92	WIPE	N/D	ROOM B16
CAPEN	101	01/17/92	WIPE	N/D	ROOM 101
CAPEN	102	01/17/92	WIPE	N/D	ROOM 102
CAPEN	103	01/17/92	WIPE	N/D	ROOM 103
CAPEN	104	01/17/92	WIPE	N/D	ROOM 104

CAPEN HALL - WIPE SAMPLES

(CONTINUED)

ON ID #	DATE	TYPE RESULT	COMMENTS
105	01/17/92	WIPE N/D	ROOM 105
106	01/17/92	WIPE N/D	ROOM 106
107	01/17/92	WIPE N/D	ROOM 107
108	10/17/92	WIPE N/D	ROOM 108
9112992-109	01/29/92	WIPE 0.1 as 1260	ROOM 109
913092-109	01/30/92	WIPE N/D	ROOM 109
113	01/17/92	WIPE N/D	ROOM 113
115	01/17/92	WIPE N/D	ROOM 115
116	01/17/92	WIPE N/D	ROOM 116
117	01/17/92	WIPE N/D	ROOM 117
118	01/17/92	WIPE N/D	ROOM 118
119	01/17/92	WIPE N/D	ROOM 119
911792120	01/17/92	WIPE N/D	ROOM 120
121	01/17/92	WIPE N/D	ROOM 121
9112992-122	01/29/92	WIPE N/D	ROOM 122
123	01/17/92	WIPE N/D	ROOM 123
124	01/17/92	WIPE N/D	ROOM 124
201	01/17/92	WIPE N/D	ROOM 201
202	01/17/92	WIPE N/D	ROOM 202
203	01/17/92	WIPE N/D	ROOM 203
204	01/17/92	WIPE N/D	ROOM 204
205	01/17/92	WIPE N/D	ROOM 205
9112992-206	01/29/92	WIPE N/D	ROOM 206
207	01/17/92	WIPE N/D	ROOM 207
208	01/17/92	WIPE N/D	ROOM 208
209	01/17/92	WIPE N/D	ROOM 209
210	01/17/92	WIPE N/D	ROOM 210
211	01/17/92	WIPE N/D	ROOM 211
212	01/17/92	WIPE N/D	ROOM 212
213	01/17/92	WIPE N/D	ROOM 213
214	01/17/92	WIPE N/D	ROOM 214
215	01/17/92	WIPE N/D	ROOM 215
216	01/17/92	WIPE N/D	ROOM 216
217	01/17/92	WIPE N/D	ROOM 217
218	01/17/92	WIPE N/D	ROOM 218
219	01/17/92	WIPE N/D	ROOM 219
220	01/17/92	WIPE N/D	ROOM 220
221	01/17/92	WIPE N/D	ROOM 221
222	01/17/92	WIPE N/D	ROOM 222
223	01/17/92	WIPE N/D	ROOM 223
224	01/17/92	WIPE N/D	ROOM 224
225	01/17/92	WIPE N/D	ROOM 225
226	01/17/92	WIPE N/D	ROOM 226
227	01/17/92	WIPE N/D	ROOM 227
228	01/17/92	WIPE N/D	ROOM 228
229	01/17/92	WIPE N/D	ROOM 229
230	01/17/92	WIPE N/D	ROOM 230
231	01/17/92	WIPE N/D	ROOM 231
9P2311692-301	01/16/92	WIPE N/D	ROOM 301
9P1511692-302	01/16/92	WIPE N/D	ROOM 302
9P111692-303	01/16/92	WIPE N/D	ROOM 303
9P11692-303B	01/17/92	WIPE N/D	ROOM 303
9P1411692-304	01/16/92	WIPE N/D	ROOM 304
9P2511692-305	01/16/92	WIPE N/D	ROOM 305

ET

RM #6
R #3M

CAPEN HALL - WIPE SAMPLES

(CONTINUED)

<u>LOCATION</u>	<u>ID #</u>	<u>DATE</u>	<u>TYPE</u>	<u>RESULT</u>	<u>COMMENTS</u>
CAPEN	9B12592-0	01/25/92	WIPE	22.0 as 1260	STORAGE ROOM, TOP OF TOASTER OVEN
CAPEN	912792	01/27/92	WIPE	1.9 as 1260	STORAGE ROOM
CAPEN	9112892-1	01/28/92	WIPE	N/D	1ST FLOOR STORE ROOM ELECTRICAL ROOM
CAPEN	9112892-2	01/28/92	WIPE	N/D	1ST FLOOR-OFFICE CLOSET WALL
CAPEN	9212892-1	01/28/92	WIPE	N/D	ELECTRICAL BOX-2ND FLOOR NEXT TO JC13
CAPEN	9212892-2	01/28/92	WIPE	N/D	2ND FLOOR REC ROOM #4
CAPEN	9B12892-JC1	01/28/92	WIPE	N/D	BASEMENT JC1
CAPEN	9B12892-JC2	01/28/92	WIPE	N/D	BASEMENT JC2
CAPEN	21B12892-JC4	01/28/92	WIPE	N/D	JANITOR CLOSET 4-INSIDE DOOR CHAS #9201332-01N
CAPEN	21B12892-JC5	01/28/92	WIPE	N/D	JANITOR CLOSET #5 CHAS #9201332-02N
CAPEN	21B12892-JC6	01/28/92	WIPE	N/D	JANITOR CLOSET #6 CAHS #9201332-03N
CAPEN	21B12892-JC7	01/28/92	WIPE	N/D	JANITOR CLOSET #7 CHAS #9201332-04N
CAPEN	21B12892-JC8	01/28/92	WIPE	N/D	JANITOR CLOSET #8 CHAS #9201332-05N
CAPEN	21B12892-JC9	01/28/92	WIPE	N/D	JANITOR CLOSET #9 CHAS #9201332-06N
CAPEN	21B12892-JC10	01/28/92	WIPE	N/D	JANITOR CLOSET #10 CHAS #9201332-07N
CAPEN	21B12892-JC11	01/28/92	WIPE	N/D	JANITOR CLOSET #11 CHAS #9201332-08N
CAPEN	21212892-JC12	01/28/92	WIPE	N/D	JANITOR CLOSET-JC12 - WALL CHAS #9201334-01N
CAPEN	9212892-JC13	01/28/92	WIPE	N/D	JANITOR CLOSET-JC13
CAPEN	9212892-JC14	01/28/92	WIPE	N/D	JANITOR CLOSET-JC14
CAPEN	9212892-JC15	01/28/92	WIPE	N/D	JANITOR CLOSET-JC15
CAPEN	21212892-JC16	01/28/92	WIPE	N/D	JANITOR CLOSET-JC16 - WALL CHAS #9201334--4N
CAPEN	21312892-JC17	01/28/92	WIPE	N/D	JANITOR CLOSET-JC17 - SINK CHAS #9201334-05N
CAPEN	9312892-JC18	01/28/92	WIPE	N/D	JANITOR CLOSET-JC18
CAPEN	9312892-JC19	01/28/92	WIPE	N/D	JANITOR CLOSET-JC19
CAPEN	9312892-JC20	01/28/92	WIPE	N/D	JANITOR CLOSET-JC20
CAPEN	9312892-JC21	01/28/92	WIPE	N/D	JANITOR CLOSET-JC21
CAPEN	9B12892WR	01/28/92	WIPE	2.2 as 1260	SINK IN WOMENS EMPLOYEE ROOM ACROSS FROM VAULT
CAPEN	9B12892-MR	01/28/92	WIPE	1.2 as 1260	SINK IN MENS EMPLOYEE ROOM ACROSS FROM VAULT
CAPEN	9B12892-S2	01/28/92	WIPE	N/D	MIRROR - BASEMENT STORAGE ROOM 2
CAPEN	9B12892-S3	01/28/92	WIPE	0.1 as 1260	GARBAGE TOP BASEMENT STORAGE ROOM 3
CAPEN	9B13092-1	01/29/92	WIPE		STORAGE ROOM

CAPEN HALL
NEW YORK STATE DEPT. OF HEALTH
WIPE SAMPLE RESULTS

CAPEN	9117921010	01/17/92	WIPE 0.09 as 1260	ROOM 101 DESK TOPS
CAPEN	9117921060	01/17/92	WIPE 0.05 as 1260	ROOM 106 DESK TOP
CAPEN		01/ /92	WIPE 0.71 as 1260	ELECTRICAL BOX COVER IN ELECTRICAL PANEL ROOM NEXT TO VAULT
CAPEN	92B1892	01/08/92	WIPE 0.33 as 1260	ROOM 8 ON FLOOR UNDER RIGHT BED
CAPEN	0901010592	01/06/92	WIPE 0.42 as 1260	WINDOW SILL ACROSS FROM STAIRS- 2ST FLOOR

CAPEN HALL

2,3,7,8,-TCDD Equivalent (ng/sq.m)

2,3,7,8-TCDD equivalents are below detection limits. See attached ETC summary report.