



STATE OF NEW YORK DEPARTMENT OF HEALTH

Office of Public Health

11 University Place

Albany, New York 12203-3399

Barbara A. DeBuono, M.D., M.P.H.
Commissioner

Karen Schimke
Executive Deputy Commissioner

Arnold Bernadini
Assistant Vice President
for Facilities & Planning
SUNY College at New Paltz
75 South Mannheim Boulevard
New Paltz, N.Y. 12561

August 11, 1997

Dear Mr. Bernadini:

The analytical results of the PCB (polychlorinated biphenyl) wipe and air samples collected on June 24, 1997 are enclosed. These samples were collected in Gage Hall and Coykendall Science Building to complete the quarterly sampling of encapsulated areas in these buildings according to the protocol proposed by Clean Harbors Environmental Services Inc. in their May 30, 1996 report. Sampling and analysis was conducted in accordance with the established cleanup project protocols.

Eight wipe and two air samples were collected and analyzed at the New York State Department of Health Laboratory. One wipe sample could not be analyzed due to damage to the sample container during transit to the laboratory. All results are listed in the enclosed tables.

None of the wipe or air samples exceeded the PCB cleanup criteria of 1 microgram per 100 square centimeter (MCG/100 Sq.Cm.) and 1 microgram per cubic meter (MCG/CU.M.) respectively. The highest wipe result was 0.42 MCG/100Sq.Cm. from a sample collected in the Gage transformer vault. Half of the wipe sample results were below the method detection limit of 0.05 MCG. The air sample collected in the Gage Hall transformer vault had a PCB level of 0.30 MCG/CU.M. The Coykendall transformer vault air sample had a PCB level below the 0.01 MCG/CU.M method detection limit.

These results indicate that the requirements described in the May 30, 1996 report for two years of wipe and air sample results below the project cleanup criteria have been satisfied for these buildings. Future sampling will be conducted according to a schedule proposed by your department and approved by the Ulster County Department of Health in consultation with the N.Y.S Department of Health.

Water samples were collected from the 14 monitoring wells located near affected building on July 22 and July 24, 1997. Analysis of these samples has not been completed. After you receive these results you should contact Keith Browne of the NYS Department of Environmental Conservation (DEC) concerning the future sample collection schedule. Monitoring well CB-3, near the Coykendall Science Building, could not be sampled due to an obstruction in the casing. This well should be abandoned according to procedures developed by the NYS DEC.

If you have any questions please call me at (914) 794-2045.

Sincerely,

Mark Knudsen
Regional Toxics Coordinator

cc: J. Hawley
S. Bates
A. Dumas
K. Browne
J. Coffey




TABLE 2
 PCB AIR SAMPLE RESULTS
 (micrograms per cubic meter)

LOCATION	PCB AROCLORS DETECTED		
	1016/1242	1254	1260
Gage Hall Transformer Vault			0.30
Coykendall Transformer Vault	0.29	0.36	<0.01 ¹
Trip Blank	ND ²	ND	ND

¹ Not detected above the method detection limit of 0.01 MCG/CU.M.

² Not detected

TABLE 1
 PCB WIPE SAMPLE RESULTS
 (Micrograms/100 sq. cm.)

LOCATION	SAMPLE ID	PCB AROCLOR 1260
<u>Gage Hall</u>		
Vault, south door beam	G-Beam #1	0.42
Vault door columns	G-Col #1	0.09
<u>Coykendall Science Building</u>		
Electric room columns	C-Mer Col #1	0.09
Electric room columns	C-Mer Col #2	[SL] ¹
Vault, east wall	C-Mer Wall #1	0.06 ²
Electric room, east wall	C-Mer Wall #2	<0.05 ³
Electric room ceiling	C-Mer Ceiling #1	<0.05
Vault & Elec room ceilings	C-Mer Ceiling #2	<0.05
Vault & Elec room beams	C-Mer Beam	<0.05

¹ Sample leaked or was damaged in transit and could not be analyzed

² Aroclors 1016/1242 were detected in this sample below the method detection limit


³ Not detected above the method detection limit of 0.5 MCG/100 sq. cm

SAMPLE ID: 9701261 SAMPLE RECEIVED: 97/06/27/ CHARGE: 4.00
 PROGRAM: 870: SUNY @ NEW PALTZ
 SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
 POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
 LATITUDE: LONGITUDE: Z DIRECTION:
 LOCATION: SUNNY NEW PALTZ PCB SPILL
 DESCRIPTION: GAGE, VAULT DOOR COLUMNS, G-COL #1
 REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
 TEST PATTERN: PCBWP: PCB'S IN WIPES
 SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
 TIME OF SAMPLING: 97/06/24 : DATE PRINTED: 97/08/06

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
 DATE PRINTED: 97/08/06 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.84 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****



NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
 COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
 C/O NY STATE DEPARTMENT OF HEALTH
 MONTICELLO DISTRICT OFFICE
 6 PRINCE ST.
 MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

PAGE 1

RESULTS OF EXAMINATION


FINAL REPORT

SAMPLE ID: 9701265 SAMPLE RECEIVED: 97/06/27/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNNY NEW PALTZ PCB SPILL
DESCRIPTION: GAGE, VAULT SOUTH DOOR BEAM G-BEAM #1
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/06/24 DATE PRINTED: 97/08/06

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
DATE PRINTED: 97/08/06 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	3.8 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****



NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

SAMPLE ID: 9701262 SAMPLE RECEIVED: 97/06/27/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNNY NEW PALTZ PCB SPILL
DESCRIPTION: COYKENDALL, VAULT AND ELECTRIC ROOM CEILINGS, C-MER CEILING
DESCRIPTION: #2
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/06/24 DATE PRINTED: 97/08/06

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
DATE PRINTED: 97/08/06 FINAL REPORT

PARAMETER	RESULT
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.12 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

PAGE 1

RESULTS OF EXAMINATION

FINAL REPORT

SAMPLE ID: 9701263 SAMPLE RECEIVED: 97/06/27/ CHARGE: 4.00
PROGRAM: 870:SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNNY NEW PALTZ PCB SPILL
DESCRIPTION: COYKENDALL, ELEC ROOM COLUMNS C-MER COL #1
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/06/24 : DATE PRINTED: 97/08/06

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
DATE PRINTED: 97/08/06 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.85 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

PAGE 1

RESULTS OF EXAMINATION

FINAL REPORT

SAMPLE ID: 9701264 SAMPLE RECEIVED: 97/06/27/ CHARGE: 4.00
PROGRAM: 870:SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN:13 GAZETTEER CODE:5522
POLITICAL SUBDIVISION:NEW PALTZ V. COUNTY:ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNNY NEW PALTZ PCB SPILL
DESCRIPTION:COYKENDALL, ELECTRIC RM EAST WALL C-MER WALL #2
REPORTING LAB: TOX:LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP:PCB'S IN WIPES
SAMPLE TYPE: 947:SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/06/24 DATE PRINTED:97/08/06

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
DATE PRINTED: 97/08/06 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.11 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

***** END OF REPORT *****

AUG 1997
MONTICELLO DISTRICT OFFICE

NYS ELAP ID'S: 10762 (INORGANIC,NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY:KNUDSEN

WADSWORTH CENTER

PAGE 1

RESULTS OF EXAMINATION

FINAL REPORT

SAMPLE ID: 9701266 SAMPLE RECEIVED: 97/06/27/ CHARGE: 4.00
 PROGRAM: 870: SUNY @ NEW PALTZ
 SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
 POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
 LATITUDE: LONGITUDE: Z DIRECTION:
 LOCATION: SUNNY NEW PALTZ PCB SPILL
 DESCRIPTION: COYKENDALL, VAULT EAST WALL, C-MER WALL #1
 REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
 TEST PATTERN: PCBWP: PCB'S IN WIPES
 SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
 TIME OF SAMPLING: 97/06/24 : DATE PRINTED: 97/08/06

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
 DATE PRINTED: 97/08/06 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	0.09 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.53 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
 COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
 C/O NY STATE DEPARTMENT OF HEALTH
 MONTICELLO DISTRICT OFFICE
 6 PRINCE ST.
 MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

PAGE 1

RESULTS OF EXAMINATION

FINAL REPORT

SAMPLE ID: 9701267 SAMPLE RECEIVED: 97/06/27/ CHARGE: 4.00
 PROGRAM: 870:SUNY @ NEW PALTZ
 SOURCE ID: DRAINAGE BASIN:13. GAZETTEER CODE:5522
 POLITICAL SUBDIVISION:NEW PALTZ V. COUNTY:ULSTER
 LATITUDE: LONGITUDE: Z DIRECTION:
 LOCATION: SUNNY NEW PALTZ PCB SPILL
 DESCRIPTION:COYKENDALL, ELECTRIC ROOM CEILING C-MER CEILING #1
 REPORTING LAB: TOX:LAB FOR ORGANIC ANALYTICAL CHEMISTRY
 TEST PATTERN: PCBWP:PCB'S IN WIPES
 SAMPLE TYPE: 947:SURFACE WIPE USING SOLVENT
 TIME OF SAMPLING: 97/06/24 : DATE PRINTED:97/08/06

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
 DATE PRINTED: 97/08/06 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.29 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

MONTICELLO DISTRICT

NYS ELAP ID'S: 10762 (INORGANIC,NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
 COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
 C/O NY STATE DEPARTMENT OF HEALTH
 MONTICELLO DISTRICT OFFICE
 6 PRINCE ST.
 MONTICELLO, NY 12701

SUBMITTED BY:KNUDSEN

PAGE 1

RESULTS OF EXAMINATION


FINAL REPORT

SAMPLE ID: 9701268 SAMPLE RECEIVED: 97/06/27/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNNY NEW PALTZ PCB SPILL
DESCRIPTION: COYKENDALL, VAULT & ELECTRIC RM BEAMS C-MER BEAM
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/06/24 DATE PRINTED: 97/08/06

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3) FINAL REPORT
DATE PRINTED: 97/08/06

-----PARAMETER-----	-----RESULT-----
AROCOR 1221	< 0.05 MCG
AROCOR 1016/1242	< 0.05 MCG
AROCOR 1248	< 0.05 MCG
AROCOR 1254	< 0.05 MCG
AROCOR 1260	0.22 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****



NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

PAGE 1

RESULTS OF EXAMINATION

FINAL REPORT

SAMPLE ID: 9701269 SAMPLE RECEIVED: 97/06/27/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNNY NEW PALTZ PCB SPILL
DESCRIPTION: COYKENDALL, ELECTRIC RM COLUMN C-MER COL #2
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/06/24 DATE PRINTED: 97/08/06

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
DATE PRINTED: 97/08/06 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	[SL]
AROCLOR 1016/1242	[SL]
AROCLOR 1248	[SL]
AROCLOR 1254	[SL]
AROCLOR 1260	[SL]
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.
**** END OF REPORT ****	

JG 1997

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

SAMPLE ID: 9701260 SAMPLE RECEIVED: 97/06/27/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNNY NEW PALTZ PCB SPILL
DESCRIPTION: TRIP BLANK SAMPLE #9701258,59
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBA: PCBs in AIR
SAMPLE TYPE: 950: CONTROL - AIR CARTRIDGE BLANK
TIME OF SAMPLING: 97/06/24 DATE PRINTED: 97/07/18

ANALYSIS: PCBA PCBs IN AIR (DES 311-1) FINAL REPORT
DATE PRINTED: 97/07/18

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	[ND]
AROCLOR 1016/1242	[ND]
AROCLOR 1248	[ND]
AROCLOR 1254	[ND]
AROCLOR 1260	[ND]
AIR VOLUME	NONE

**** END OF REPORT ****

24

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

PAGE 1

RESULTS OF EXAMINATION

FINAL REPORT

SAMPLE ID: 9701259 SAMPLE RECEIVED: 97/06/27/ CHARGE: 4.00
 PROGRAM: 870:SUNY @ NEW PALTZ
 SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
 POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
 LATITUDE: LONGITUDE: Z DIRECTION:
 LOCATION: SUNNY NEW PALTZ PCB SPILL
 DESCRIPTION: GAGE VAULT
 DESCRIPTION: CART #109651, 109642
 REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
 TEST PATTERN: PCBA: PCBs in AIR
 SAMPLE TYPE: 902: AMBIENT AIR - INDOOR
 TIME OF SAMPLING: 97/06/24 : DATE PRINTED: 97/07/18

ANALYSIS: PCBA PCBs IN AIR (DES 311-1)
 DATE PRINTED: 97/07/18

FINAL REPORT

PARAMETER	RESULT
AROCLOR 1221	< 0.01 MCG/CU.M.
AROCLOR 1016/1242	< 0.01 MCG/CU.M.
AROCLOR 1248	< 0.01 MCG/CU.M.
AROCLOR 1254	< 0.01 MCG/CU.M.
AROCLOR 1260	0.30 MCG/CU.M.
AIR VOLUME	0.193 CU.M.

**** END OF REPORT ****

24 '00'

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
 COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
 C/O NY STATE DEPARTMENT OF HEALTH
 MONTICELLO DISTRICT OFFICE
 6 PRINCE ST.
 MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

SAMPLE ID: 9701258 SAMPLE RECEIVED: 97/06/27/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNNY NEW PALTZ PCB SPILL
DESCRIPTION: COYKENDALL MER VAULT
DESCRIPTION: CART #'S 109658, 109657
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBA: PCBs in AIR
SAMPLE TYPE: 902: AMBIENT AIR - INDOOR
TIME OF SAMPLING: 97/06/24 : DATE PRINTED: 97/07/18

ANALYSIS: PCBA PCBs IN AIR (DES 311-1)
DATE PRINTED: 97/07/18 FINAL REPORT

PARAMETER	RESULT
AROCLOR 1221	< 0.01 MCG/CU.M.
AROCLOR 1016/1242	0.29 MCG/CU.M.
AROCLOR 1248	< 0.01 MCG/CU.M.
AROCLOR 1254	0.36 MCG/CU.M.
AROCLOR 1260	< 0.01 MCG/CU.M.
AIR VOLUME	0.195 CU.M.

**** END OF REPORT ****

41897

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN