

SAMPLE ID: 9700469 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNY NEW PALTZ
DESCRIPTION: C-MER WALL #1, COYKENDALL, EAST WALL INSIDE FORMER VAULT
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/03/10 DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3) FINAL REPORT
DATE PRINTED: 97/04/01

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	0.06 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	1.4 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

APR = 7 1997

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

SAMPLE ID: 9700468 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNY NEW PALTZ
DESCRIPTION: C-MER WALL #2, COYKENDALL, EAST WLL IN FORMER ELEC RM
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/03/10 DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3) FINAL REPORT
DATE PRINTED: 97/04/01

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.5 MCG
AROCLOR 1016/1242	0.05 MCG [PL]
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.82 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

PAGE 1

RESULTS OF EXAMINATION

FINAL REPORT

SAMPLE ID: 9700467 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNY NEW PALTZ
DESCRIPTION: C-MER CEILING #1, COYKENDALL, CEILING SOUTH END OF FORMER
DESCRIPTION: ELECTRIC ROOM
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/03/10 : DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
DATE PRINTED: 97/04/01 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.40 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

PAGE 1

RESULTS OF EXAMINATION

FINAL REPORT

SAMPLE ID: 9700466 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNY NEW PALTZ
DESCRIPTION: C-MER CEILING #2, COYKENDALL, CEILING OF NORTH END ELEC
DESCRIPTION: ROOM AND VAULT
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/03/10 : DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
DATE PRINTED: 97/04/01

FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.16 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

PAGE 1

RESULTS OF EXAMINATION

FINAL REPORT

SAMPLE ID: 9700465 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
PROGRAM: 870:SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNY NEW PALTZ
DESCRIPTION: C-MER BEAM, COYKENDALL, BEAMS IN FORMER VAULT & ELEC RMS
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/03/10 DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
DATE PRINTED: 97/04/01

FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.16 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO(1), RO(0), LPHE(1), FED(), INFO-P(), INFO-L(), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

WADSWORTH CENTER

PAGE 1

RESULTS OF EXAMINATION

FINAL REPORT

SAMPLE ID: 9700464 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNY NEW PALTZ
DESCRIPTION: C-MER COLUMN #1, COYKENDALL, COLUMNS-FORMER TRANSFMR VAULT
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/03/10 : DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
DATE PRINTED: 97/04/01 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	0.55 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	3.9 MCG
AREA OF WIPE IN SQUARE METER.	0.09 SQ. M.

**** END OF REPORT ****



NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

SAMPLE ID: 9700474 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
 PROGRAM: 870: SUNY @ NEW PALTZ
 SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
 POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
 LATITUDE: LONGITUDE: Z DIRECTION:
 LOCATION: SUNY NEW PALTZ
 DESCRIPTION: S-BEAM #2, SCUDDER HALL, WEST & SOUTH BEAMS
 REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
 TEST PATTERN: PCBWP: PCB'S IN WIPES
 SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
 TIME OF SAMPLING: 97/03/10 : DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
 DATE PRINTED: 97/04/01 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.75 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
 COPIES SENT TO: CO(1), RO(0), LPHE(1), FED(), INFO-P(), INFO-L(), 405

MARK KNUDSEN
 C/O NY STATE DEPARTMENT OF HEALTH
 MONTICELLO DISTRICT OFFICE
 6 PRINCE ST.
 MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

SAMPLE ID: 9700473 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNY NEW PALTZ
DESCRIPTION: S-GRADE BEAM, SCUDDER HALL, EXTERIOR GRADE BEAM, EAST SIDE
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/03/11 DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
DATE PRINTED: 97/04/01 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	1.0 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

DP = 7

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

PAGE 1

RESULTS OF EXAMINATION

FINAL REPORT

SAMPLE ID: 9700475 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
 PROGRAM: 870: SUNY @ NEW PALTZ
 SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
 POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
 LATITUDE: LONGITUDE: Z DIRECTION:
 LOCATION: SUNY NEW PALTZ
 DESCRIPTION: S BEAM #1, SCUDDER HALL, EAST WALL BEAM
 REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
 TEST PATTERN: PCBWP: PCB'S IN WIPES
 SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
 TIME OF SAMPLING: 97/03/10 DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
 DATE PRINTED: 97/04/01

FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	0.05 MCG [PL]
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.49 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
 COPIES SENT TO: CO(1), RO(0), LPHE(1), FED(), INFO-P(), INFO-L(), 405

MARK KNUDSEN
 C/O NY STATE DEPARTMENT OF HEALTH
 MONTICELLO DISTRICT OFFICE
 6 PRINCE ST.
 MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

SAMPLE ID: 9700472 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNY NEW PALTZ
DESCRIPTION: S-COLUMN, SCUDDER HALL, SOUTH COLUMN NEAR DOOR
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/03/10 DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
DATE PRINTED: 97/04/01 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	< 0.05 MCG
AREA OF WIPE IN SQUARE METER.	0.09 SQ. M.

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO(1), RO(0), LPHE(1), FED(), INFO-P(), INFO-L(), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

PAGE 1

RESULTS OF EXAMINATION

FINAL REPORT

SAMPLE ID: 9700476 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
 PROGRAM: 870: SUNY @ NEW PALTZ
 SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
 POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
 LATITUDE: LONGITUDE: Z DIRECTION:
 LOCATION: SUNY NEW PALTZ
 DESCRIPTION: G-COLUMN #1, GAGE HALL, TRANSFORMER VAULT - COLUMNS
 REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
 TEST PATTERN: PCBWP: PCB'S IN WIPES
 SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
 TIME OF SAMPLING: 97/03/10 : DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
 DATE PRINTED: 97/04/01 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	2.7 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

*** END OF REPORT ***

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
 COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
 C/O NY STATE DEPARTMENT OF HEALTH
 MONTICELLO DISTRICT OFFICE
 6 PRINCE ST.
 MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

SAMPLE ID: 9700477 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNY NEW PALTZ
DESCRIPTION: G-BEAM #1, GAGE HALL, SOUTH DOOR BEAM
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/03/10 DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
DATE PRINTED: 97/04/01 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	2.0 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

1080

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER

405

PAGE 1

RESULTS OF EXAMINATION

FINAL REPORT

SAMPLE ID: 9700478 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNY NEW PALTZ
DESCRIPTION: G-BEAM #2, GAGE HALL, BEAM ABOVE DOOR
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/03/10 : DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
DATE PRINTED: 97/04/01 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	2.2 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

PAGE 1

RESULTS OF EXAMINATION

FINAL REPORT

SAMPLE ID: 9700460 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
 PROGRAM: 870: SUNY @ NEW PALTZ
 SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
 POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
 LATITUDE: LONGITUDE: Z DIRECTION:
 LOCATION: SUNY NEW PALTZ
 DESCRIPTION: B-EXT GRADE BEAM, BLISS, EXT GRADE BEAM BEHIND FENCED AREA
 REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
 TEST PATTERN: PCBWP: PCB'S IN WIPES
 SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
 TIME OF SAMPLING: 97/03/10 DATE PRINTED: 97/04/01

ANALYSIS: PCBWP: PCB'S IN WIPES (DES 312-3)
 DATE PRINTED: 97/04/01 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.36 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
 COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
 C/O NY STATE DEPARTMENT OF HEALTH
 MONTICELLO DISTRICT OFFICE
 6 PRINCE ST.
 MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

PAGE 1

RESULTS OF EXAMINATION

FINAL REPORT

SAMPLE ID: 9700461 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
 PROGRAM: 870: SUNY @ NEW PALTZ
 SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
 POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
 LATITUDE: LONGITUDE: Z DIRECTION:
 LOCATION: SUNY NEW PALTZ
 DESCRIPTION: B-Vault #2, Bliss Hall, West Top Beam and West Column
 REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
 TEST PATTERN: PCBWP: PCB'S IN WIPES
 SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
 TIME OF SAMPLING: 97/03/10 DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
 DATE PRINTED: 97/04/01 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.35 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
 COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
 C/O NY STATE DEPARTMENT OF HEALTH
 MONTICELLO DISTRICT OFFICE
 6 PRINCE ST.
 MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

SAMPLE ID: 9700462 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNY NEW PALTZ
DESCRIPTION: B-VAULT #1, BLISS HALL, SOUTH TOP BEAM & EAST COLUMN
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/03/10 : DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3) FINAL REPORT
DATE PRINTED: 97/04/01

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.21 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

APR - 7 1997

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

SAMPLE ID: 9700463 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNY NEW PALTZ
DESCRIPTION: B-ELEC ROOM, BLISS HALL ELECTRIC ROOM, CEILING BEAM
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/03/10 DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3) FINAL REPORT
DATE PRINTED: 97/04/01

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	0.09 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	3.3 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

RR

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

SAMPLE ID: 9700459 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
 PROGRAM: 870: SUNY @ NEW PALTZ
 SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
 POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
 LATITUDE: LONGITUDE: Z DIRECTION:
 LOCATION: SUNY NEW PALTZ
 DESCRIPTION: P-VAULT #1, PARKER THEATER, TRANSFORMER - VAULT EAST WALL
 REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
 TEST PATTERN: PCBWP: PCB'S IN WIPES
 SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
 TIME OF SAMPLING: 97/03/10 DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
 DATE PRINTED: 97/04/01 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	0.17 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	2.0 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

APA - 7 25

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
 COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
 C/O NY STATE DEPARTMENT OF HEALTH
 MONTICELLO DISTRICT OFFICE
 6 PRINCE ST.
 MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

PAGE 1

RESULTS OF EXAMINATION

FINAL REPORT

SAMPLE ID: 9700458 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
 PROGRAM: 870: SUNY @ NEW PALTZ
 SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
 POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
 LATITUDE: LONGITUDE: Z DIRECTION:
 LOCATION: SUNY NEW PALTZ
 DESCRIPTION: P-Vault 2, PARKER THEATER, TRANSFORMER VAULT - SOUTH WALL
 REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
 TEST PATTERN: PCBWP: PCB'S IN WIPES
 SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
 TIME OF SAMPLING: 97/03/10 : DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
 DATE PRINTED: 97/04/01

FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	0.24 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	1.7 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
 COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
 C/O NY STATE DEPARTMENT OF HEALTH
 MONTICELLO DISTRICT OFFICE
 6 PRINCE ST.
 MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

SAMPLE ID: 9700457 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNY NEW PALTZ
DESCRIPTION: P-ELEC RM #1, PARKER THEATER, ELECTRIC RM SOUTH & WEST WLL
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/03/10 DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3) FINAL REPORT
DATE PRINTED: 97/04/01

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	0.05 MCG [PL]
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.25 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

PAGE 1

RESULTS OF EXAMINATION

FINAL REPORT

SAMPLE ID: 9700456 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNY NEW PALTZ
DESCRIPTION: P-ELEC RM #2, PARKER THEATER, ELECTRIC RM NORTH & EAST WLL
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/03/10 DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
DATE PRINTED: 97/04/01 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	0.05 MCG [PL]
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.24 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

AD
46-7

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

SAMPLE ID: 9700479 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
 PROGRAM: 870: SUNY @ NEW PALTZ
 SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
 POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
 LATITUDE: LONGITUDE: Z DIRECTION:
 LOCATION: SUNY NEW PALTZ
 DESCRIPTION: MOIST WIPE BLANK
 REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
 TEST PATTERN: PCBWP: PCB'S IN WIPES
 SAMPLE TYPE: 285: FIELD BLANK - ORIGINATES IN THE FIELD
 TIME OF SAMPLING: 97/03/10 : DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
 DATE PRINTED: 97/04/01 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	< 0.05 MCG
AREA OF WIPE IN SQUARE METER	NONE

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
 COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
 C/O NY STATE DEPARTMENT OF HEALTH
 MONTICELLO DISTRICT OFFICE
 6 PRINCE ST.
 MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

SAMPLE ID: 9700480 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNY NEW PALTZ
DESCRIPTION: DRY WIPE BLANK
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 285: FIELD BLANK - ORIGINATES IN THE FIELD
TIME OF SAMPLING: 97/03/11 : DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
DATE PRINTED: 97/04/01 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	< 0.05 MCG
AREA OF WIPE IN SQUARE METER	NONE

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

SAMPLE ID: 9700453 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNY NEW PALTZ
DESCRIPTION: PARKER THEATER, P-Vault BEAM, EXTERIOR Vault GRADE BEAM
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/03/10 DATE PRINTED: 97/04/01

ANALYSIS: PCBWP: PCB'S IN WIPES (DES 312-3) FINAL REPORT
DATE PRINTED: 97/04/01

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.05 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO(1), RO(0), LPHE(1), FED(), INFO-P(), INFO-L(), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701


SUBMITTED BY: KNUDSEN

SAMPLE ID: 9700452 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
 PROGRAM: 870: SUNY @ NEW PALTZ
 SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
 POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
 LATITUDE: LONGITUDE: Z DIRECTION:
 LOCATION: SUNY NEW PALTZ
 DESCRIPTION: P-TEMPLATE, 100CMSQ METAL TEMPLATE SURFACE
 REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
 TEST PATTERN: PCBWP: PCB'S IN WIPES
 SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
 TIME OF SAMPLING: 97/03/10 : DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
 DATE PRINTED: 97/04/01 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.08 MCG
AREA OF WIPE IN SQUARE METER	0.021 SQ. M.

**** END OF REPORT ****



NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
 COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
 C/O NY STATE DEPARTMENT OF HEALTH
 MONTICELLO DISTRICT OFFICE
 6 PRINCE ST.
 MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

SAMPLE ID: 9700455 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNY NEW PALTZ
DESCRIPTION: P-LOADD1, PARKER THEATER, LOADING DOCK FACE
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/03/10 DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES. 312-3) FINAL REPORT
DATE PRINTED: 97/04/01

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.05 MCG
AREA OF WIPE IN SQUARE METER	0.05 SQ. M.

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO(1), RO(0), LPHE(1), FED(), INFO-P(), INFO-L(), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

PAGE 1

RESULTS OF EXAMINATION

FINAL REPORT

SAMPLE ID: 9700454 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNY NEW PALTZ
DESCRIPTION: P-LOADD 2, PARKER THEATER, LOADING DOCK FACE
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/03/10 DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
DATE PRINTED: 97/04/01 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.05 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****

NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN

PAGE 1

RESULTS OF EXAMINATION


FINAL REPORT

SAMPLE ID: 9700470 SAMPLE RECEIVED: 97/03/12/ CHARGE: 4.00
PROGRAM: 870: SUNY @ NEW PALTZ
SOURCE ID: DRAINAGE BASIN: 13 GAZETTEER CODE: 5522
POLITICAL SUBDIVISION: NEW PALTZ V. COUNTY: ULSTER
LATITUDE: LONGITUDE: Z DIRECTION:
LOCATION: SUNY NEW PALTZ
DESCRIPTION: C-MER COLUM #2, COYKENDALL, COLUMNS IN FORMER ELECTRIC RM
REPORTING LAB: TOX: LAB FOR ORGANIC ANALYTICAL CHEMISTRY
TEST PATTERN: PCBWP: PCB'S IN WIPES
SAMPLE TYPE: 947: SURFACE WIPE USING SOLVENT
TIME OF SAMPLING: 97/03/10 : DATE PRINTED: 97/04/01

ANALYSIS: PCBWP PCB'S IN WIPES (DES 312-3)
* DATE PRINTED: 97/04/01 FINAL REPORT

-----PARAMETER-----	-----RESULT-----
AROCLOR 1221	< 0.05 MCG
AROCLOR 1016/1242	< 0.05 MCG
AROCLOR 1248	< 0.05 MCG
AROCLOR 1254	< 0.05 MCG
AROCLOR 1260	0.46 MCG
AREA OF WIPE IN SQUARE METER	0.09 SQ. M.

**** END OF REPORT ****



NYS ELAP ID'S: 10762 (INORGANIC, NUCLEAR) 10763 (ORGANIC) 10765 (BACTERIOLOGY)
COPIES SENT TO: CO (1), RO (0), LPHE (1), FED (), INFO-P (), INFO-L (), 405

MARK KNUDSEN
C/O NY STATE DEPARTMENT OF HEALTH
MONTICELLO DISTRICT OFFICE
6 PRINCE ST.
MONTICELLO, NY 12701

SUBMITTED BY: KNUDSEN