


Building # 1 (OM)

Old Main Building

Edwards


- FIRE ALARMS
- P.M. EXT.
- CO₂ EXT.
- A.B.C. EXT.
- GENERATOR
- △ FIRE PANEL

SUNY New Paltz 8/75
Safety Office




Sub-Basement Plan

Building # 1 (OM)
CIG MAN BUILDING




BASEMENT PLAN

Old Main Building




1st Floor Plan

Old Main Building




2ND FLOOR PLAN

Old Main Building



Old MAIN BUILDING



PENT HOUSE PLAN



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: SWS-7, OLD MAIN
Sample Type: Wipe

CHAS Lab #: 9201009-07N
Date Received: 01/02/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 01/02/91
Analysis Date: 01/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 100 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.