

			<u>ELEVATOR SAMPLES</u>		
<u>LOCATION</u>	<u>ID #</u>	<u>DATE</u>	<u>TYPE</u>	<u>RESULTS</u>	<u>COMMENTS</u>
BLISS (1 @ 900 sq cm)	225192-BELV	5/01/92	WIPE	0.3 as 1260	BASEMENT ELEVATOR DOOR- INSIDE SHAFT
BLISS (1 @ 900 sq cm)	225192-1ELV	5/01/92	WIPE	0.2 as 1260	1ST FLOOR ELEVATOR DOOR- INSIDE SHAFT
BLISS (1 @ 900 sq cm)	225192-2ELV	5/01/92	WIPE	0.2 as 1260	2ND FLOOR ELEVATOR DOOR- INSIDE SHAFT
BLISS (1 @ 900 sq cm)	225192-3ELV	5/01/92	WIPE	0.2 as 1260	3RD FLOOR ELEVATOR DOOR- INSIDE SHAFT
BLISS	224192-ELEV1	04/01/92	WIPE	0.1 as 1260	1ST FL ELEVATOR JAM DOORWAY AND ABOVE
BLISS	224192-ELEV3	04/01/92	WIPE	1.3 as 1260	3RD FL ELEVATOR JAM DOORWAY AND ABOVE
BLISS (1 @ (30 cm X 30 cm))	224992-EL1	04/09/92	WIPE	N/D	<u>ELEVATOR SHAFT</u> <u>CEILING OF ELEVATOR SHAFT</u>
BLISS (1 @ (30 cm X 30 cm))	224992-EL2	04/09/92	WIPE	1.7 as 1260	<u>ELEVATOR SHAFT - ROOF OF</u> <u>ELEVATOR CAR</u>

Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2231992-ELEV. BLISS
Sample Type: Wipe

CHAS Lab #: 9203285-01N
Date Received: 03/20/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 03/20/92
Analysis Date: 03/22/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	1.9	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 225192-BELV BLISS
Sample Type: Wipe

GHAS Lab #: 9205013-09N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/06/92
Analysis Date: 05/10/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.3	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 225192-1ELV BLISS
Sample Type: Wipe

CHAS Lab #: 9205013-06N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/06/92
Analysis Date: 05/10/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 225192-2ELV BLISS
Sample Type: Wipe

CHAS Lab #: 9205013-04N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/06/92

Analysis Date: 05/10/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 225192-3ELV BLISS
Sample Type: Wipe

CHAS Lab #: 9205013-02N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/06/92

Analysis Date: 05/09/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 224192-ELEV1 BLISS
Sample Type: Wipe

CHAS Lab #: 9204073-01N
Date Received: 04/06/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/06/92
Analysis Date: 04/10/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.1	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 224192-ELEV3 BLISS
Sample Type: Wipe

CHAS Lab #: 9204073-02N
Date Received: 04/06/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/06/92
Analysis Date: 04/10/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	1.3	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 224992-EL1 BLISS
Sample Type: Wipe

CHAS Lab #: 9204195-01N
Date Received: 04/10/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/14/92
Analysis Date: 04/16/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 224992-EL2 BLISS
Sample Type: Wipe

CHAS Lab #: 9204195-02N
Date Received: 04/10/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/14/92
Analysis Date: 04/16/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	1.7	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.