

BLISS VAULT SAMPLES

LOCATION	ID #	DATE	TYPE	RESULTS	COMMENTS
BLISS	2222492-1 (9 @ (10 cm X 10 cm))	02/24/92	WIPE	63 as 1260	RED BRICK WALL W/DOOR POST-CLEAN VAULT
BLISS	2222492-2 (9 @ (10 cm X 10 cm))	02/24/92	WIPE	29 as 1260	WALL WHERE TRANS REMOVED POST-CLEAN VAULT
BLISS	2222492-3 (9 @ (10 cm X 10 cm))	02/24/92	WIPE	15 as 1260	VAULT CEILING POST-CLEAN VAULT
BLISS	2222492-4 X 10 cm))	02/24/92	WIPE	27 as 1260	WALL WITH WINDOWS (9 @ (10 cm POST-CLEAN VAULT
BLISS	2222492-5 (9 @ (10 cm X 10 cm))	02/24/92	WIPE	1100 as 1260	FLOOR POST-CLEAN VAULT
BLISS	2222492-6 (9 @ (10 cm X 10 cm))	02/24/92	WIPE	24 as 1260	INSIDE WALL ON LEFT POST-CLEAN VAULT
BLISS	224292-CEL (9 @ (10 cm X 10 cm))	04/02/92	WIPE	1.9 as 1260	VAULT CEILING
BLISS	2291192-VLTCLNG (9 @ (10 cm X 10 cm))	09/11/92	WIPE	0.4 as 1260	CEILING - EPA GRID POST CLEAN
BLISS	224292-FL (9 @ (10 cm X 10 cm))	04/02/92	WIPE	3100 as 1260	VAULT FLOOR
BLISS	224292-A (9 @ (10 cm X 10 cm))	04/02/92	WIPE	19 as 1260	WALL "A"- EAST WALL PRE-CLEAN
BLISS	2291192-VLTEW (9 @ (10 cm X 10 cm))	09/11/92	WIPE	15 as 1260	EAST WALL - EPA GRID POST CLEAN
BLISS	224292-B (9 @ (10 cm X 10 cm))	04/02/92	WIPE	11 as 1260	WALL "B" - SOUTH WALL PRE-CLEAN
BLISS	2291192-VLTSW (9 @ (10 cm X 10 cm))	09/11/92	WIPE	40 as 1260	SOUTH WEST WALL-EPA GRID POST CLEAN
BLISS	224292-C (9 @ (10 cm X 10 cm))	04/02/92	WIPE	2.8 as 1260	WALL "C" - WEST WALL PRE-CLEAN
BLISS	2291192-VLTWW (9 @ (10 cm X 10 cm))	09/11/92	WIPE	16 as 1260	WEST WALL - EPA GRID POST CLEAN
BLISS	224292-D (9 @ (10 cm X 10 cm))	04/02/92	WIPE	33 as 1260	WALL "D" - NORTH WALL PRE-CLEAN
BLISS	2291192-VLTNW (9 @ (10 cm X 10 cm))	09/11/92	WIPE	260 as 1260	NORTH WALL-EPA GRID POST CLEAN



Client: Clean Harbors of Kingston, Inc.  
Sample I.D.: 2222492-1 BLISS  
Sample Type: Wipe

CHAS Lab #: 9202303-01N  
Date Received: 02/25/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/25/92  
Analysis Date: 02/26/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	10	ND	ug/100 sq cm
PCB - Aroclor 1221	10	ND	ug/100 sq cm
PCB - Aroclor 1232	10	ND	ug/100 sq cm
PCB - Aroclor 1242	10	ND	ug/100 sq cm
PCB - Aroclor 1248	10	ND	ug/100 sq cm
PCB - Aroclor 1254	10	ND	ug/100 sq cm
PCB - Aroclor 1260	10	63	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.  
Sample I.D.: 2222492-2 BLISS  
Sample Type: Wipe

CHAS Lab #: 9202303-02N  
Date Received: 02/25/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/25/92  
Analysis Date: 02/26/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	29	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.  
Sample I.D.: 2222492-3 BLISS  
Sample Type: Wipe

CHAS Lab #: 9202303-03N  
Date Received: 02/25/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/25/92  
Analysis Date: 02/26/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	15	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.  
Sample I.D.: 2222492-4 BLISS  
Sample Type: Wipe

CHAS Lab #: 9202303-04N  
Date Received: 02/25/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/25/92  
Analysis Date: 02/26/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	27	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.  
Sample I.D.: 2222492-5 BLISS  
Sample Type: Wipe

CHAS Lab #: 9202303-05N  
Date Received: 02/25/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/25/92  
Analysis Date: 02/26/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	100	ND	ug/100 sq cm
PCB - Aroclor 1221	100	ND	ug/100 sq cm
PCB - Aroclor 1232	100	ND	ug/100 sq cm
PCB - Aroclor 1242	100	ND	ug/100 sq cm
PCB - Aroclor 1248	100	ND	ug/100 sq cm
PCB - Aroclor 1254	100	ND	ug/100 sq cm
PCB - Aroclor 1260	100	1,100	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.  
Sample I.D.: 2222492-6 BLISS  
Sample Type: Wipe

CHAS Lab #: 9202303-06N  
Date Received: 02/25/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/25/92  
Analysis Date: 02/26/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	24	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.  
Sample I.D.: 224292-CEL BLISS  
Sample Type: Wipe

CHAS Lab #: 9204075-01N  
Date Received: 04/06/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/06/92  
Analysis Date: 04/10/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	1.9	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.





Client: Clean Harbors of Kingston, Inc.  
Sample I.D.: 2291192-VLT CLNG, BLISS  
Sample Type: Wipe

CHAS Lab #: 9209152-01N  
Date Received: 09/12/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 09/14/92  
Analysis Date: 09/14/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.4	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.  
Sample I.D.: 224292-FL BLISS  
Sample Type: Wipe

CHAS Lab #: 9204075-02N  
Date Received: 04/06/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/06/92  
Analysis Date: 04/13/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	100	ND	ug/100 sq cm
PCB - Aroclor 1221	100	ND	ug/100 sq cm
PCB - Aroclor 1232	100	ND	ug/100 sq cm
PCB - Aroclor 1242	100	ND	ug/100 sq cm
PCB - Aroclor 1248	100	ND	ug/100 sq cm
PCB - Aroclor 1254	100	ND	ug/100 sq cm
PCB - Aroclor 1260	100	3,100	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.  
Sample I.D.: 224292-A BLISS  
Sample Type: Wipe

CHAS Lab #: 9204075-03N  
Date Received: 04/06/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/06/92  
Analysis Date: 04/13/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	19	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.  
Sample I.D.: 2291192-VLT EW, BLISS  
Sample Type: Wipe

CHAS Lab #: 9209152-04N  
Date Received: 09/12/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 09/14/92  
Analysis Date: 09/15/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	15	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.  
Sample I.D.: 224292-B BLISS  
Sample Type: Wipe

CHAS Lab #: 9204075-04N  
Date Received: 04/06/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/06/92  
Analysis Date: 04/11/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	11	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.  
Sample I.D.: 2291192-VLT SW, BLISS  
Sample Type: Wipe

CHAS Lab #: 9209152-02N  
Date Received: 09/12/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 09/14/92  
Analysis Date: 09/14/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	40	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.  
Sample I.D.: 224292-C BLISS  
Sample Type: Wipe

CHAS Lab #: 9204075-05N  
Date Received: 04/06/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/06/92  
Analysis Date: 04/10/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	2.8	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.  
Sample I.D.: 2291192-VLT WW, BLISS  
Sample Type: Wipe

CHAS Lab #: 9209152-05N  
Date Received: 09/12/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 09/14/92  
Analysis Date: 09/15/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	16	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.





Client: Clean Harbors of Kingston, Inc.  
Sample I.D.: 224292-D BLISS  
Sample Type: Wipe

CHAS Lab #: 9204075-06N  
Date Received: 04/06/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/06/92  
Analysis Date: 04/11/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	33	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.  
Sample I.D.: 2291192-VLT NW, BLISS  
Sample Type: Wipe

CHAS Lab #: 9209152-03N  
Date Received: 09/12/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 09/14/92  
Analysis Date: 09/15/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	10	ND	ug/100 sq cm
PCB - Aroclor 1221	10	ND	ug/100 sq cm
PCB - Aroclor 1232	10	ND	ug/100 sq cm
PCB - Aroclor 1242	10	ND	ug/100 sq cm
PCB - Aroclor 1248	10	ND	ug/100 sq cm
PCB - Aroclor 1254	10	ND	ug/100 sq cm
PCB - Aroclor 1260	10	260	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.