

WATER SAMPLES

<u>LOCATION</u>	<u>ID #</u>	<u>DATE</u>	<u>TYPE</u>	<u>RESULTS</u>	<u>COMMENTS</u>
BLISS	BLISS-2	01/03/92	WATER	29 as 1260	WATER ON POLY OUTSIDE ENTRANCE
BLISS	R02-1	01/05/92	WATER	9000 as 1260	WATER ON POLY 10' FROM ENTRANCE
BLISS	2212792-1	01/27/92	WATER	6.3	SPICKET AT BLISS
BLISS	2221492-COND	BLISS TRANS COND			
		02/18/92		200 as 1260	
BLISS	BLISS-1	01/03/92	OIL	1,000,000	VAULT TRANSFORMER
BLISS	32492-22P	03/26/92	WATER	3,500 as 1260	PENETONE/RINSE WATER
PARKER/31892-PR		03/18/92	WATER	290000 as 1260	PENETONE RINSE COMPOSITE-
BLISS/ SCUDDER					PARKER/BLISS/SCUDDER

Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2212792-1 BH
Sample Type: Water

CHAS Lab #: 9201312-03N
Date Received: 01/28/92

Polychlorinated Biphenyls (PCBs)
by EPA Method 608

Extraction Date: 01/28/92
Analysis Date: 01/28/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/l
PCB - Aroclor 1221	1.0	ND	ug/l
PCB - Aroclor 1232	1.0	ND	ug/l
PCB - Aroclor 1242	1.0	ND	ug/l
PCB - Aroclor 1248	1.0	ND	ug/l
PCB - Aroclor 1254	1.0	ND	ug/l
PCB - Aroclor 1260	1.0	6.3	ug/l

Notes: ND - Below minimum detectable level (MDL)
Soil/solid sample results based on sample dry weight

QA/QC

Surrogate Recovery	Acceptance Criteria
Hexabromobenzene: 97.7%	34-104%

Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2221492-COND BLISS TRANS. COND
Sample Type: Water

CHAS Lab #: 9202215-01N
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)
by EPA Method 608

Extraction Date: 02/19/92
Analysis Date: 02/20/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	10	ND	ug/l
PCB - Aroclor 1221	10	ND	ug/l
PCB - Aroclor 1232	10	ND	ug/l
PCB - Aroclor 1242	10	ND	ug/l
PCB - Aroclor 1248	10	ND	ug/l
PCB - Aroclor 1254	10	ND	ug/l
PCB - Aroclor 1260	10	200	ug/l

Notes: ND - Below minimum detectable level (MDL)
Soil/solid sample results based on sample dry weight

QA/QC

Surrogate Recovery	Acceptance Criteria
Hexabromobenzene: Diluted out	34-104%



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: BLISS-1, BLISS VAULT TRANSF.
Sample Type: Oil

CHAS Lab #: 9201025-
Date Received: 01/03

Polychlorinated Biphenyls (PCBs)
by EPA Method 600/4-81-045

Extraction Date: 01/03/92
Analysis Date: 01/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	50000	ND	mg/kg
PCB - Aroclor 1221	50000	ND	mg/kg
PCB - Aroclor 1232	50000	ND	mg/kg
PCB - Aroclor 1242	50000	ND	mg/kg
PCB - Aroclor 1248	50000	ND	mg/kg
PCB - Aroclor 1254	50000	ND	mg/kg
PCB - Aroclor 1260	50000	1000000	mg/kg

Notes: ND - Below minimum detectable level (MDL)
Soil/solid sample results based on sample dry weight

Client: Clean Harbors of Kingston, Inc.
Sample I.D.: BLISS-2, POLY OUT SIDE ENTRAN.
Sample Type: Water

CHAS Lab #: 9201025-0
Date Received: 01/03/92

Polychlorinated Biphenyls (PCBs)
by EPA Method 608

Extraction Date: 01/03/92
Analysis Date: 01/04/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	3.0	ND	ug/l
PCB - Aroclor 1221	3.0	ND	ug/l
PCB - Aroclor 1232	3.0	ND	ug/l
PCB - Aroclor 1242	3.0	ND	ug/l
PCB - Aroclor 1248	3.0	ND	ug/l
PCB - Aroclor 1254	3.0	ND	ug/l
PCB - Aroclor 1260	3.0	29	ug/l

Notes: ND - Below minimum detectable level (MDL)
Soil/solid sample results based on sample dry weight

QA/QC

Surrogate Recovery	Acceptance Criteria
Hexabromobenzene: 88.2%	34-104%

Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 32492-22P BLISS
Sample Type: Water

CHAS Lab #: 9203402-01
Date Received: 03/26/92

Polychlorinated Biphenyls (PCBs)
by EPA Method 608

Extraction Date: 03/26/92
Analysis Date: 03/27/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1000	ND	ug/l
PCB - Aroclor 1221	1000	ND	ug/l
PCB - Aroclor 1232	1000	ND	ug/l
PCB - Aroclor 1242	1000	ND	ug/l
PCB - Aroclor 1248	1000	ND	ug/l
PCB - Aroclor 1254	1000	ND	ug/l
PCB - Aroclor 1260	1000	3,500	ug/l

Notes: ND = Below minimum detectable level (MDL)
Soil/solid sample results based on sample dry weight

QA/QC

Surrogate Recovery	Acceptance Criteria
Hexabromobenzene: Diluted out	34-104%

Client: Clean Harbors of Kingston, Inc.
Sample I.D.: RO2-1
Sample Type: Water

CHAS Lab #: 9201038-06N
Date Received: 01/05/92

Polychlorinated Biphenyls (PCBs)
by EPA Method 608

Extraction Date: 01/05/92
Analysis Date: 01/05/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1000	ND	ug/l
PCB - Aroclor 1221	1000	ND	ug/l
PCB - Aroclor 1232	1000	ND	ug/l
PCB - Aroclor 1242	1000	ND	ug/l
PCB - Aroclor 1248	1000	ND	ug/l
PCB - Aroclor 1254	1000	ND	ug/l
PCB - Aroclor 1260	1000	9,800	ug/l

Notes: ND - Below minimum detectable level (MDL)
Soil/solid sample results based on sample dry weight

QA/QC

Surrogate Recovery	Acceptance Criteria
Hexabromobenzene: Diluted out	34-104%

Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 31892-PR PARKER, BLISS, SCUDDER
Sample Type: Water

CHAS Lab #: 9203256-01N
Date Received: 03/18/92

Polychlorinated Biphenyls (PCBs)
by EPA Method 608

Extraction Date: 03/18/92
Analysis Date: 03/19/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	10000	ND	ug/l
PCB - Aroclor 1221	10000	ND	ug/l
PCB - Aroclor 1232	10000	ND	ug/l
PCB - Aroclor 1242	10000	ND	ug/l
PCB - Aroclor 1248	10000	ND	ug/l
PCB - Aroclor 1254	10000	ND	ug/l
PCB - Aroclor 1260	10000	290,000	ug/l

Notes: ND - Below minimum detectable level (MDL)
Soil/solid sample results based on sample dry weight

QA/QC

Surrogate Recovery	Acceptance Criteria
Hexabromobenzene: Diluted out	34-104%