

GAGE HALL - WIPE SAMPLES

LOCATION	ID #	DATE	TYPE	RESULT	COMMENTS
GAGE	B-1	12/31/91	WIPE	N/D	SRN01
GAGE	B-2	12/31/91	WIPE	N/D	ROOM B10
GAGE	B-3	12/31/91	WIPE	1.3 as 1260	HALLWAY OUTSIDE TRANSFORMER
GAGE	B-4	12/31/91	WIPE	7.9 as 1260	TRANSFORMER ROOM
GAGE	B-5	12/31/91	WIPE	3.6 as 1260	SRN02
GAGE	1-1	12/31/91	WIPE	N/D	
GAGE	1-2	12/31/91	WIPE	N/D	
GAGE	2-1	12/31/91	WIPE	N/D	
GAGE	2-2	12/31/91	WIPE	N/D	
GAGE	3-1	12/31/91	WIPE	5.1 as 1260	3RD FLOOR FIRE EXTINGUISHER
GAGE	3-2	12/31/91	WIPE	N/D	
GAGE	SWS-18	01/01/92	WIPE	<1.0	DESK TOP IN ROOM B1
GAGE	SWS-19	01/01/92	WIPE	<1.0	FLOOR NEAR ROOM 128
GAGE	SWS-20	01/01/92	WIPE	<1.0	STRIP UNDER DOOR NEAR 346
GAGE	SWS-21	01/01/92	WIPE	8.8 as 1260	DOOR STRIP NEAR STORAGE ROOM
GAGE	21B1010592	01/05/92	WIPE	<1.0	STUDY ROOM #6-3RD FLOOR REC
GAGE	2132010592	01/05/92	WIPE	<1.0	STUDY ROOM #6-3RD FLOOR
GAGE	21B1010592	01/05/92	WIPE	<1.0	BASEMENT-REC ROOM #1
GAGE	21B2010592	01/05/92	WIPE	1.1 as 1260	BASEMENT-REC ROOM #1
GAGE	21B3010592	01/05/92	WIPE	<1.0	SRN01/LEDGE-1ST FLOOR
GAGE	21121792	01/07/92	WIPE	N/D	ROOM B19 - DESK ON LEFT
GAGE	21101792	01/07/92	WIPE	N/D	ROOM B4 - DESK ON RIGHT
GAGE	2111A792	01/07/92	WIPE	0.1 as 1260	REC ROOM #1 -BASEMENT LIGHT-BROWN TABLE
GAGE	218A1792	01/07/92	WIPE	N/D	ROOM 114 RIGHT DESK NEXT TO WINDOW
GAGE	2111792	01/07/92	WIPE	0.1 as 1260	ROOM 348 DESK ON RIGHT
GAGE	215A1792	01/07/92	WIPE	N/D	ROOM 225 DESK ON RIGHT
GAGE	2161792	01/07/92	WIPE	N/D	ROOM 248 DESK ON RIGHT
GAGE	2141792	01/07/92	WIPE	N/D	ROOM 203 DESK ON RIGHT
GAGE	2191792	01/07/92	WIPE	N/D	ROOM 101 TOP OF STEREO
GAGE	212A1792	01/07/92	WIPE	0.3 as 1260	ROOM 101 TOP OF STEREO
GAGE	2131792	01/07/92	WIPE	N/D	ROOM 323 RIGHT SIDE/RIGHT DESK
GAGE	2171792	01/07/92	WIPE	N/D	ROOM 305 LEFT DESK
GAGE	21311592	01/15/92	WIPE	59.0 as 1260	BASEMENT OUTSIDE VAULT
GAGE	21111592	01/15/92	WIPE	0.1 as 1260	1ST FLOOR ELEV. SHAFT
GAGE	21211592	01/15/92	WIPE	0.2 as 1260	PHONE BOOTH ACROSS ROOM 221
GAGE	21311592	01/15/92	WIPE	1.2 as 1260	PHONE BOOTH ACROSS ROOM 321
GAGE	21A11692	01/16/92	WIPE	17.0 as 1260	INSIDE ELECTRICAL PANEL COVER
GAGE	21111892B1	01/18/92	WIPE	N/D	ROOM B1
GAGE	21111892B2	01/18/92	WIPE	N/D	ROOM B2
GAGE	21111892B3	01/18/92	WIPE	N/D	ROOM B3
GAGE	21111892B4	01/18/92	WIPE	N/D	ROOM B4
GAGE	21111892B5	01/18/92	WIPE	N/D	ROOM B5
GAGE	21111892B6	01/18/92	WIPE	N/D	ROOM B6
GAGE	21111892B7	01/18/92	WIPE	N/D	ROOM B7
GAGE	21111892B8	01/18/92	WIPE	N/D	ROOM B8
GAGE	21111892B9	01/18/92	WIPE	N/D	ROOM B9
GAGE	21111892B11	01/18/92	WIPE	N/D	ROOM B11

GAGE HALL - WIPE SAMPLES

(CONTINUED)

LOCATION	ID #	DATE	TYPE RESULT	COMMENTS
GAGE	21111892B12	01/18/92	WIPE N/D	ROOM B12
GAGE	21111892B13	01/18/92	WIPE N/D	ROOM B13
GAGE	21111892B14	01/18/92	WIPE N/D	ROOM B14
GAGE	21111892B15	01/18/92	WIPE N/D	ROOM B15
GAGE	21111892B16	01/18/92	WIPE N/D	ROOM B16
GAGE	21111892B17	01/18/92	WIPE N/D	ROOM B17
GAGE	21111892B18	01/18/92	WIPE N/D	ROOM B18
GAGE	21111892B19	01/18/92	WIPE N/D	ROOM B19
GAGE	21111892B20	01/18/92	WIPE N/D	ROOM B20
GAGE	21111892B21	01/18/92	WIPE N/D	ROOM B21
GAGE	21111892-101	01/18/92	WIPE N/D	ROOM 101
GAGE	21111892-102	01/18/92	WIPE N/D	ROOM 102
GAGE	21111892-103	01/18/92	WIPE N/D	ROOM 103
GAGE	21111892-104	01/18/92	WIPE N/D	ROOM 104
GAGE	21111892-105	01/18/92	WIPE N/D	ROOM 105
GAGE	21111892-106	01/18/92	WIPE N/D	ROOM 106
GAGE	21111892-107	01/18/92	WIPE N/D	ROOM 107
GAGE	21111892-108	01/18/92	WIPE N/D	ROOM 108
GAGE	21111892-109	01/18/92	WIPE N/D	ROOM 109
GAGE	21111892-110	01/18/92	WIPE N/D	ROOM 110
GAGE	21111892-111	01/18/92	WIPE N/D	ROOM 111
GAGE	21111892-112	01/18/92	WIPE N/D	ROOM 112
GAGE	21111892-113	01/18/92	WIPE N/D	ROOM 113
GAGE	21111892-114	01/18/92	WIPE N/D	ROOM 114
GAGE	21111892-115	01/18/92	WIPE N/D	ROOM 115
GAGE	21111892-116	01/18/92	WIPE N/D	ROOM 116
GAGE	21111892-117	01/18/92	WIPE N/D	ROOM 117
GAGE	21111892-118	01/18/92	WIPE N/D	ROOM 118
GAGE	21111892-119	01/18/92	WIPE N/D	ROOM 119
GAGE	21111892-120	01/18/92	WIPE N/D	ROOM 120
GAGE	21111892-121	01/18/92	WIPE N/D	ROOM 121
GAGE	21111892-122	01/18/92	WIPE N/D	ROOM 122
GAGE	21111892-123	01/18/92	WIPE N/D	ROOM 123
GAGE	21111892-124	01/18/92	WIPE N/D	ROOM 124
GAGE	21111892-125	01/18/92	WIPE N/D	ROOM 125
GAGE	21111892-126	01/18/92	WIPE N/D	ROOM 126
GAGE	21111892-127	01/18/92	WIPE N/D	ROOM 127
GAGE	21111892-128	01/18/92	WIPE N/D	ROOM 128
GAGE	21111892-129	01/18/92	WIPE N/D	ROOM 129
GAGE	21111892-130	01/18/92	WIPE N/D	ROOM 130
GAGE	21111892-131	01/18/92	WIPE N/D	ROOM 131
GAGE	21111892-132	01/18/92	WIPE N/D	ROOM 132
GAGE	21111892-133	01/18/92	WIPE N/D	ROOM 133
GAGE	21211792-201	01/17/92	WIPE N/D	ROOM 201
GAGE	21211792-202	01/17/92	WIPE N/D	ROOM 202
GAGE	21211792-203	01/17/92	WIPE N/D	ROOM 203
GAGE	21211792-204	01/17/92	WIPE N/D	ROOM 204
GAGE	21211792-205	01/17/92	WIPE N/D	ROOM 205
GAGE	21211792-206	01/17/92	WIPE N/D	ROOM 206
GAGE	21211792-207	01/17/92	WIPE N/D	ROOM 207
GAGE	21211792-208	01/17/92	WIPE N/D	ROOM 208

GAGE HALL - WIPE SAMPLES

(CONTINUED)

LOCATION	ID #	DATE	TYPE RESULT	COMMENTS
GAGE	21211792-209	01/17/92	WIPE N/D	ROOM 209
GAGE	21211792-210	01/17/92	WIPE N/D	ROOM 210
GAGE	21211792-211	01/17/92	WIPE N/D	ROOM 211
GAGE	21211792-212	01/17/92	WIPE N/D	ROOM 212
GAGE	21211792-213	01/17/92	WIPE N/D	ROOM 213
GAGE	21211792-214	01/17/92	WIPE N/D	ROOM 214
GAGE	21211792-215	01/17/92	WIPE N/D	ROOM 215
GAGE	21211792-216	01/17/92	WIPE N/D	ROOM 216
GAGE	21211792-217	01/17/92	WIPE N/D	ROOM 217
GAGE	21211792-218	01/17/92	WIPE N/D	ROOM 218
GAGE	21211792-219	01/17/92	WIPE N/D	ROOM 219
GAGE	21211792-220	01/17/92	WIPE N/D	ROOM 220
GAGE	21211792-221	01/17/92	WIPE N/D	ROOM 221
GAGE	21211792-222	01/17/92	WIPE N/D	ROOM 222
GAGE	21211792-223	01/17/92	WIPE N/D	ROOM 223
GAGE	21211792-224	01/17/92	WIPE 0.3 as 1260	ROOM 224
GAGE	21211792-225	01/17/92	WIPE N/D	ROOM 225
GAGE	21211792-226	01/17/92	WIPE N/D	ROOM 226
GAGE	21211792-227	01/17/92	WIPE N/D	ROOM 227
GAGE	21211792-228	01/17/92	WIPE N/D	ROOM 228
GAGE	21211792-229	01/17/92	WIPE N/D	ROOM 229
GAGE	21211792-230	01/17/92	WIPE N/D	ROOM 230
GAGE	21211792-231	01/17/92	WIPE N/D	ROOM 231
GAGE	21211792-232	01/17/92	WIPE N/D	ROOM 232
GAGE	21211792-233	01/17/92	WIPE N/D	ROOM 233
GAGE	21211792-234	01/17/92	WIPE N/D	ROOM 234
GAGE	21211792-235	01/17/92	WIPE N/D	ROOM 235
GAGE	21211792-236	01/17/92	WIPE N/D	ROOM 236
GAGE	21211792-237	01/17/92	WIPE N/D	ROOM 237
GAGE	21211792-238	01/17/92	WIPE N/D	ROOM 238
GAGE	21211792-239	01/17/92	WIPE N/D	ROOM 239
GAGE	21211792-240	01/17/92	WIPE N/D	ROOM 240
GAGE	21211792-241	01/17/92	WIPE N/D	ROOM 241
GAGE	21211792-242	01/17/92	WIPE N/D	ROOM 242
GAGE	21211792-243	01/17/92	WIPE N/D	ROOM 243
GAGE	21211792-244	01/17/92	WIPE N/D	ROOM 244
GAGE	21211792-245	01/17/92	WIPE N/D	ROOM 245
GAGE	21211792-246	01/17/92	WIPE N/D	ROOM 246
GAGE	21211792-247	01/17/92	WIPE N/D	ROOM 247
GAGE	21211792-248	01/17/92	WIPE N/D	ROOM 248
GAGE	21211792-249	01/17/92	WIPE N/D	ROOM 249
GAGE	21311792-301	01/17/92	WIPE N/D	ROOM 301
GAGE	21311792-302	01/17/92	WIPE N/D	ROOM 302
GAGE	21311792-303	01/17/92	WIPE N/D	ROOM 303
GAGE	21311792-304	01/17/92	WIPE N/D	ROOM 304
GAGE	21311792-305	01/17/92	WIPE N/D	ROOM 305
GAGE	21311792-306	01/17/92	WIPE N/D	ROOM 306
GAGE	21311792-307	01/17/92	WIPE N/D	ROOM 307
GAGE	21311792-308	01/17/92	WIPE N/D	ROOM 308

GAGE HALL - WIPE SAMPLES

(CONTINUED)

LOCATION	ID #	DATE	TYPE RESULT	COMMENTS
GAGE	21311792-309	01/17/92	WIPE N/D	ROOM 309
GAGE	21311792-310	01/17/92	WIPE N/D	ROOM 310
GAGE	21311792-311	01/17/92	WIPE N/D	ROOM 311
GAGE	21311792-312	01/17/92	WIPE N/D	ROOM 312
GAGE	21311792-313	01/17/92	WIPE N/D	ROOM 313
GAGE	21311792-314	01/17/92	WIPE N/D	ROOM 314
GAGE	21311792-315	01/17/92	WIPE N/D	ROOM 315
GAGE	21311792-316	01/17/92	WIPE N/D	ROOM 316
GAGE	21311792-317	01/17/92	WIPE N/D	ROOM 317
GAGE	21311792-318	01/17/92	WIPE N/D	ROOM 318
GAGE	21311792-319	01/17/92	WIPE N/D	ROOM 319
GAGE	21311792-320	01/17/92	WIPE N/D	ROOM 320
GAGE	21311792-321	01/17/92	WIPE N/D	ROOM 321
GAGE	21311792-322	01/17/92	WIPE N/D	ROOM 322
GAGE	21311792-323	01/17/92	WIPE N/D	ROOM 323
GAGE	21311792-324	01/17/92	WIPE N/D	ROOM 324
GAGE	21311792-325	01/17/92	WIPE N/D	ROOM 325
GAGE	21311792-326	01/17/92	WIPE N/D	ROOM 326
GAGE	21311792-327	01/17/92	WIPE N/D	ROOM 327
GAGE	21311792-328	01/17/92	WIPE N/D	ROOM 328
GAGE	21311792-329	01/17/92	WIPE N/D	ROOM 329
GAGE	21311792-330	01/17/92	WIPE N/D	ROOM 330
GAGE	21311792-331	01/17/92	WIPE N/D	ROOM 331
GAGE	21311792-332	01/17/92	WIPE N/D	ROOM 332
GAGE	21311792-333	01/17/92	WIPE N/D	ROOM 333
GAGE	21311792-334	01/17/92	WIPE N/D	ROOM 334
GAGE	21311792-335	01/17/92	WIPE N/D	ROOM 335
GAGE	21311792-336	01/17/92	WIPE N/D	ROOM 336
GAGE	21311792-337	01/17/92	WIPE N/D	ROOM 337
GAGE	21311792-338	01/17/92	WIPE N/D	ROOM 338
GAGE	21311792-339	01/17/92	WIPE N/D	ROOM 339
GAGE	21311792-340	01/17/92	WIPE N/D	ROOM 340
GAGE	21311792-341	01/17/92	WIPE N/D	ROOM 341
GAGE	21311792-342	01/17/92	WIPE N/D	ROOM 342
GAGE	21311792-343	01/17/92	WIPE N/D	ROOM 343
GAGE	21311792-344	01/17/92	WIPE N/D	ROOM 344
GAGE	21311792-345	01/17/92	WIPE N/D	ROOM 345
GAGE	21311792-346	01/17/92	WIPE N/D	ROOM 346
GAGE	21311792-347	01/17/92	WIPE N/D	ROOM 347
GAGE	21311792-348	01/17/92	WIPE N/D	ROOM 348
GAGE	21311792-349	01/17/92	WIPE N/D	ROOM 349
GAGE	2111892B1B	01/18/92	WIPE N/D	BATHROOM SRN10-SINK
GAGE	2111892B1A	01/18/92	WIPE N/D	BATHROOM SRN02 TUB
GAGE	2111892B2A.	01/18/92	WIPE 0.1 as 1260	BATHROOM-SRN011
GAGE	2111892B2B	01/18/92	WIPE N/D	BATHROOM-SRN011 WINDOW SILL
GAGE	2111892TV1	01/18/92	WIPE N/D	REC ROOM #4-ROUND TABLE
GAGE	2111892B3A	01/18/92	WIPE N/D	BATHROOM SRN012 SILL
			ABOVE SINK	
GAGE	2111892B3B	01/18/92	WIPE N/D	BATHROOM SRN012 SILL
				ABOVE SINK

GAGE HALL - WIPE SAMPLES

(CONTINUED)

LOCATION	ID #	DATE	TYPE RESULT	COMMENTS
GAGE	2111892BLR	01/18/92	WIPE N/D	SRN06 2ND FLOOR
GAGE	2111892B10	01/18/92	WIPE N/D	ROO BIO
GAGE	2111892LRB	01/18/92	WIPE N/D	LAUNDRY ROOM #1
GAGE	21C11892P3	01/18/92	WIPE N/D	PHONE BY F21
GAGE	2111892LC	01/18/92	WIPE N/D	LINEN CLOSET
GAGE	21B11892V	01/18/92	WIPE 1000 as 1260	VAULT POST CLEAN
GAGE	21211892BBA	01/18/92	WIPE N/D	BATHROOM SRN05/SILL OVER SINK
GAGE	21311892SA	01/18/92	WIPE N/D	SHELF BY 338
GAGE	21111892P1	01/18/92	WIPE N/D	PHONE BY F31 (X9936)
GAGE	21311892SB	01/18/92	WIPE .03 as 1260	SHELF BY 331
GAGE	21311892SC	01/18/92	WIPE N/D	SHELF BY 307
GAGE	21C11892P2	01/18/92	WIPE 0.1 as 1260	PHONE BOOTH BY CENTER LOUNGE
GAGE	21111892SRA	01/18/92	WIPE N/D	SHELF BY ROOM 124
GAGE	21111892SD	01/18/92	WIPE N/D	SHELF BY ROOM 125
GAGE	21211892BBB	01/18/92	WIPE N/D	BATHROOM SRN08 SILL ABOVE SINK
GAGE	21211892BAC	01/18/92	WIPE N/D	BATHROOM SRN07 SILL ABOVE SINK
GAGE	2111892R1	01/18/92	WIPE N/D	REC & STUDY ROOM #3
GAGE	2111892LR	01/18/92	WIPE 0.2 as 1260	LUGGAGE ROOM #1
GAGE	21211892TV2	01/18/92	WIPE N/D	LOUNGE #3
GAGE	21111892BBD	01/18/92	WIPE N/D	BATHROOM BY 111
GAGE	21111892SRB	01/18/92	WIPE N/D	STUDY ROOM BY 109
GAGE	21111892BBE	01/18/92	WIPE N/D	SRN03 SILL ABOVE SINK
GAGE	21111892LC	01/18/92	WIPE N/D	LINEN CLOSET (LIMSR)
GAGE	2112492-1	01/24/92	WIPE N/D	SRN09
GAGE	2112492-2	01/24/92	WIPE 0.5 as 1260	1ST FLOOR STORAGE ROOM MICRO TABLE
GAGE	2112492-3	01/24/92	WIPE 0.2 AS 1254	BASEMENT WOMEN'S EMPLOYEE ROOM ON CHAIR
GAGE	2112492-4	01/24/92	WIPE N/D	SRN05 (2ND FLOOR) FLOOR 2ND LOUNGE FROM FLOOR
GAGE	2112492-5	01/24/92	WIPE N/D	DIR OFFICE 1ST FLOOR-TABLE
GAGE	2112492-6	01/24/92	WIPE 0.3 as 1260	BASEMENT STORAGE-FOLD CHAIR
GAGE	2112492-7	01/24/92	WIPE 0.1 as 1260	LAUNDRY 2 BASEMENT FLOOR (TABLE)
GAGE	2112492-8	01/24/92	WIPE 0.2 as 1260	BASEMENT LUGGAGE RM/TRASH CAN
GAGE	2112492-9	01/24/92	WIPE N/D	BASEMENT - MEN'S EMPLOYEE DRESSER
GAGE	2112492-10	01/24/92	WIPE N/D	REC 5/2ND FLOOR TABLE
GAGE	2112492-12	01/24/92	WIPE N/D	BATHROOM ACROSS SRN04
GAGE	2112492-13	01/24/92	WIPE 0.1 as 1260	MAIN LOUNGE #2 TABLE (REC 2)
GAGE	2112492-14	01/24/92	WIPE N/D	SRN09 BENCH (3RD FLOOR)
GAGE	2112492-15	01/24/92	WIPE 0.2 as 1260	BASEMENT LUGGAGE ROOM #2
GAGE	2112492-11	01/24/92	WIPE 1.4 as 1260	JC2 SINK/ BASEMENT
GAGE	21112792-1	01/27/92	WIPE N/D	WALL ACROSS FROM REC ROOM
GAGE	21112792-2	01/27/92	WIPE .01 AS 1260	STAIRWAY WALL NEAR VAULT CLOSE TO FLOOR

GAGE HALL - WIPE SAMPLES

(CONTINUED)

LOCATION	ID #	DATE	TYPE RESULT	COMMENTS
GAGE	21112792-3	01/27/92	WIPE 1.5 AS 1260	NEAR VAULT, ALONG WALL
GAGE	21112792-4	01/27/92	WIPE 1.5 AS 1260	ELEVATOR WALL
GAGE	21W12792-1	01/27/92	WIPE 55 AS 1260	UNPAINTED BRICKS-VAULT
GAGE	21W12792-2	01/27/92	WIPE 27 AS 1260	PAINTED BRICK - VAULT
GAGE	21B12892-WS	01/28/92	WIPE N/D	ROOM BS6
GAGE	21B12892-WE	01/28/92	WIPE N/D	WOMEN'S EMPLOYEE
GAGE	21B12892-ES	01/28/92	WIPE 1.5 AS 1260	EASTERN STORAGE
GAGE	21112892-LR	01/28/92	WIPE N/D	LADIES' ROOM-2ND FLOOR
GAGE	21112892-MR	01/28/92	WIPE 0.4 AS 1260	MEN'S ROOM-2ND FLOOR
GAGE	211292-JC1	01/29/92	WIPE N/D	JANITOR CLOSET #1
GAGE	21B12892-JC2	01/28/92	WIPE N/D	JANITOR CLOSET #2
				CHAS #9201333-01N
GAGE	21B12892-JC3	01/28/92	WIPE 0.8 as 1260	JANITOR CLOSET #3
				CHAS #9201326-01N
GAGE	21B12892-JC4	01/18/92	WIPE 1.1 AS 1260	JANITOR CLOSET 4-INSIDE DOOR
				CHAS #9201326-02N
GAGE	21B12892-JC5	01/28/92	WIPE 0.3 AS 1260	JANITOR CLOSET 5
				CHAS #9201326-03N
GAGE	21B12892-JC6	01/28/92	WIPE 0.4 AS 1260	JANITOR CLOSET 6-WALL TO
				RIGHT - CHAS #920133-01N
GAGE	21B12892-JC7	01/28/92	WIPE 1.7 AS 1260	JANITOR CLOSET 7
				CHAS #9201326-05N
GAGE	21B12892-JC8	01/28/92	WIPE N/D	JANITOR CLOSET 8-SINK
GAGE	21B12892-JC9	01/28/92	WIPE N/D	JANITOR CLOSET 9-TOP OF
				GARBAGE CAN
GAGE	21B12892-JC10	01/28/92	WIPE 0.1 AS 1260	JANITOR CLOSET 10
				CHAS # 9201326-06N
GAGE	21B12892-JC11	01/28/92	WIPE N/D	JANITOR CLOSET 11-LEFT WALL
				CHAS #9201333-03N
GAGE	2122192-JC13	02/01/92	WIPE N/D	JANITOR CLOSET 13
GAGE	21212892-JC14	01/28/92	WIPE N/D	JANITOR CLOSET 14
				CHAS #9201334-02N
GAGE	2122192-JC15	02/01/92		
GAGE	21212892-JC15	01/28/92	WIPE N/D	JANITOR CLOSET-15
				CHAS #9201334-03N
GAGE	2122192-JC16	02/01/92	WIPE N/D	JANITOR CLOSET 16
GAGE	2122192-JC17	02/01/92	WIPE N/D	JANITOR CLOSET 17
GAGE	21212892-JC18	01/28/92	WIPE N/D	JANITOR CLOSET #18
				CHAS #9201334-06N
GAGE	2122192-JC18	02/01/92	WIPE 0.1 as 1260	JANITOR CLOSET 18
GAGE	21212892-JC19	01/28/91	WIPE N/D	JANITOR CLOSET #19
				CHAS 9201334-07N
GAGE	2122192-JC19L	02/01/92	WIPE N/D	2ND FLOOR-JC TO LEFT OF
				BATHROOM (NEAR JC 19)
GAGE	2122192-JC19R	02/01/92	WIPE 0.1 as 1260	2ND FLOOR-JC TO RIGHT OF
				BATHROOM (JC19 ON MAP)
GAGE	2132192-JC20	02/01/92	WIPE N/D	JANITOR CLOSET 20-THIRD
				FLOOR
GAGE	21212892-JC21	01/28/91	WIPE W/D	JANITOR CLOSET #21
				CHAS #9203340-08N
GAGE	2132192-JC21	02/01/92	WIPE N/D	JANITOR CLOSET 21-3RD FLOOR
GAGE	21312892-JC22	01/28/92	WIPE N/D	JANITOR CLOSET 22-SHELF
				NEXT TO 314
GAGE	21312892-AA	01/28/92	WIPE N/D	JANITOR CLOSET 23

GAGE HALL - WIPE SAMPLES

LOCATION	ID #	DATE	TYPE	RESULT	COMMENTS
GAGE	21B1010592	01/05/92	WIPE	ND	BASEMENT-REC ROOM #1
GAGE	21B2010592	01/05/92	WIPE	1.1 as 1260	BASEMENT-REC ROOM #1
GAGE	2171792-NORTH (1 @ 900 sq cm)	07/17/92	WIPE	ND	NORTH WALL OF REC. ROOM POST CLEAN CHAS #9207226
GAGE	2171792-SOUTH (1 @ 900 sq cm)	07/17/92	WIPE	ND	SOUTH WALL OF REC. ROOM POST CLEAN CHAS #9207226
GAGE	2171792-EAST (1 @ 900 sq cm)	07/17/92	WIPE	ND	EAST WALL OF REC. ROOM POST CLEAN CHAS #9207226
GAGE	2171792-WEST (1 @ 900 sq cm)	07/17/92	WIPE	ND	WEST WALL OF REC. ROOM POST CLEAN CHAS #9207226
GAGE	2172292-RRNORTH (1 @ 900 sq cm)	07/22/92	WIPE	ND	NORTH END OF BASEMENT REC. ROOM FLOOR POST CLEAN
GAGE	2172292-RREAST (1 @ 900 sq cm)	07/22/92	WIPE	ND	EAST END OF BASEMENT REC. ROOM FLOOR POST CLEAN
GAGE	2172292-RRSOUTH (1 @ 900 sq cm)	07/22/92	WIPE	0.3 as 1260	SOUTH END OF BASEMENT REC. ROOM FLOOR POST CLEAN
GAGE	2172292-RRWEST (1 @ 900 sq cm)	07/22/92	WIPE	ND	WEST END OF BASEMENT REC. ROOM FLOOR POST CLEAN



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 21B1010592, GAGE
Sample Type: Wipe

CHAS Lab #: 9201048-03
Date Received: 01/06/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 01/06/92
Analysis Date: 01/06/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 21B2010592, GAGE
Sample Type: Wipe

CHAS Lab #: 9201048-04F
Date Received: 01/06/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 01/06/92
Analysis Date: 01/06/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	1.1	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2171792-NORTH GAGE
Sample Type: Wipe

CHAS Lab #: 9207226-01N
Date Received: 07/18/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 07/18/92
Analysis Date: 07/21/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2171792-SOUTH GAGE
Sample Type: Wipe

CHAS Lab #: 9207226-02N
Date Received: 07/18/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 07/18/92
Analysis Date: 07/21/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2171792-EAST GAGE
Sample Type: Wipe

CHAS Lab #: 9207226-03N
Date Received: 07/18/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 07/18/92
Analysis Date: 07/21/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2171792-WEST GAGE
Sample Type: Wipe

CHAS Lab #: 9207226-04N
Date Received: 07/18/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 07/18/92
Analysis Date: 07/21/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2172292-RRNORTH GAGE
Sample Type: Wipe

CHAS Lab #: 9207283-01N
Date Received: 07/23/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 07/23/92
Analysis Date: 07/24/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2172292-RREAST GAGE
Sample Type: Wipe

CHAS Lab #: 9207283-02N
Date Received: 07/23/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 07/23/92
Analysis Date: 07/24/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2172292-RRSOUTH GAGE
Sample Type: Wipe

CHAS Lab #: 9207283-03N
Date Received: 07/23/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 07/23/92

Analysis Date: 07/24/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.3	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2172292-RRWEST GAGE
Sample Type: Wipe

CHAS Lab #: 9207283-04N
Date Received: 07/23/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 07/23/92
Analysis Date: 07/24/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.