



ENVIRONMENTAL SERVICES, INC.

32 BASK ROAD • GLENMONT, NY 12077

(518) 434-0149 • FAX (518) 434-9118

M E M O R A N D U M

To: List

From: Allison Smith (CHESI) *ams*

Date: September 21, 1994

RE: Gage Hall Exhaust System Analysis Report

Enclosed is a copy of the Gage Hall Exhaust System Analysis Report. This report includes analysis of all wipe and air samples taken in the initial phase of the system remediation. Please feel free to call me at (914) 257-3366 if you have any questions.

cc: Lindo Signorelli (SUNY)  
Alice Chandler (SUNY)  
John Hawley (NYSDOH)

GAGE HALL - WIPE SAMPLES - EXHAUST DUCT

LOCATION	ID #	DATE	RESULT	COMMENTS
<b>SYSTEM E1</b>				
GAGE	218394-E1-LAUN EAST (4 @ (15 cm X 15 cm))	8/3/94	1.6 as 1260	LAUNDRY ROOM EAST PRE-CLEAN
GAGE	21081194-E1-LAUNEAST-PC (4 @ (15 cm X 15 cm))	8/11/94	3.6 as 1260	LAUNDRY ROOM EAST POST CLEAN
<b>SYSTEM E2</b>				
GAGE	218394-E2-JC2 (1 @ (30 cm X 30 cm))	8/3/94	1.4 as 1260	JANITOR'S CLOSET #2 PRE-CLEAN
GAGE	21081194-E2-JC2-PC (1 @ (30 cm X 30 cm))	8/11/94	0.2 as 1260	JANITORS CLOSET #2 POST CLEAN
GAGE	218394-E2-SRN01 (6 @ (12.25 cm X 12.25 cm))	8/3/94	1.1 as 1260	SRN01-BATHROOM EAST BASEMENT PRE-CLEAN
GAGE	21081194-E2-SRN01-PC (6 @ (12.25 cm X 12.25))	8/11/94	0.4 as 1260	SRN01-BASEMENT BATHROOM POST CLEAN
GAGE	218394-E2-SRN03 (4 @ (15 cm X 15 cm))	8/3/94	4.9 as 1260	SRN03-1ST FLOOR BATHROOM PRE-CLEAN
GAGE	21081194-E2-SRN03-PC (4 @ (15 cm X 15 cm))	8/11/94	2.1 as 1260	SRN03-FIRST FLOOR POST CLEAN
GAGE	218394-E2-SRN03JC (1 @ (30 cm X 30 cm))	8/3/94	1.6 as 1260	JANITOR'S CLOSET NEXT TO SRN03-1ST FLOOR PRE-CLEAN
GAGE	21081194-E2-SRN03JC-PC (1 @ (30 cm X 30 cm))	8/11/94	0.3 as 1260	JANITORS CLOSET NEXT TO SRN03-1ST FLOOR POST CLEAN
GAGE	218394-E2-SRN05 (4 @ (15 cm X 15 cm))	8/3/94	2.2 as 1260	SRN05-2ND FLOOR BATHROOM PRE-CLEAN
GAGE	21081294-E2-SRN05-PC (4 @ (15 cm X 15 cm))	8/3/94	0.1 as 1260	SRN05-2ND FLOOR BATHROOM POST CLEAN
GAGE	218394-E2-JC17 (1 @ (30 cm X 30 cm))	8/3/94	ND	JANITOR'S CLOSET #17-2ND FLOOR PRE-CLEAN
GAGE	21081294-JC17-PC (1 @ (30 cm X 30 cm))	8/12/94	0.1 as 1260	JANITORS CLOSET #17 POST CLEAN
GAGE	21080994-SRN09JC (1 @ (30 cm X 30 cm))	8/9/94	1.6 as 1260	JANITORS CLOSET #17 - NO INLET; CUT MADE INTO DUCT PRE-CLEAN
GAGE	21081294-SRN09JC-PC (1 @ (30 cm X 30 cm))	8/12/94	0.4 as 1260	JANITORS CLOSET #17 - NO INLET; CUT MADE INTO DUCT POST CLEAN
GAGE	218394-E2-SRN09 (4 @ (15 cm X 15 cm))	8/3/94	10 as 1260	SRN09-3RD FLOOR BATHROOM PRE-CLEAN
GAGE	21081094-SRN09-AP (1 @ (30 cm X 30 cm))	8/10/94	1.0 as 1260	SRN09 ACCESS PANEL LOCATED ABOVE THE STALL IN SRN09 PRE-CLEAN
GAGE	21081194-E2-SRN09-PC (1 @ (30 cm X 30 cm))	8/11/94	0.4 as 1260	SRN09-3RD FLOOR POST CLEAN
GAGE	21081294-SRN09-PC (4 @ (15 cm X 15 cm))	8/12/94	0.1 as 1260	SRN09-3RD FLOOR BATHROOM POST CLEAN

## SYSTEM E3

GAGE 218394-E3-EMPWOM (4 @ (15 cm X 15 cm))	8/3/94	11 as 1260	BASEMENT EMPLOYEE WOMEN'S ROOM PRE-CLEAN
GAGE 21081194-E3-EMPWOM-PC (4 @ (15 cm X 15 cm))	8/11/94	1.7 as 1260	BASEMENT EMPLOYEE WOMEN'S ROOM POST CLEAN
GAGE 21080594-INC-E3 (1 @ (30 cm X 30 cm))	8/5/94	10 as 1260	INCINERATOR ROOM (NO INLET HERE; CUT MADE INTO DUCT) PRE-CLEAN
GAGE 21081194-E3-INCROOM-PC (1 @ (30 cm X 30 cm))	8/11/94	1.0 as 1260	INCINERATOR ROOM POST CLEAN
GAGE 21080894-RD-GBV (1 @ (30 cm X 30 cm))	8/8/94	0.2 as 1260	RESIDENT DIRECTOR'S GURST BEDROOM PRE-CLEAN
GAGE 21081194-RD-GBV-PC (1 @ (30 cm X 30 cm))	8/11/94	ND	RESIDENT DIRECTOR'S GUEST BEDROOM POST CLEAN
GAGE 21080894-RD-MBV (1 @ (30 cm X 30 cm))	8/8/94	0.3 as 1260	RESIDENT DIRECTOR'S BEDROOM PRE-CLEAN
GAGE 21081194-RD-BV-PC (1 @ (30 cm X 30 cm))	8/11/94	ND	RESIDENT DIRECTOR'S BEDROOM POST CLEAN
GAGE 21081094-RD-GBV-EXT (1 @ (30 cm X 30 cm))	8/10/94	ND	RESIDENT DIRECTOR'S GUEST BEDROOM - SAMPLE TAKEN WITH EXTENSION POLE 8' INTO VENT (TOWARDS INCINERATOR ROOM)
GAGE 21081294-RD-KV-PC (1 @ (30 cm X 30 cm))	8/12/94	0.2 as 1260	RESIDENT DIRECTOR'S KITCHEN POST CLEAN
GAGE 218394-E3-SRNO6 (7 @ (11.4 cm X 11.4 cm))	8/3/94	3.4 as 1260	SRNO6-2ND FLOOR BATHROOM PRE-CLEAN
GAGE 21081294-E3-SRNO6-PC (4 @ (15 cm X 15 cm))	8/12/94	ND	SRNO6-2ND FLOOR BATHROOM POST CLEAN
GAGE 218394-E3-JC21 (1 @ (30 cm X 30 cm))	8/3/94	2.6 as 1260	JANITOR'S CLOSET #21-3RD FLOOR PRE-CLEAN
GAGE 21081294-E3-JC21-PC (1 @ (30 cm X 30 cm))	8/12/94	ND	JANITORS CLOSET #21 POST CLEAN
GAGE 218394-E3-SRNO10 (4 @ (15 cm X 15 cm))	8/3/94	2.1 as 1260	SRNO10-3RD FLOOR BATHROOM PRE-CLEAN
GAGE 21081294-SRNO10-PC (4 @ (15 cm X 15 cm))	8/12/94	0.4 as 1260	SRNO10-3RD FLOOR BATHROOM POST CLEAN

## SYSTEM E4

GAGE 218394-E4-2RECRM (1 @ (30 cm X 30 cm))	8/3/94	5.7 as 1260	2ND FLOOR REC ROOM PRE-CLEAN
GAGE 21081294-E4-2RECRM-PC (1 @ (30 cm X 30 cm))	8/12/94	0.2 as 1254	2ND FLOOR REC ROOM POST CLEAN
GAGE 218394-E4-3RECRM (1 @ (30 cm X 30 cm))	8/3/94	4.1 as 1260	3RD FLOOR REC ROOM PRE-CLEAN
GAGE 21081294-E4-3RECRM (1 @ (30 cm X 30 cm))	8/12/94	ND	3RD FLOOR REC ROOM POST CLEAN

## SYSTEM E5

GAGE 218394-E5-BRECRM (1 @ (30 cm X 30 cm))	8/3/94	2.4 as 1254	BASEMENT REC ROOM PRE-CLEAN
GAGE 21081194-E5-BRECRM-PC (1 @ (30 cm X 30 cm))	8/11/94	1.5 as 1254	BASEMENT REC ROOM POST CLEAN
GAGE 218394-E5-1RECRM (1 @ (30 cm X 30 cm))	8/3/94	2.4 as 1254	1ST FLOOR REC RM PRE-CLEAN

GAGE	21081194-E5-1RECRM-PC	8/11/94	0.9 as 1254	1ST FLOOR REC RM
	(3 @ (30 cm X 30 cm))			POST CLEAN
<b>SYSTEM E6</b>				
GAGE	218394-E6-EMPMENS	8/3/94	6.3 as 1260	BASEMENT EMPLOYEE MENS ROOM
	(3 @ (17 cm X 17 cm))			PRE-CLEAN
GAGE	21081194-E6-EMPMENS-PC	8/11/94	0.3 as 1260	BASEMENT EMPLOYEE MENS ROOM
	(3 @ (17 cm X 17 cm))			POST CLEAN
GAGE	218394-E6-WF1	8/3/94	2.1 as 1260	1ST FLOOR WOMENS ROOM-VISITORS
	(1 @ (30 cm X 30 cm))			PRE-CLEAN
GAGE	21081194-E6-WF1-PC	8/11/94	0.3 as 1260	1ST FLOOR WOMENS ROOM-VISITORS
	(1 @ (30 cm X 30 cm))			POST CLEAN
GAGE	218394-E6-WF1	8/3/94	2.1 as 1254	1ST FLOOR MENS ROOM-VISITORS
	(1 @ (30 cm X 30 cm))			PRE-CLEAN
GAGE	21081194-E6-WF1-PC	8/11/94	0.2 as 1254	1ST FLOOR MENS ROOM-VISITORS
	(1 @ (30 cm X 30 cm))			POST CLEAN
GAGE	218394-E6-SRN07	8/3/94	3.0 as 1260	SRN07-2ND FLOOR BATHROOM
	(4 @ (15 cm X 15 cm))			PRE-CLEAN
GAGE	21081294-E6-SRN07-PC	8/12/94	0.1 as 1260	SRN07-2ND FLOOR BATHROOM
	(4 @ (15 cm X cm))			POST CLEAN
GAGE	218394-E6-JC12	8/3/94	3.1 as 1260	JANITORS CLOSET #12-2ND FLOOR
	(1 @ (30 cm X 30 cm))			PRE-CLEAN
GAGE	21081294-E6-JC12-PC	8/12/94	ND	JANITORS CLOSET #12-2ND FLOOR
	(1 @ (30 cm X 30 cm))			POST CLEAN
GAGE	218394-E6-JC25	8/3/94	8.6 as 1260	JANITORS CLOSET #25-3RD FLOOR
	(1 @ (30 cm X 30 cm))			PRE-CLEAN
GAGE	21081294-E6-JC25-PC	8/12/94	0.4 as 1260	JANITORS CLOSET
	(1 @ (30 cm X 30 cm))			POST CLEAN
GAGE	218394-E6-SRN011	8/3/94	3.4 as 1260	SRN011-3RD FLOOR BATHROOM
	(4 @ (15 cm X 15 cm))			PRE-CLEAN
GAGE	21081294-SRN011-PC	8/12/94	0.2 as 1260	SRN011-3RD FLOOR BATHROOM
	(4 @ (15 cm X 15 cm))			POST CLEAN
<b>SYSTEM E7</b>				
GAGE	218394-E7-LAUNWEST	8/3/94	14 as 1260	BASEMENT WEST LAUNDRY
	(4 @ (15 cm X 15 cm))			PRE-CLEAN
GAGE	21081194-E7-LAUNWEST-PC	8/11/94	3.7 as 1260	BASEMENT WEST LAUNDRY
	(4 @ (15 cm X 15 cm))			POST CLEAN
GAGE	21080594-JC4-E7	8/5/94	4.7 as 1260	JANITORS CLOSET #4-BASEMENT NO INLET; CUT MADE
	(1 @ (30 cm X 30 cm))			INTO DUCT PRE-CLEAN
GAGE	21080594-JC14-E7	8/5/94	6.5 as 1260	JANITORS CLOSET #7 (SAMPLE ID MISLABELLED) NO INLET; CUT
	(1 @ (30 cm X 30 cm))			MADE INTO DUCT PRE-CLEAN
<b>SYSTEM E8</b>				
GAGE	218394-E8-SRN02	8/3/94	0.7 as 1260	SRN02-BASEMENT BATHROOM
	(6 @ (12.25 cm X 12.25 cm))			PRE-CLEAN
GAGE	218394-E8-JC4	8/3/94	1.0 as 1260	JANITORS CLOSET #4-BASEMENT
	(1 @ (30 cm X 30 cm))			PRE-CLEAN
GAGE	21081194-E8-JC4-PC	8/11/94	ND	JANITORS CLOSET #4
	(1 @ (30 cm X 30 cm))			POST CLEAN

GAGE	218394-E8-JC7	8/3/94	3.6 as 1260	JANITORS CLOSET #7-1ST FLOOR PRE-CLEAN
(1 @ (30 cm X 30 cm))				
GAGE	21081194-E8-JC7-PC	8/11/94	4.7 as 1260	JANITORS CLOSET JC#7 POST CLEAN
(1 @ (30 cm X 30 cm))				
GAGE	218394-E8-SRN04	8/3/94	0.6 as 1260	SRN04-1ST FLOOR BATHROOM PRE-CLEAN
(4 @ (15 cm X 15 cm))				
GAGE	21081194-E8-SRN04-PC	8/11/94	1.1 as 1260	SRN04-1ST FLOOR BATHROOM POST CLEAN
(4 @ (15 cm X 15 cm))				
GAGE	21081194-SRN04(2)-PC	8/11/94	0.8 as 1260	SRN04-1ST FLOOR BATHROOM POST CLEAN
(1 @ (30 cm X 30 cm))				
GAGE	218394-E8-SRN08	8/3/94	3.3 as 1260	SRN08-2ND FLOOR BATHROOM PRE-CLEAN
(1 @ (30 cm X 30 cm))				
GAGE	21081294-SRN08-PC	8/12/94	0.2 as 1260	SRN08-2ND FLOOR BATHROOM POST CLEAN
(4 @ (15 cm X 15 cm))				
GAGE	218394-E8-JC14	8/3/94	0.4 as 1260	JANITORS CLOSET #14-2ND FLOOR PRE-CLEAN
(1 @ (30 cm X 30 cm))				
GAGE	21081294-JC14-PC	8/12/94	ND	JANITORS CLOSET #14-2ND FLOOR POST CLEAN
(1 @ (30 cm X 30 cm))				
GAGE	218394-E8-SRN012	8/3/94	5.6 as 1260	SRN012-3RD FLOOR BATHROOM PRE-CLEAN
(4 @ (15 cm X 15 cm))				
GAGE	21081294-SRN012-PC	8/12/94	0.5 as 1260	SRN012-3RD FLOOR BATHROOM POST CLEAN
(4 @ (15 cm X 15 cm))				
GAGE	218394-E8-JC27	8/3/94	3.4 as 1260	JANITORS CLOSET #27 PRE-CLEAN
(1 @ (30 cm X 30 cm))				
GAGE	21081294-E8-JC27-PC	8/12/94	0.4 as 1260	JANITORS CLOSET #27-3RD FLOOR POST CLEAN
(1 @ (30 cm X 30 cm))				
ROOF VENTS				
GAGE	218394-ROOFVA	8/3/94	3.8 as 1260	SYSTEM E1 PRE-CLEAN
(1 @ (30 cm X 30 cm))				
GAGE	21081194-E1-PC	8/11/94	4.4 as 1260	SYSTEM E1 POST CLEAN
(1 @ (30 cm X 30 cm))				
GAGE	218394-ROOFVB	8/3/94	1.3 as 1260	SYSTEM E2 PRE-CLEAN
(1 @ (30 cm X 30 cm))				
GAGE	21081194-E2-PC	8/11/94	0.4 as 1260	SYSTEM E2 POST CLEAN
(1 @ (30 cm X 30 cm))				
GAGE	218394-ROOFVC	8/3/94	2.4 as 1260	SYSTEM E3 PRE-CLEAN
(1 @ (30 cm X 30 cm))				
GAGE	21081194-E3-PC	8/11/94	1.8 as 1260	SYSTEM E4 POST CLEAN
(1 @ (30 cm X 30 cm))				
GAGE	218394-ROOFVD	8/3/94	0.2 as 1260	SYSTEM E4 PRE-CLEAN
(1 @ (30 cm X 30 cm))				
GAGE	21081194-E4-PC	8/11/94	0.5 as 1260	SYSTEM E4 POST CLEAN
(1 @ (30 cm X 30 cm))				

GAGE 218394-ROOFVE (1 @ (30 CM X 30 CM))	8/3/94	0.5 as 1260	SYSTEM E5 PRE-CLEAN
GAGE 21081194-E5-PC (1 @ (30 CM X 30 CM))	8/11/94	0.9 as 1260	SYSTEM E5 POST CLEAN
GAGE 218394-ROOFVF (1 @ (30 CM X 30 CM))	8/3/94	2.5 as 1260	SYSTEM E6 PRE-CLEAN
GAGE 21081194-E6-PC (1 @ (30 CM X 30 CM))	8/11/94	0.7 as 1260	SYSTEM E6 POST CLEAN
GAGE 218394-ROOFVG (1 @ (30 CM X 30 CM))	8/3/94	0.7 as 1260	SYSTEM E7 PRE-CLEAN
GAGE 21081194-E7-PC (1 @ (30 CM X 30 CM))	8/11/94	8.7 as 1260	SYSTEM E7 POST CLEAN
GAGE 218394-ROOFVH (1 @ (30 CM X 30 CM))	8/3/94	1.6 as 1260	SYSTEM E8 PRE-CLEAN
GAGE 21081194-E8-PC (1 @ (30 CM X 30 CM))	8/11/94	0.5 as 1260	SYSTEM E8 POST CLEAN



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E1-LAWN EAST-GAGE  
Sample Type: Wipe

CHES Lab #: 9408056-01N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	1.6	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E2-JC2-GAGE  
Sample Type: Wipe

CHES Lab #: 9408059-01N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	1.4	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E2-JC2-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408196-04N  
Date Received: 08/12/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/19/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E2-SRN01-GAGE  
Sample Type: Wipe

CHES Lab #: 9408059-02N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	1.1	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E2-SRN01-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408196-03N  
Date Received: 08/12/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/19/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.3	ND	ug/100 sq cm
PCB - Aroclor 1221	0.3	ND	ug/100 sq cm
PCB - Aroclor 1232	0.3	ND	ug/100 sq cm
PCB - Aroclor 1242	0.3	ND	ug/100 sq cm
PCB - Aroclor 1248	0.3	ND	ug/100 sq cm
PCB - Aroclor 1254	0.3	ND	ug/100 sq cm
PCB - Aroclor 1260	0.3	0.4	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E1-LAUNEAST-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408196-05N  
Date Received: 08/12/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/19/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	3.6	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E2-SRN03-GAGE  
Sample Type: Wipe

CHES Lab #: 9408059-03N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	4.9	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E2-SRNO3-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408214-09N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	2.1	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E2-SR010-GAGE  
Sample Type: Wipe ~~SR010~~ SR009 <sup>AD</sup>

CHES Lab #: 9408059-07N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94

Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	10	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E3-EMPWOM-GAGE  
Sample Type: Wipe

CHES Lab #: 9408057-01N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	11	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E2-SRN03JC-GAGE  
Sample Type: Wipe

CHES Lab #: 9408059-04N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94

Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	1.6	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E2-SRNO3JC-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408213-03N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/19/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.3	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E2-SRN05-GAGE  
Sample Type: Wipe

CHES Lab #: 9408059-05N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94

Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	2.2	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081294-E2-SRNO5-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408215-08N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94

Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.1	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E2-JC17-GAGE  
Sample Type: Wipe

CHES Lab #: 9408059-06N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081294-JC17-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408215-01N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.1	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21080994-SRN09JC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408159-01N  
Date Received: 08/11/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/11/94  
Analysis Date: 08/11/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	1.6	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081294-SRNO9JC-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408216-05N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.4	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081094-SRN09-AP, GAGE  
Sample Type: Wipe

CHES Lab #: 9408158-01N  
Date Received: 08/11/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/11/94  
Analysis Date: 08/11/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	1.0	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081094-SRNO9-AP, GAGE  
Sample Type: Wipe

CHES Lab #: 9408158-01N  
Date Received: 08/11/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/11/94  
Analysis Date: 08/11/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	1.0	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E2-SRN09-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408188-01N  
Date Received: 08/12/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/12/94  
Analysis Date: 08/12/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.3	ND	ug/100 sq cm
PCB - Aroclor 1221	0.3	ND	ug/100 sq cm
PCB - Aroclor 1232	0.3	ND	ug/100 sq cm
PCB - Aroclor 1242	0.3	ND	ug/100 sq cm
PCB - Aroclor 1248	0.3	ND	ug/100 sq cm
PCB - Aroclor 1254	0.3	ND	ug/100 sq cm
PCB - Aroclor 1260	0.3	0.4	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081294-SRNO9-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408216-01N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94

Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.1	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E3-EMPWOM-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408188-02N  
Date Received: 08/12/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/12/94

Analysis Date: 08/12/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	1.7	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E3-INCROOM-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408188-03N  
Date Received: 08/12/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/12/94  
Analysis Date: 08/12/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	1.0	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-RD-GBV-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408213-01N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/19/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21080894-RD-GBV, GAGE  
Sample Type: Wipe

CHES Lab #: 9408123-01N  
Date Received: 08/09/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/09/94  
Analysis Date: 08/09/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21080894-RD-GBV, GAGE  
Sample Type: Wipe

CHES Lab #: 9408123-01N  
Date Received: 08/09/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/09/94

Analysis Date: 08/09/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21080894-RD-MBV, GAGE  
Sample Type: Wipe

CHES Lab #: 9408123-02N  
Date Received: 08/09/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/09/94  
Analysis Date: 08/09/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.3	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-RD-BV-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408213-02N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/19/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081294-E3-SRNO6-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408215-07N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E3-JC21-GAGE  
Sample Type: Wipe

CHES Lab #: 9408057-03N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94

Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	2.6	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081294-RD-KV-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408275-01N  
Date Received: 08/17/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/23/94  
Analysis Date: 08/24/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081094-RD-GBV-EXT, GAGE  
Sample Type: Wipe

CHES Lab #: 9408157-01N  
Date Received: 08/11/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/11/94  
Analysis Date: 08/11/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081294-E3-JC21-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408216-06N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E3-~~SRND10~~-GAGE  
Sample Type: Wipe SRND10 AS

CHES Lab #: 9408057-04N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	2.1	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081294-SRNO10-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408216-02N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.4	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081294-E4-3RECRM, GAGE  
Sample Type: Wipe

CHES Lab #: 9408216-09N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E5-BRECRM-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408196-06N  
Date Received: 08/12/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/19/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	1.5	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E5-1RECRM-GAGE  
Sample Type: Wipe

CHES Lab #: 9408055-02N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	2.4	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E~~5~~-1RECRM-PC, GAGE  
Sample Type: Wipe 6

CHES Lab #: 9408213-04N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	0.9	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E6-EMPMENS-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408196-01N  
Date Received: 08/12/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/19/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.3	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E6-WF1-GAGE  
Sample Type: Wipe

CHES Lab #: 9408052-02N  
Date Received: 08/03/94

### Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	2.1	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E6-WFI-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408213-07N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.3	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E6-MFI-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408213-08N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	0.2	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E6-SRNO7-GAGE  
Sample Type: Wipe

CHES Lab #: 9408052-04N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	3.0	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081294-E6-SRNO7-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408215-06N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.1	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E6-JC12-GAGE  
Sample Type: Wipe

CHES Lab #: 9408052-05N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	3.1	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081294-E6-JC12-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408215-05N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081294-E6-JC25-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408216-07N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.4	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E6-SRN011-GAGE  
Sample Type: Wipe

CHES Lab #: 9408052-07N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	3.4	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081294-SRNO11-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408216-04N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21080594-INC-E3, GAGE  
Sample Type: Wipe

CHES Lab #: 9408107-01N  
Date Received: 08/08/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/08/94  
Analysis Date: 08/08/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	1.4	ND	ug/100 sq cm
PCB - Aroclor 1221	1.4	ND	ug/100 sq cm
PCB - Aroclor 1232	1.4	ND	ug/100 sq cm
PCB - Aroclor 1242	1.4	ND	ug/100 sq cm
PCB - Aroclor 1248	1.4	ND	ug/100 sq cm
PCB - Aroclor 1254	1.4	ND	ug/100 sq cm
PCB - Aroclor 1260	1.4	10	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E3-SRN06-GAGE  
Sample Type: Wipe

CHES Lab #: 9408057-02N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	3.4	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E4-2RECRM-GAGE  
Sample Type: Wipe

CHES Lab #: 9408058-01N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94

Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	1.4	ND	ug/100 sq cm
PCB - Aroclor 1221	1.4	ND	ug/100 sq cm
PCB - Aroclor 1232	1.4	ND	ug/100 sq cm
PCB - Aroclor 1242	1.4	ND	ug/100 sq cm
PCB - Aroclor 1248	1.4	ND	ug/100 sq cm
PCB - Aroclor 1254	1.4	ND	ug/100 sq cm
PCB - Aroclor 1260	1.4	5.7	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081294-E4-2RECRM-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408215-02N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	0.2	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E4-3RECRM-GAGE  
Sample Type: Wipe

CHES Lab #: 9408058-02N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	4.1	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E5-BRECRM-GAGE  
Sample Type: Wipe

CHES Lab #: 9408055-01N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	2.4	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E6-EMPMENS-GAGE  
Sample Type: Wipe

CHES Lab #: 9408052-01N  
Date Received: 08/03/94

## Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	1.4	ND	ug/100 sq cm
PCB - Aroclor 1221	1.4	ND	ug/100 sq cm
PCB - Aroclor 1232	1.4	ND	ug/100 sq cm
PCB - Aroclor 1242	1.4	ND	ug/100 sq cm
PCB - Aroclor 1248	1.4	ND	ug/100 sq cm
PCB - Aroclor 1254	1.4	ND	ug/100 sq cm
PCB - Aroclor 1260	1.4	6.3	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E6-MF1-GAGE  
Sample Type: Wipe

CHES Lab #: 9408052-03N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	2.1	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E6-JC25-GAGE  
Sample Type: Wipe

CHES Lab #: 9408052-06N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	1.4	ND	ug/100 sq cm
PCB - Aroclor 1221	1.4	ND	ug/100 sq cm
PCB - Aroclor 1232	1.4	ND	ug/100 sq cm
PCB - Aroclor 1242	1.4	ND	ug/100 sq cm
PCB - Aroclor 1248	1.4	ND	ug/100 sq cm
PCB - Aroclor 1254	1.4	ND	ug/100 sq cm
PCB - Aroclor 1260	1.4	8.6	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E7-LAWN WEST-GAGE  
Sample Type: Wipe

CHES Lab #: 9408060-01N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	1.4	ND	ug/100 sq cm
PCB - Aroclor 1221	1.4	ND	ug/100 sq cm
PCB - Aroclor 1232	1.4	ND	ug/100 sq cm
PCB - Aroclor 1242	1.4	ND	ug/100 sq cm
PCB - Aroclor 1248	1.4	ND	ug/100 sq cm
PCB - Aroclor 1254	1.4	ND	ug/100 sq cm
PCB - Aroclor 1260	1.4	14	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E7-LAUNWEST-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408188-04N  
Date Received: 08/12/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/12/94  
Analysis Date: 08/12/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	3.7	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21080594-JC4-E7, GAGE  
Sample Type: Wipe

CHES Lab #: 9408107-03N  
Date Received: 08/08/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/08/94  
Analysis Date: 08/08/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	1.4	ND	ug/100 sq cm
PCB - Aroclor 1221	1.4	ND	ug/100 sq cm
PCB - Aroclor 1232	1.4	ND	ug/100 sq cm
PCB - Aroclor 1242	1.4	ND	ug/100 sq cm
PCB - Aroclor 1248	1.4	ND	ug/100 sq cm
PCB - Aroclor 1254	1.4	ND	ug/100 sq cm
PCB - Aroclor 1260	1.4	4.7	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21080594-JC14-E7, GAGE  
Sample Type: Wipe

CHES Lab #: 9408107-02N  
Date Received: 08/08/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/08/94  
Analysis Date: 08/08/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	1.4	ND	ug/100 sq cm
PCB - Aroclor 1221	1.4	ND	ug/100 sq cm
PCB - Aroclor 1232	1.4	ND	ug/100 sq cm
PCB - Aroclor 1242	1.4	ND	ug/100 sq cm
PCB - Aroclor 1248	1.4	ND	ug/100 sq cm
PCB - Aroclor 1254	1.4	ND	ug/100 sq cm
PCB - Aroclor 1260	1.4	6.5	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E8-SRN02-GAGE  
Sample Type: Wipe

CHES Lab #: 9408054-01N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.7	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E8-JC4-GAGE  
Sample Type: Wipe

CHES Lab #: 9408054-02N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	1.0	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E8-JC4-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408196-02N  
Date Received: 08/12/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/19/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E8-JC7-GAGE  
Sample Type: Wipe

CHES Lab #: 9408054-03N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	3.6	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E8-JC7-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408213-09N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	4.7	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E8-SRNO4-GAGE  
Sample Type: Wipe

CHES Lab #: 9408054-04N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94

Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.6	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E8-SRNO4-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408213-06N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	1.1	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-SRNO4(2)-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408213-05N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.8	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E8-SRN08-GAGE  
Sample Type: Wipe

CHES Lab #: 9408054-05N  
Date Received: 08/03/94

5N  
34

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	3.3	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081294-SRNO8-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408215-03N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E8-JC14-GAGE  
Sample Type: Wipe

CHES Lab #: 9408054-06N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.4	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081294-JC14-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408215-04N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E8-SRN012-GAGE  
Sample Type: Wipe

CHES Lab #: 9408054-07N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	5.6	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081294-SRNO12-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408216-03N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94

Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.5	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-E8-JC27-GAGE  
Sample Type: Wipe

CHES Lab #: 9408054-08N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	3.4	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081294-E8-JC27-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408216-08N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.4	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-ROOFVA-GAGE  
Sample Type: Wipe

CHES Lab #: 9408053-01N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	3.8	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E1-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408214-01N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	4.4	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-ROOFVB-GAGE  
Sample Type: Wipe

CHES Lab #: 9408053-02N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	1.3	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E2-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408214-02N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.4	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E6-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408214-06N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.7	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-ROOFVG-GAGE  
Sample Type: Wipe

CHES Lab #: 9408053-07N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.7	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E7-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408214-07N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/22/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	1.4	ND	ug/100 sq cm
PCB - Aroclor 1221	1.4	ND	ug/100 sq cm
PCB - Aroclor 1232	1.4	ND	ug/100 sq cm
PCB - Aroclor 1242	1.4	ND	ug/100 sq cm
PCB - Aroclor 1248	1.4	ND	ug/100 sq cm
PCB - Aroclor 1254	1.4	ND	ug/100 sq cm
PCB - Aroclor 1260	1.4	8.7	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-ROOFVH-GAGE  
Sample Type: Wipe

CHES Lab #: 9408053-08N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	1.6	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E8-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408214-08N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/22/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.5	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-ROOFVC-GAGE  
Sample Type: Wipe

CHES Lab #: 9408053-03N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	2.4	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E3-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408214-03N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	1.8	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-ROOFVD-GAGE  
Sample Type: Wipe

CHES Lab #: 9408053-04N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E4-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408214-04N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94

Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.5	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-ROOFVE-GAGE  
Sample Type: Wipe

CHES Lab #: 9408053-05N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.5	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 21081194-E5-PC, GAGE  
Sample Type: Wipe

CHES Lab #: 9408214-05N  
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/19/94  
Analysis Date: 08/20/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.9	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.  
Sample I.D.: 218394-ROOFVF-GAGE  
Sample Type: Wipe

CHES Lab #: 9408053-06N  
Date Received: 08/03/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/03/94  
Analysis Date: 08/04/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	2.5	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)  
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.