

GAGE HALL - WIPE SAMPLES OF ROOMS WITH INLETS

LOCATION	ID #	DATE	RESULT	COMMENTS
EXHAUST SYSTEM E1				
GAGE	21082494-LAUNEAST (4 @ (15 cm X 15 cm))	8/24/94	0.1 as 1260	EAST WING LAUNDRY ROOM: 2 TABLE TOPS, 2 WASHING MACHINES BASEMENT
EXHAUST SYSTEM E2				
GAGE	21082494-SRN01 (4 @ (15 cm X 15 cm))	8/24/94	ND	SRN01: 2 SINK LEDGES, 2 WINDOW SILLS BASEMENT
GAGE	21082494-SRN03E (4 @ (15 cm X 15 cm))	8/24/94	ND	SRN03: 2 SINK LEDGES, 2 WINDOW SILLS 1ST FLOOR
GAGE	21082494-SRN03W (4 @ (15 cm X 15 cm))	8/24/94	ND	SRN03: 2 SINK LEDGES, 2 WINDOW SILLS 1ST FLOOR
GAGE	2182794-E2-JC10 (1 @ (30 cm X 30 cm))	8/27/94	0.1 as 1260	JANITORS CLOSET: SHELF 1ST FLOOR
GAGE	21082494-SRN05 (4 @ (15 cm X 15 cm))	8/24/94	ND	SRN05: 2 SINK LEDGES, 2 WINDOW SILLS 2ND FLOOR
GAGE	21082494-SRN09 (4 @ (15 cm X 15 cm))	8/24/94	ND	SRN09: 2 SINK LEDGES, 2 WINDOW SILLS
SYSTEM E3				
GAGE	21082494-EMPWOM (4 @ (15 cm X 15 cm))	8/24/94	0.2 as 1260	BASEMENT EMPLOYEE WOMENS ROOM: 2 SINK LEDGES, 2 WINDOW SILLS
GAGE	21082494-RES DIR (4 @ (15 cm X 15 cm))	8/24/94	ND	RESIDENT DIRECTOR'S ROOM: GUEST BEDROOM TABLE, KITCHEN SHELF, LIVING ROOM TABLE, BATHROOM SINK LEDGE
GAGE	21082494-SRN06 (4 @ (15 cm X 15 cm))	8/24/94	0.1 as 1260	SRN06: 2 SINK LEDGES, 2 WINDOW SILLS 2ND FLOOR
GAGE	21082494-SRN010 (4 @ (15 cm X 15 cm))	8/24/94	ND	SRN010: 2 SINK LEDGES, 2 WINDOW SILLS 3RD FLOOR
EXHAUST SYSTEM E4				
GAGE	21082494-2RECRM (4 @ (15 cm X 15 cm))	8/24/94	ND	2ND FLOOR RECREATION ROOM: TABLE, HEATER, STOVE, TABLE
GAGE	21082494-3RECRM (4 @ (15 cm X 15 cm))	8/24/94	0.2 as 1254	3RD FLOOR RECREATION ROOM: TABLE, TABLE, STOVE TOP, WINDOW SILL
EXHAUST SYSTEM E5				
GAGE	21080494-TABLE2 (1 @ (30 cm X 30 cm))	8/4/94	ND	BASEMENT REC RM; SEE MAP
GAGE	21080494-TV (1 @ (30 cm X 30 cm))	8/4/94	0.1/1254	BASEMENT REC RM; TELEVISION
GAGE	21080494-TABLE-1 (1 @ (30 cm X 30 cm))	8/4/94	ND	BASEMENT REC RM; TABLE
GAGE	21080494-HEATER (1 @ (30 cm X 30 cm))	8/4/94	ND	BASEMENT REC RM; HEATER
GAGE	21080494-STOVE (1 @ (30 cm X 30 cm))	8/4/94	ND	BASEMENT REC RM; STOVE

GAGE	21080594-WPN	8/4/94	ND	BASMENT REC RM; WALL PAPER; NORTH
(4 @ (15 cm X 15 cm))				
GAGE	21080594-WPS	8/4/94	ND	BASEMENT REC RM; WALL PAPER; SOUTH
(4 @ (15 cm X 15 cm))				
GAGE	21082494-1RECRM	8/24/94	ND	1ST FLOOR REC RM: STOVE, PIANO, HEATER, TABLE
(4 @ (15 cm X 15 cm))				

EXHAUST SYSTEM E6

GAGE	21082494-EMP MEN	8/24/94	0.3 as 1254	BASMENT EMPLOYEE MENS ROOM: 2 SINK LEDGES, 2 WINDOW SILLS
(4 @ (15 cm X 15 cm))				
GAGE	21082494-WF1	8/24/94	ND	1ST FLOOR MENS ROOM-VISITORS: PAPER TOWEL HOLDER, WINDOW SILL, SINK LEDGE, SINK SHELF
(4 @ (15 cm X 15 cm))				
GAGE	21082494-WF1	8/24/94	0.2 as 1260	1ST FLOOR WOMENS ROOM-VISITORS: PAPER TOWEL HOLDER, SINK LEDGE, WINDOW SILL, SINK SHELF
(4 @ (15 cm X 15 cm))				
GAGE	21082494-SRN07	8/24/94	ND	SRN07: 2 SINK LEDGES, 2 WINDOW SILLS
(4 @ (15 cm X 15 cm))				
GAGE	21082494-SRN011	8/24/94	ND	SRN011: 2 SINK LEDGES, 2 WINDOW SILLS
(4 @ (15 cm X 15 cm))				
GAGE	2182794-E6-JC25	8/27/94	0.2 as 1260	JANITORS CLOSET #25: SHELF
(1 @ (30 cm X 30 cm))				
3RD FLOOR				

EXHAUST SYSTEM E7

GAGE	21082494-LAUNWEST	8/24/94	0.1 as 1260	WEST WING LAUNDRY ROOM: 2 TABLE TOPS, 2 WASHING MACHINES
(4 @ (15 cm X 15 cm))				
BASEMENT				

EXHAUST SYSTEM E8

GAGE	21082494-SRN02	8/24/94	0.1 as 1260	SRN02: 2 SINK LEDGES, 2 WINDOW SILLS
(4 @ (15 cm X 15 cm))				
BASEMENT				
GAGE	2182794-E8-JC4	8/27/94	0.1 as 1260	JANITORS CLOSET #4: SHELF
(1 @ (30 cm X 30 cm))				
BASEMENT				
GAGE	21082494-SRN04	8/24/94	ND	SRN04: 2 SINK LEDGES, 2 WINDOW SILLS
(4 @ (15 cm X 15 cm))				
1ST FLOOR				
GAGE	21082494-SRN08	8/24/94	ND	SRN08: 2 SINK LEDGES, 2 WINDOW SILLS
(4 @ (15 cm X 15 cm))				
2ND FLOOR				
GAGE	21082494-SRN012	8/24/94	ND	SRN012: 2 SINK LEDGES, 2 WINDOW SILLS
(4 @ (15 cm X 15 cm))				
3RD FLOOR				



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-LAUNEAST, GAGE
Sample Type: Wipe

CHES Lab #: 9408405-02N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94

Analysis Date: 08/25/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.1	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-SRN01, GAGE
Sample Type: Wipe

CHES Lab #: 9408405-01N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/25/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-SRN03E, GAGE
Sample Type: Wipe

CHES Lab #: 9408405-07N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/25/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-SRN03W, GAGE
Sample Type: Wipe

CHES Lab #: 9408404-05N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/25/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 2182794-E2-JC10, GAGE
Sample Type: Wipe

CHES Lab #: 9408494-03N
Date Received: 08/30/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/30/94
Analysis Date: 08/30/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.1	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-SRN05, GAGE
Sample Type: Wipe

CHES Lab #: 9408403-04N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/24/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-SRN09, GAGE
Sample Type: Wipe

CHES Lab #: 9408403-09N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/25/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-EMPWOM, GAGE
Sample Type: Wipe

CHES Lab #: 9408405-03N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/25/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-RES DIR, GAGE
Sample Type: Wipe

CHES Lab #: 9408405-08N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/25/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-SRN06, GAGE
Sample Type: Wipe

CHES Lab #: 9408403-05N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/24/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.1	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-SRN010, GAGE
Sample Type: Wipe

CHES Lab #: 9408404-01N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/25/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-2RECRM, GAGE
Sample Type: Wipe

CHES Lab #: 9408403-06N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/24/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-3RECRM, GAGE
Sample Type: Wipe

CHES Lab #: 9408404-02N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/25/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	0.2	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21080494-TABLES, GAGE
Sample Type: Wipe

CHES Lab #: 9408204-01N
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/15/94
Analysis Date: 08/16/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL).
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21080494-TV, GAGE
Sample Type: Wipe

CHES Lab #: 9408204-02N
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/15/94
Analysis Date: 08/15/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	0.1	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21080494-TABLE-1, GAGE
Sample Type: Wipe

CHES Lab #: 9408204-03N
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/15/94

Analysis Date: 08/15/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21080494-HEATER, GAGE
Sample Type: Wipe

CHES Lab #: 9408204-04N
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/15/94
Analysis Date: 08/15/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21080494-STOVE, GAGE
Sample Type: Wipe

CHES Lab #: 9408204-06N
Date Received: 08/15/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/15/94
Analysis Date: 08/15/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21080594-WPN, GAGE
Sample Type: Wipe

CHES Lab #: 9408253-01N
Date Received: 08/17/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/17/94

Analysis Date: 08/17/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	ND	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)
Wipe Area: 100 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21080594-WPS, GAGE
Sample Type: Wipe

CHES Lab #: 9408253-02N
Date Received: 08/17/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/17/94
Analysis Date: 08/17/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 100 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-1RECRM, GAGE
Sample Type: Wipe

CHES Lab #: 9408405-09N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/25/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-EMPMEN, GAGE
Sample Type: Wipe

CHES Lab #: 9408405-04N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94

Analysis Date: 08/25/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	0.3	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-MF1, GAGE
Sample Type: Wipe

CHES Lab #: 9408403-01N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/24/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-WF1, GAGE
Sample Type: Wipe

CHES Lab #: 9408403-02N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/24/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-SRN07, GAGE
Sample Type: Wipe

CHES Lab #: 9408403-07N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94

Analysis Date: 08/24/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-SRN011, GAGE
Sample Type: Wipe

CHES Lab #: 9408404-03N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/25/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 2182794-E6-JC25, GAGE
Sample Type: Wipe

CHES Lab #: 9408494-01N
Date Received: 08/30/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/30/94
Analysis Date: 08/30/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-LAUNWEST, GAGE
Sample Type: Wipe

CHES Lab #: 9408405-05N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/25/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.1	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-SRN02, GAGE
Sample Type: Wipe

CHES Lab #: 9408405-06N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/25/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.1	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 2182794-E8-JC4, GAGE
Sample Type: Wipe

CHES Lab #: 9408494-02N
Date Received: 08/30/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/30/94
Analysis Date: 08/30/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	.0.1	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-SRN04, GAGE
Sample Type: Wipe

CHES Lab #: 9408403-03N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/24/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-SRN08, GAGE
Sample Type: Wipe

CHES Lab #: 9408403-08N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/24/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors Environmental Services, Inc.
Sample I.D.: 21082494-SRN012, GAGE
Sample Type: Wipe

CHES Lab #: 9408404-04N
Date Received: 08/24/94

Polychlorinated Biphenyls (PCBs)

Extraction Date: 08/24/94
Analysis Date: 08/25/94

Parameter	PQL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below practical quantitation limit (PQL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.