


Building = 18 (W)

WOOSTER SCIENCE BUILDING



BASEMENT FLOOR PLAN


Simplex Recorder Co.

- FIRE ALARMS ☐
- P.W. EXT. ☐
- CO2 EXT. ☐
- ABC EXT. ☐
- GENERATOR ☐
- FIREPANEL ☐

SUNY New Paltz 8/75
Safety Office


WOOSTER SCIENCE BUILDING

Stair III




FIRST FLOOR PLAN

Stair III



WOORSTER SCIENCE BUILDING



SECOND FLOOR PLAN



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: SWS-5, WOOSTER
Sample Type: Wipe

CHAS Lab #: 9201009-05N
Date Received: 01/02/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 01/02/91
Analysis Date: 01/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 100 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: SWS-4, WOOSTER
Sample Type: Wipe

CHAS Lab #: 9201009-04N
Date Received: 01/02/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 01/02/91
Analysis Date: 01/02/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 100 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.