



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021092101 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202122-05N
Date Received: 02/11/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/11/92
Analysis Date: 02/11/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-102 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202204-01N
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/19/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021092103 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202122-06N
Date Received: 02/11/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/11/92
Analysis Date: 02/11/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-104 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202204-02N
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/19/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-105 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202203-061
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/20/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-106 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202204-03N
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/19/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-107 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202203-07N
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/20/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-108 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202203-08N
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/20/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-109 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202204-09N
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/19/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-110 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202204-04
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/19/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021092111 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202122-07M
Date Received: 02/11/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/11/92
Analysis Date: 02/11/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021092112 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202122-10
Date Received: 02/11/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/11/92
Analysis Date: 02/11/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021092113 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202122-01
Date Received: 02/11/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/11/92
Analysis Date: 02/11/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-114 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202204-06M
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/19/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-115 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202203-02N
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/20/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.

Sample I.D.: 2021892-116 SCUDDER

Sample Type: Wipe

CHAS Lab #: 9202203-03N

Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92

Analysis Date: 02/20/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)

Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-117 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202203-04N
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/20/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-118 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202204-07N
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/19/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-119 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202203-05N
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/20/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-120 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202204-08N
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/19/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-121 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202203-09N
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/20/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-122 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202201-01N
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/19/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021092123 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202122-09N
Date Received: 02/11/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/11/92
Analysis Date: 02/11/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021092124 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202120-01N
Date Received: 02/11/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/11/92
Analysis Date: 02/11/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021092125 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202120-02N
Date Received: 02/11/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/11/92
Analysis Date: 02/11/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-125BR SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205005-07N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92
Analysis Date: 05/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.5	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-126 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202204-11N
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/20/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-126BED SCUDDER
Sample Type: Wipe

CHAS Lab #: 0005011-01N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92
Analysis Date: 05/04/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-126MAIN SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205011-02N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92
Analysis Date: 05/04/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-126KIT SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205011-03N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92
Analysis Date: 05/04/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-126BATH SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205011-04N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92
Analysis Date: 05/05/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 1-3, SCUDDER HALL
Sample Type: Wipe

CHAS Lab #: 9112302-04N
Date Received: 12/31/91

Polychlorinated Biphenyls (PCBs)

Extraction Date: 12/31/91
Analysis Date: 12/31/91

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	31	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 100 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-DB SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202204-10N
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/20/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2032492-1 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9203407-01N
Date Received: 03/26/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 03/26/92
Analysis Date: 03/27/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

Dir off

Report: P C B P R E

Initials: RF 7/29

Status: D R A F T

Printed: APR. 29 1992 12:41 PM

Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2042192-DIROFW SCUODER
Sample Type: Wipe

CHAS Lab #: 9204346-05H
Date Received: 04/22/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/23/92

Analysis Date: 04/24/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

----- NOTES -----

Calculated and reported by KW.

Report: F C B P R E

Initials: EE v/2

Status: D R A F T

Printed: APR. 29 1992 12:43 PM

Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2042192-DIROFF SCUDDER
Sample Type: Wipe

CHAS Lab #: 9204346-09N
Date Received: 04/22/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/23/92

Analysis Date: 04/24/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

----- NOTES -----

Calculated and reported by KW.

RCV BY:XEROX TELECOPIER 7010 ; 5- 5-92 6:03PM ;
SENT BY:CH Analyst Serv/Wood Rd; 5- 5-92 6:03PM ;

6178481955→
6178481955→



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-DIROFFA SCUDDER
Sample Type: Wipe

CHAS Lab #:
Date Received:

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92
Analysis Date: 05/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 s
PCB - Aroclor 1221	0.1	ND	ug/100 s
PCB - Aroclor 1232	0.1	ND	ug/100 s
PCB - Aroclor 1242	0.1	ND	ug/100 s
PCB - Aroclor 1248	0.1	ND	ug/100 s
PCB - Aroclor 1254	0.1	ND	ug/100 s
PCB - Aroclor 1260	0.1	ND	ug/100 s

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-DIROFFB SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205006-08N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92

Analysis Date: 05/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2642192-SRNO3 SCUDDER POST
Sample Type: Wipe

CHAS Lab #: 9204342-0
Date Received: 04/22/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/22/92

Analysis Date: 04/23/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

Report: P C B P R E

Initials: KF 4/29

Status: D R A F T

Printed: APR. 28 1992 7:45 PM

Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2042192-SRN04 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9204345-02N
Date Received: 04/22/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/23/92

Analysis Date: 04/24/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

----- NOTES -----

Calculated and reported by KW.

Report: P C B P R E

Initials: EE 4/29

Status: I D R A P T

Printed: APR. 28 1992 7:47 PM

Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2042192-PUBST SCUDDER
Sample Type: Wipe

CHAS Lab #: 9204345-07N
Date Received: 04/22/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/23/92

Analysis Date: 04/24/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.7 0.6	ug/100 sq cm

EE 4/29

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

NOTES

Calculated and reported by KW.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-PUBERI SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205006-09N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92
Analysis Date: 05/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-REC3 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202204-05N
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/19/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-JC117 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205007-02N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92
Analysis Date: 05/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-JC124 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205007-03N
Data Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92
Analysis Date: 05/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-JG101 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205005-01N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92

Analysis Date: 05/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-JCSRNO3 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205005-08N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92
Analysis Date: 05/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2642192-JCL4 SCUDDER POST
Sample Type: Wipe

CHAS Lab #: 9204342-04
Data Received: 04/22/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/22/92

Analysis Date: 04/23/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 201C1692, SCUDDER
Sample Type: Wipe

CHAS Lab #: 9201072-01N
Date Received: 01/07/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 01/07/92
Analysis Date: 01/07/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2042192-MAIN LOBBY SCUDDER
Sample Type: Wipe

CHAS Lab #: 9204345-06N
Date Received: 04/22/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/23/92
Analysis Date: 04/25/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	10	ND	ug/100 sq cm
PCB - Aroclor 1221	10	ND	ug/100 sq cm
PCB - Aroclor 1232	10	ND	ug/100 sq cm
PCB - Aroclor 1242	10	ND	ug/100 sq cm
PCB - Aroclor 1248	10	ND	ug/100 sq cm
PCB - Aroclor 1254	10	ND	ug/100 sq cm
PCB - Aroclor 1260	10	110	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-MNLOBBYA SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205006-01N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92
Analysis Date: 05/04/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	10	ND	ug/100 sq cm
PCB - Aroclor 1221	10	ND	ug/100 sq cm
PCB - Aroclor 1232	10	ND	ug/100 sq cm
PCB - Aroclor 1242	10	ND	ug/100 sq cm
PCB - Aroclor 1248	10	ND	ug/100 sq cm
PCB - Aroclor 1254	10	ND	ug/100 sq cm
PCB - Aroclor 1260	10	96	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-MNLOBBYB SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205006-02N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92
Analysis Date: 05/04/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	2.9	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-MNLOBBYC SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205006-03N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92

Analysis Date: 05/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.8	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-MNLOBBYD SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205006-04N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92
Analysis Date: 05/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.6	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 205692 L1A SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205064-07N
Date Received: 05/07/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/07/92
Analysis Date: 05/07/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.5	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 205692 L1B SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205064-08N
Date Received: 05/07/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/07/92
Analysis Date: 05/07/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	14	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 205692 LIC SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205064-09N
Date Received: 05/07/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/07/92
Analysis Date: 05/07/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.4	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 205692 L1D SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205064-10N
Date Received: 05/07/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/07/92
Analysis Date: 05/07/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.1	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 205892 MLA, POST CLN. SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205099-02N
Date Received: 05/08/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/08/92
Analysis Date: 05/09/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.5	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 205892 MLB, POST CLN. SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205099-03N
Date Received: 05/08/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/08/92

Analysis Date: 05/09/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-MLKITA SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205006-05N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92
Analysis Date: 05/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

RCV BY:XEROX TELECOPIER 7010 ; 5- 5-92 6:02PM ;

6178481955→

SENT BY:CH Analyst Serv/Wood Rd; 5- 5-92 6:03PM ;

6178481955→



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-MLKITB SCUDDER
Sample Type: Wipe

CHAS Lab #: 9
Date Received

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92

Analysis Date: 05/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq
PCB - Aroclor 1221	0.1	ND	ug/100 sq
PCB - Aroclor 1232	0.1	ND	ug/100 sq
PCB - Aroclor 1242	0.1	ND	ug/100 sq
PCB - Aroclor 1248	0.1	ND	ug/100 sq
PCB - Aroclor 1254	0.1	ND	ug/100 sq
PCB - Aroclor 1260	0.1	0.1	ug/100 sq

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 1-2, SCUDDER HALL
Sample Type: Wipe

CHAS Lab #: 9112302-05N
Date Received: 12/31/91

Polychlorinated Biphenyls (PCBs)

Extraction Date: 12/31/91
Analysis Date: 12/31/91

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	100	ND	ug/100 sq cm
PCB - Aroclor 1221	100	ND	ug/100 sq cm
PCB - Aroclor 1232	100	ND	ug/100 sq cm
PCB - Aroclor 1242	100	ND	ug/100 sq cm
PCB - Aroclor 1248	100	ND	ug/100 sq cm
PCB - Aroclor 1254	100	ND	ug/100 sq cm
PCB - Aroclor 1260	100	710	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 100 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 201A1692 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9201060-01N
Date Received: 01/07/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 01/07/92
Analysis Date: 01/07/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	1.8	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 201A1792, SCUDDER
Sample Type: Wipe

CHAS Lab #: 9201074-02N
Date Received: 01/08/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 01/08/92
Analysis Date: 01/08/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.7	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

Report: P C B P R E

Initials: EE 4/29

Status: D R A F T

Printed: APR. 29 1992 12:40 PM

Client: Clean Harbors of Kingston, Inc.

CHAS Lab #: 9204346-01N

Sample I.D.: 2042192-LOBBYF SCUDDER

Date Received: 04/22/92

Sample Type: Wipe

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/23/92

Analysis Date: 04/23/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.1-0.2 ug	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

----- NOTES -----

Calculated and reported by KW.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2042192-LOBBYW SCUDDER
Sample Type: Wipe

CHAS Lab #: 9204344-02N
Date Received: 04/22/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/23/92

Analysis Date: 04/23/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-CLA SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205006-10N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92
Analysis Date: 05/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-CLB SCUDDER
Sample Type: Wipe

CHAS Lab #: 920
Date Received:

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92
Analysis Date: 05/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2043092-CLC SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205007-01N
Date Received: 05/01/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/01/92

Analysis Date: 05/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2021892-OM SCUDDER
Sample Type: Wipe

CHAS Lab #: 9202203-01N
Date Received: 02/19/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 02/19/92
Analysis Date: 02/20/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 1-1, SCUDDER HALL
Sample Type: Wipe

CHAS Lab #: 9112302-02N
Date Received: 12/31/91

Polychlorinated Biphenyls (PCBs)

Extraction Date: 12/31/91
Analysis Date: 12/31/91

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	61	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 100 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

Hall in front of S.R. 103



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: SWS-14, SCUDDER HALL
Sample Type: Wipe

CHAS Lab #: 9201010-03N
Date Received: 01/02/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 01/02/91
Analysis Date: 01/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 100 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: SWS-17, SCUDDER HALL
Sample Type: Wipe

CHAS Lab #: 9201010-06N
Date Received: 01/02/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 01/02/91
Analysis Date: 01/03/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 100 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

Report: P C E L P R E

Initials: SP 4/29

Status: D R A F T

Printed: APR. 29 1992 12:41 PM

Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2042192-HS113F SCHLUDER
Sample Type: Wipe

CHAS Lab #: 9204346-06N
Date Received: 04/22/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/23/92

Analysis Date: 04/24/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

----- NOTES -----

Calculated and reported by KW.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2042192-HN108W SCUDDER
Sample Type: Wipe

CHAS Lab #: 9204347-06N
Date Received: 04/22/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/23/92

Analysis Date: 04/24/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2042192-HN103F SCUDDER
Sample Type: Wipe

CHAS Lab #: 9204347-07N
Date Received: 04/22/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/23/92
Analysis Date: 04/24/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2042292-HS1W SCUDDER
Sample Type: Wipe

CHAS Lab #: 9204372-02N
Date Received: 04/23/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/25/92
Analysis Date: 04/27/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

Report: PCB PRE

Initials: RF ybs

Status: DRAFT

Printed: APR. 29 1992 12:42 PM

Client: Clean Harbors of Kingston, Inc.

CHAS Lab #: 9204346-07N

Sample I.D.: 2042192-1SN SCUDDER

Date Received: 04/22/92

Sample Type: Wipe

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/23/92

Analysis Date: 04/24/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)

Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

----- NOTES -----

Calculated and reported by KW.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2042192-1SC SCUDDER
Sample Type: Wipe

CHAS Lab #: 9204344-05N
Date Received: 04/22/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/23/92

Analysis Date: 04/23/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.3	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2042192-1SS SCUDDER
Sample Type: Wipe

CHAS Lab #: 9204347-04N
Date Received: 04/22/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/23/92

Analysis Date: 04/24/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2042292-COKEV SCUDDER
Sample Type: Wipe

CHAS Lab #: 9204370-01N
Date Received: 04/23/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/25/92
Analysis Date: 04/25/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2042292-VF SCUDDER
Sample Type: Wipe

CHAS Lab #: 9204370-02N
Date Received: 04/23/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/25/92

Analysis Date: 04/25/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2042292-CANDY SCUDDER
Sample Type: Wipe

CHAS Lab #: 9204370-04N
Date Received: 04/23/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/25/92
Analysis Date: 04/26/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2642192-PATIO SCUDDER POST
Sample Type: Wipe

CHAS Lab #: 9204342-0
Date Received: 04/22/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/22/92

Analysis Date: 04/23/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.4	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 205592-P1 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205042-01N
Date Received: 05/06/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/06/92
Analysis Date: 05/06/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 205592-P2 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205042-02N
Date Received: 05/06/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/06/92
Analysis Date: 05/06/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.3	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 205592-P3 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205042-03N
Date Received: 05/06/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/06/92
Analysis Date: 05/06/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	0.2	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 205592-P4 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205042-04N
Date Received: 05/06/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/06/92
Analysis Date: 05/06/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	4.5	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 205892 PA, POST CLN. SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205099-01N
Date Received: 05/08/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/08/92
Analysis Date: 05/09/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 205892 GA, POST CLN. SCUDDER
Sample Type: Wipe

CHAS Lab #: 9205099-04N
Date Received: 05/08/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 05/08/92
Analysis Date: 05/09/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	0.1	ND	ug/100 sq cm
PCB - Aroclor 1221	0.1	ND	ug/100 sq cm
PCB - Aroclor 1232	0.1	ND	ug/100 sq cm
PCB - Aroclor 1242	0.1	ND	ug/100 sq cm
PCB - Aroclor 1248	0.1	ND	ug/100 sq cm
PCB - Aroclor 1254	0.1	ND	ug/100 sq cm
PCB - Aroclor 1260	0.1	ND	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.