



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: B-2, SCUDDER HALL
Sample Type: Wipe

CHAS Lab #: 9112302-06N
Date Received: 12/31/91

Polychlorinated Biphenyls (PCBs)

Extraction Date: 12/31/91
Analysis Date: 12/31/91

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1000	ND	ug/100 sq cm
PCB - Aroclor 1221	1000	ND	ug/100 sq cm
PCB - Aroclor 1232	1000	ND	ug/100 sq cm
PCB - Aroclor 1242	1000	ND	ug/100 sq cm
PCB - Aroclor 1248	1000	ND	ug/100 sq cm
PCB - Aroclor 1254	1000	ND	ug/100 sq cm
PCB - Aroclor 1260	1000	30,000	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 100 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2031892 SCUDDER
Sample Type: Wipe

CHAS Lab #: 9201094-04N
Date Received: 01/09/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 01/09/92
Analysis Date: 01/10/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	500	ND	ug/100 sq cm
PCB - Aroclor 1221	500	ND	ug/100 sq cm
PCB - Aroclor 1232	500	ND	ug/100 sq cm
PCB - Aroclor 1242	500	ND	ug/100 sq cm
PCB - Aroclor 1248	500	ND	ug/100 sq cm
PCB - Aroclor 1254	500	ND	ug/100 sq cm
PCB - Aroclor 1260	500	9,000	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2032092-1 SCUDDER VAULT
Sample Type: Wipe

CHAS Lab #: 9203326-01N
Date Received: 03/20/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 03/20/92
Analysis Date: 03/22/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	100	ND	ug/100 sq cm
PCB - Aroclor 1221	100	ND	ug/100 sq cm
PCB - Aroclor 1232	100	ND	ug/100 sq cm
PCB - Aroclor 1242	100	ND	ug/100 sq cm
PCB - Aroclor 1248	100	ND	ug/100 sq cm
PCB - Aroclor 1254	100	ND	ug/100 sq cm
PCB - Aroclor 1260	100	220	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2032092-2 SCUDDER VAULT
Sample Type: Wipe

CHAS Lab #: 9203326-02N
Date Received: 03/20/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 03/20/92
Analysis Date: 03/22/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	100	ND	ug/100 sq cm
PCB - Aroclor 1221	100	ND	ug/100 sq cm
PCB - Aroclor 1232	100	ND	ug/100 sq cm
PCB - Aroclor 1242	100	ND	ug/100 sq cm
PCB - Aroclor 1248	100	ND	ug/100 sq cm
PCB - Aroclor 1254	100	ND	ug/100 sq cm
PCB - Aroclor 1260	100	210	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2032092-3 SCUDDER VAULT
Sample Type: Wipe

CHAS Lab #: 9203326-03N
Date Received: 03/20/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 03/20/92
Analysis Date: 03/22/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	100	ND	ug/100 sq cm
PCB - Aroclor 1221	100	ND	ug/100 sq cm
PCB - Aroclor 1232	100	ND	ug/100 sq cm
PCB - Aroclor 1242	100	ND	ug/100 sq cm
PCB - Aroclor 1248	100	ND	ug/100 sq cm
PCB - Aroclor 1254	100	ND	ug/100 sq cm
PCB - Aroclor 1260	100	150	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2032092-4 SCUDDER VAULT
Sample Type: Wipe

CHAS Lab #: 9203326-04N
Date Received: 03/20/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 03/20/92
Analysis Date: 03/22/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	100	ND	ug/100 sq cm
PCB - Aroclor 1221	100	ND	ug/100 sq cm
PCB - Aroclor 1232	100	ND	ug/100 sq cm
PCB - Aroclor 1242	100	ND	ug/100 sq cm
PCB - Aroclor 1248	100	ND	ug/100 sq cm
PCB - Aroclor 1254	100	ND	ug/100 sq cm
PCB - Aroclor 1260	100	210	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2032092-5 SCUDDER VAULT
Sample Type: Wipe

CHAS Lab #: 9203326-05N
Date Received: 03/20/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 03/20/92
Analysis Date: 03/22/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	100	ND	ug/100 sq cm
PCB - Aroclor 1221	100	ND	ug/100 sq cm
PCB - Aroclor 1232	100	ND	ug/100 sq cm
PCB - Aroclor 1242	100	ND	ug/100 sq cm
PCB - Aroclor 1248	100	ND	ug/100 sq cm
PCB - Aroclor 1254	100	ND	ug/100 sq cm
PCB - Aroclor 1260	100	420	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

Report: PCBs PCE

Initials: DS/4

Status: DRAFT

Printed: MAY 4 1992 2:23 PM

Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2042892-VFL SCUDDER
Sample Type: Wipe

CHAS Lab #: 9204463-01
Date Received: 04/30/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/30/92 ✓
Analysis Date: 05/01/92 ✓

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	100 ✓	ND	ug/100 sq cm
PCB - Aroclor 1221	100	ND	ug/100 sq cm
PCB - Aroclor 1232	100	ND	ug/100 sq cm
PCB - Aroclor 1242	100	ND	ug/100 sq cm
PCB - Aroclor 1248	100	ND	ug/100 sq cm
PCB - Aroclor 1254	100	ND	ug/100 sq cm
PCB - Aroclor 1260	100	1,400 ✓	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm ✓

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

NOTES

MDL'S 1000x STD MDL'S DUE TO 1:1000 DIL. NEEDED (HIGH-LEVEL 1260) ✓
C&R 5/4 EF.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2032092-6 SCUDDER VAULT
Sample Type: Wipe

CHAS Lab #: 9203326-06N
Date Received: 03/20/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 03/20/92
Analysis Date: 03/22/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	100	ND	ug/100 sq cm
PCB - Aroclor 1221	100	ND	ug/100 sq cm
PCB - Aroclor 1232	100	ND	ug/100 sq cm
PCB - Aroclor 1242	100	ND	ug/100 sq cm
PCB - Aroclor 1248	100	ND	ug/100 sq cm
PCB - Aroclor 1254	100	ND	ug/100 sq cm
PCB - Aroclor 1260	100	4,300	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

Report: PCB F R E

Initials: DS 5/4

Status: D R A F T

Printed: MAY 4 1992 2:23

Client: Clean Harbors of Kingston, Inc.

Sample I.D.: 2042892-VCL SCUDDER

Sample Type: Wipe

CHAS Lab #: 9204463-0

Date Received: 04/30/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/30/92 ✓

Analysis Date: 05/01/92 ✓

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0 ✓	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	4.2 ✓	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)

Wipe Area: 900 sq cm ✓

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

NOTES

DL's 10X standard DL's due to 1:10 dilution needed for analysis (high PCBs) ✓
C&R 5/4 EF.

Report: P C B F R E

Initials: DS 5/4

Status: D R A F T

Printed: MAY 4 1992 2:21

Client: Clean Harbors of Kingston, Inc.

Sample I.D.: 2042992-TOPB SCUDDER

Sample Type: Wipe

CHAS Lab #: 9204464-01

Date Received: 04/30/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/30/92 ✓

Analysis Date: 05/01/92 ✓

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	1.0 ✓	ND	ug/100 sq cm
PCB - Aroclor 1221	1.0	ND	ug/100 sq cm
PCB - Aroclor 1232	1.0	ND	ug/100 sq cm
PCB - Aroclor 1242	1.0	ND	ug/100 sq cm
PCB - Aroclor 1248	1.0	ND	ug/100 sq cm
PCB - Aroclor 1254	1.0	ND	ug/100 sq cm
PCB - Aroclor 1260	1.0	64 ✓	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)

Wipe Area: 900 sq cm ✓

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECO following EPA Method 8080.

----- NOTES -----

DL's 10X standard DL's due to 1:10 dilution needed for analysis (high PCBs) ✓
C&R 5/4 EF.

DL's 100X standard DL's due to 1:100 dilution needed for analysis (high PC/As)
C&R 5/4 EF.

Report: PCBPRE

Initials: DS 5/4

Status: DRAFT

Printed: MAY 4 1992 2:22

Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2042992-FLRB SCUDDER
Sample Type: Wipe

CHAS Lab #: 9204464-0
Date Received: 04/30/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 04/30/92 ✓
Analysis Date: 05/01/92 ✓

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	10 ✓	ND	ug/100 sq cm
PCB - Aroclor 1221	10	ND	ug/100 sq cm
PCB - Aroclor 1232	10	ND	ug/100 sq cm
PCB - Aroclor 1242	10	ND	ug/100 sq cm
PCB - Aroclor 1248	10	ND	ug/100 sq cm
PCB - Aroclor 1254	10	ND	ug/100 sq cm
PCB - Aroclor 1260	10	240 ✓	ug/100 sq cm

Notes: ND = Below minimum detectable level (MDL)
Wipe Area: 900 sq cm ✓

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.

----- NOTES -----

DL's 100X standard DL's due to 1:100 dilution needed for analysis (high PC
C&R 5/4 EF.



Client: Clean Harbors of Kingston, Inc.
Sample I.D.: 2032092-C SCUDDER VAULT
Sample Type: Wipe

CHAS Lab #: 9203321-01N
Date Received: 03/20/92

Polychlorinated Biphenyls (PCBs)

Extraction Date: 03/20/92

Analysis Date: 03/21/92

Parameter	MDL	Concentration	Units
PCB - Aroclor 1016	100	ND	ug/100 sq cm
PCB - Aroclor 1221	100	ND	ug/100 sq cm
PCB - Aroclor 1232	100	ND	ug/100 sq cm
PCB - Aroclor 1242	100	ND	ug/100 sq cm
PCB - Aroclor 1248	100	ND	ug/100 sq cm
PCB - Aroclor 1254	100	ND	ug/100 sq cm
PCB - Aroclor 1260	100	320	ug/100 sq cm

Notes: ND - Below minimum detectable level (MDL)
Wipe Area: 900 sq cm

The sample was mixed with hexane for 5 minutes. The resulting extract was analyzed by GC/ECD following EPA Method 8080.