

SCUDDER HALL - WIPE SAMPLES (ug/100 sq cm)

<u>LOCATION</u>	<u>ID #</u>	<u>DATE</u>	<u>TYPE</u>	<u>RESULT</u>	<u>COMMENTS</u>
SCUDR	SWS-12	01/01/92	WIPE	4.2 as 1260	<u>ROOM B1-FLOOR</u>
	(1 @ (10 cm X 10 cm))				PRE-CLEAN
SCUDR	2021192B-1	02/11/92	WIPE	ND	<u>ROOM B1</u>
	(4 @ (10 cm X 10 cm))				1)FRIDGE 2)DESK ON LEFT
					3)DRESSER ON LEFT
					4)DRESSER ON RT
					PRE-CLEAN
SCUDR	203392-B1L	03/03/92	WIPE	ND	<u>RM B1 LEFT WALL</u>
	(1 @ (30 cm x 30 cm))				PRE-CLEAN
SCUDR	203392-B1R	03/03/92	WIPE	ND	<u>RM B1 RT WALL</u>
	(1 @ (30 cm x 30 cm))				PRE-CLEAN
SCUDR	203392-B1D	03/03/92	WIPE	ND	<u>RM B1 DOOR WALL</u>
	(1 @ (30 cm x 30 cm))				PRE-CLEAN
SCUDR	203392-B1W	03/03/92	WIPE	ND	<u>RM B1 WINDOW WALL</u>
	(1 @ (30 cm x 30 cm))				PRE-CLEAN
SCUDR	2022892-B1A	02/28/92	WIPE	0.1 as 1260	<u>RM B1 LEFT DESK</u>
	(1 @ (30 cm x 30 cm))				(CONFIRMATION SAMPLE)
					PRE-CLEAN
SCUDR	2022892-B1B	02/28/92	WIPE	ND	<u>RM B1 LEFT FRIDGE</u>
	(1 @ (30 cm x 30 cm))				(CONFIRMATION SAMPLE)
					PRE-CLEAN
SCUDR	2022892-B1C	02/28/92	WIPE	ND	<u>RM B1 DESK</u>
	(1 @ (30 cm x 30 cm))				(CONFIRMATION SAMPLE)
					PRE-CLEAN

SCUDR 2022892-B1D-1 2/28/92 WIPE ND
(1 @ (30 cm x 30 cm))

SCUDR 2022892-B1D-2 2/28/92 WIPE ND
(1 @ (30 cm x 30 cm))

SCUDR 205192B1F 05/01/92 WIPE ND
(1 @ (30 cm x 30 cm))

SCUDR 2021792-B2 02/17/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021792-B3 02/17/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021792-B4 02/17/92 WIPE 0.2 as 1260
(4 @ (15 cm X 15 cm))

SCUDR 2021792-B5 02/17/92 WIPE 0.1 as 1260
(4 @ (15 cm X 15 cm))

SCUDR 2021192B-6 02/11/92 WIPE 5.6 as 1260
(4 @ (15 cm X 15 cm))

SCUDR 2022892-B6A 02/28/92 WIPE 6.6
(1 @ (30 cm X 30 cm))

RM B1 RIGHT DRESSER
(CONFIRMATION SAMPLE)

PRE-CLEAN

RM B1

PRE-CLEAN

RM B1 FLOOR

POST-CLEAN

ROOM B2

1)RIGHT DESK; 2)FRIDGE;
3)LEFT DESK; 4)LEFT DRESSER

ROOM B3

1)LEFT DESK; 2)LEFT DRESSER
3)FRIDGE; 4)LEFT DESK

ROOM B4

1)DESK ON RT 2)DRESSER
ON LEFT 3)DESK ON LEFT
4)DRESSER ON RT

ROOM B5

1)1ST DESK ON RT 2)2ND
DESK ON RT 3)TOP OF
BOOKCASE 4)DRESSER IN
RT CORNER

ROOM B6 - PRE-CLEAN

1)DESK ON LEFT 2)DESK
ON LEFT NEAR WINDOW
3)DRESSER NEAR WINDOW
4)DRESSER ON RT

RM B6 - PRE-CLEAN

LEFT DESK

SCUDR 2022892-B6B 02/28/92 WIPE 11	<u>RM B6</u> - PRE-CLEAN
(1 @ (30 cm X 30 cm))	DESK
SCUDR 2022892-B6C 02/28/92 WIPE 3.2	<u>RM B6</u> - PRE-CLEAN
(1 @ (30 cm X 30 cm))	DRESSER
SCUDR 2022892-B6D 02/28/92 WIPE 11	<u>RM B6</u> - PRE-CLEAN
(1 @ (30 cm X 30 cm))	RIGHT DRESSER
SCUDR 2051192-B6-1 05/11/92 WIPE ND	<u>RM B6</u> - POST-CLEAN
(1 @ (30 cm X 30 cm))	
SCUDR 2051192-B6-2 05/11/92 WIPE ND	<u>RM B6</u> - POST-CLEAN
(1 @ (30 cm X 30 cm))	
SCUDR 2051192-B6-3 05/11/92 WIPE 0.2 as 1260	<u>RM B6</u> - POST-CLEAN
(1 @ (30 cm X 30 cm))	
SCUDR 2051192-B6-4 05/11/92 WIPE ND	<u>RM B6</u> - POST-CLEAN
(1 @ (30 cm X 30 cm))	
SCUDR 2021792-B7 02/17/92 WIPE ND	<u>ROOM B7</u>
(1 @ (15 cm x 15 cm))	1)DESK ON LEFT
	2)DRESSER ON RT
	3)DESK IN RT CORNER
	4)DRESSER ON LEFT
	PRE-CLEAN
SCUDR 203392-B7L 03/03/92 WIPE ND	<u>RM B7</u> LEFT WALL
(1 @ (30 cm X 30 cm))	PRE-CLEAN
SCUDR 203392-B7R 03/03/92 WIPE ND	<u>RM B7</u> RT WALL
(1 @ (30 cm X 30 cm))	PRE-CLEAN
SCUDR 203392-B7D 03/03/92 WIPE ND	<u>RM B7</u> DOOR WALL
(1 @ (30 cm X 30 cm))	PRE-CLEAN
SCUDR 203392-B7W 03/03/92 WIPE ND	<u>RM B7</u> WINDOW WALL
(1 @ (30 cm X 30 cm))	PRE-CLEAN
SCUDR 2022892-B7A 02/28/92 WIPE ND	<u>RM B7</u> LEFT DESK
(1 @ (30 cm X 30 cm))	PRE-CLEAN

SCUDR 2022892-B7B 02/28/92 WIPE 0.1 (1 @ (30 cm X 30 cm))	<u>RM B7</u> LEFT DRESSER PRE-CLEAN
SCUDR 2022892-B7C 02/28/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>RM B7</u> RIGHT DRESSER PRE-CLEAN
SCUDR 2021092B-8 02/10/92 WIPE 1.1 as 1260 (4 @ (15 cm x 15 cm))	<u>ROOM B8</u> - PRE-CLEAN 1)DRESSER RT OF WINDOW 2)DRESSER LEFT OF WINDOW 3)WINDOW SILL 4)DESK ON RT WALL
SCUDR 2022892-B8A 02/28/92 WIPE 0.7 as 1260 (1 @ (30 cm X 30 cm))	<u>RM B8</u> - PRE-CLEAN LEFT DRESSER
SCUDR 2022892-B8B 02/28/92 WIPE 0.6 as 1260 (1 @ (30 cm X 30 cm))	<u>RM B8</u> - PRE-CLEAN DESK AGAINST WINDOW
SCUDR 2022892-B8C 02/28/92 WIPE 0.8 as 1260 (1 @ (30 cm X 30 cm))	<u>RM B8</u> - PRE-CLEAN RIGHT DESK
SCUDR 2022892-B8D 02/28/92 WIPE 0.3 as 1260 (1 @ (30 cm X 30 cm))	<u>RM B8</u> - PRE-CLEAN RIGHT DRESSER
SCUDR 2051192-B8-1 05/11/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>RM B8</u> - POST-CLEAN
SCUDR 2051192-B8-2 05/11/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>RM B8</u> - POST-CLEAN
SCUDR 2051192-B8-3 05/11/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>RM B8</u> - POST-CLEAN
SCUDR 2051192-B8-4 05/11/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>RM B8</u> - POST-CLEAN
SCUDR 2021792-B9 02/17/92 WIPE ND (4 @ (15 cm X 15 cm))	<u>ROOM B9</u> 1)DESK IN MIDDLE OF RM 2)DRESSER ON RT 3)SPEAKER ON LEFT CLOSET 4)DESK ON LEFT OF RM

SCUDR 2021092B10 02/10/92 WIPE 0.2 as 1260 (4 @ (15 cm X 15 cm))	<u>ROOM B10</u>
SCUDR 2021792-B11 02/17/92 WIPE 0.1 as 1260 (4 @ (15 cm X 15 cm))	<u>ROOM B11</u> 1)DESK IN MIDDLE OF ROOM; 2)DESK ON LEFT OF ROOM; 3)LEFT DRESSER; 4)RIGHT DRESSER
SCUDR 2021092B12 02/10/92 WIPE 0.2 as 1260 (4 @ (15 cm X 15 cm))	<u>ROOM B12</u>
SCUDR 2021792-B13 02/17/92 WIPE ND (4 @ (15 cm X 15 cm))	<u>ROOM B13</u> 1)LEFT DESK; 2)RIGHT DESK; 3)LEFT DRESSER; 4)RIGHT DRESSER
SCUDR 2021792-B14 02/17/92 WIPE ND (4 @ (15 cm X 15 cm))	<u>ROOM B14</u> 1)LEFT DESK; 2)LEFT FRIDGE; 3)RIGHT DESK; 4)RIGHT FRIDGE
SCUDR 2021792-B15 02/17/92 WIPE 0.1 as 1260 (4 @ (15 cm X 15 cm))	<u>ROOM B15</u> 1)LEFT DESK; 2)RIGHT DESK 3)TV STAND W/O TV; 4)FIRST DRESSER
SCUDR 2021092B16 02/10/92 WIPE 0.2 as 1260 (4 @ (15 cm X 15 cm))	<u>ROOM B16</u>
SCUDR 2043092-PUBBRB 04/30/92WIPE 0.2 as 1260 (1 @ (30 cm X 30 cm))	<u>PUBL BATHRM - BASEMENT</u> PAPER TOWEL DISPENSER
SCUDR 2042292-SRN01 04/23/92 WIPE 0.7 as 1260 (4 @ (15 cm X 15 cm))	<u>SRN01 BASEMENT</u> 1ST POST-CLEAN

SCUDR 205692 BNC 05/06/92 WIPE 1.4 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 205692 BNA 05/06/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 205692 BNB 05/06/92 WIPE 0.3 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 205692 BND 05/06/92 WIPE 0.9 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2051192-SRN01 05/11/92 WIPE 0.4 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2042292-SRN02 04/22/92 WIPE ND
(1 @ (15 cm X 15 cm))

SCUDR 2021792-REC1 02/17/92 WIPE 0.1 as 1260
(4 @ (15 cm X 15 cm))

SCUDR 20B22892-RR2 02/28/92 WIPE 0.5 as 1260
(4 @ (15 cm X 15cm))

SCUDR 2043092-RECR2A 04/30/92WIPE 0.1 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2043092-RECR2B 04/30/92WIPE 0.2 as 1260
(1 @ (30 cm X 30 cm))

BASEMENT NORTH BATHRM
SHOWER BENCH (SRN01)
(CONFIRMATION SAMPLE)
BASEMENT NORTH BATHRM
SILL ABOVE SINK (SRN01)
(CONFIRMATION SAMPLE)
BASEMENT NORTH BATHRM
TOILET SEAT (SRN01)
(CONFIRMATION)
BASEMENT NORTH BATHRM
TOP OF LIGHT OVER MIRROR
(CONFIRMATION SAMPLE)
SRN01
2ND POST-CLEAN
SRN02 BASEMENT
POST-CLEAN

REC 01 RECR-1
ON THE MAP
REC. RM 2
BASEMENT
RECR-2 ON THE MAP
RECR2 DRESSER
BASEMENT
(CONFIRMATION SAMPLE)
RECR2 BOOKCASE
BASEMENT
(CONFIRMATION SAMPLE)

SCUDR 2043092-RECR2C 04/30/92WIPE ND

(1 @ (30 cm X 30 cm))

SCUDR 2043092-RECR2D 04/30/92WIPE 0.1 as 1260

(1 @ (30 cm X 30 cm))

SCUDR 20B22892-ST1 02/28/92 WIPE 0.1 as 1260

(4 X 225) CM SQ

SCUDR 2032692-S1 03/26/92 WIPE ND

(1 @ 30 X 30) CM SQ

SCUDR 2032692-S2 03/26/92 WIPE 0.1 as 1260

(1 @ 30 X 30) CM SQ

SCUDR 2032692-S3 03/26/92 WIPE 0.1 as 1260

(1 @ 30 X 30) CM SQ

SCUDR 2032592-SR 03/25/92 WIPE ND

(1 @ (30 cm X 30 cm))

SCUDR 2042292-STOR1 04/22/92 WIPE ND

(4 @ (15 cm X 15 cm))

SCUDR 2042292-STOR7 04/22/92 WIPE 0.7 as 1260

(4 @ (15 cm X 15 cm))

SCUDR 2042292-INCIN 04/22/92 WIPE 0.3 as 1260

(4 @ (15 cm X 15 cm))

SCUDR 2021792-INCIN 02/17/92 WIPE 0.6 AS 1260

(4 @ (15 cm X 15 cm))

SCUDR 205592-STOR7 05/05/92 WIPE ND

(1 @ (30 cm X 30 cm))

SCUDR 2043092-JCCL 04/30/92 WIPE ND

(1 @ (30 cm X 30 cm))

RECR2 DRESSER

BASEMENT

(CONFIRMATION SAMPLE)

RECR2 BOOKCASE

BASEMENT

(CONFIRMATION SAMPLE)

STOR. RM 1

BASEMENT

STOR. 1 DESK

STOR. 1 TABLE

STOR. 1 CONDUIT

STORAGE RM 1 CHAIR AND DESK

STORAGE 1

BASEMENT

STORAGE 7

STORAGE 7 ON NEW MAP

BASEMENT

INCINERATOR

STOR7 ON NEW MAP

STORAGE 7 - POST-CLEAN

(CONFIRMATION SAMPLE)

JC IN CENTRAL LOBBY

BASEMENT 3RD SHELF

SCUDR 2043092-JCSN 04/30/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2043092-JCRECR2 04/30/92WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2042292-MAINT 04/23/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 202A1692 01/06/92 WIPE 6.2 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 205592-BLA 05/05/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 205592-BLB 05/05/92 WIPE 0.1 as 1254
(1 @ (30 cm X 30 cm))

SCUDR 205592-BLC 05/05/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 205592-BLD 05/05/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2021792-LR1 02/17/92 WIPE 0.2 as 1260
(4 @ (15 cm X 15 cm))

SCUDR 2021792-LR2 02/17/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021792-LD1 02/17/92 WIPE 0.8 as 1260
(4 @ (15 cm X 15 cm))

SCUDR 2043092-LAUND1A 04/30/92WIPE ND
(1 @ (30 cm X 30 cm))

JC NEAR NORTH STAIR
BASEMENT; SHELF

JC ACROSS FROM RECR2

MECH JC ON NEW MAP
BASEMENT

BASEMENT LOBBY-LIGHT
PRE-CLEAN

CENTRAL LOBBY - BASEMENT
POST-CLEAN

CENTRAL LOBBY - BASEMENT
POST-CLEAN

CENTRAL LOBBY - BASEMENT
POST-CLEAN

CENTRAL LOBBY - BASEMENT
POST-CLEAN

LUGGAGE ROOM #1

LUGGAGE ROOM #2

CONFERENCE RM ON MAP

LAUNDRY ROOM #1

LAUNDRY RM #1

4TH LEFT WASHER
POST-CLEAN

SCUDR 2043092-LAUND1B 04/30/92WIPE 0.2 as 1260

(1 @ (30 cm X 30 cm))

SCUDR 2043092-LAUND1C 04/30/92WIPE ND

(1 @ (30 cm X 30 cm))

SCUDR 2043092-LAUND1D 04/30/92WIPE ND

(1 @ (30 cm X 30 cm))

SCUDR 2021792-LD2 02/17/92 WIPE ND

(4 @ (15 cm X 15 cm))

SCUDR 2042292-LAUND2 04/22/92 WIPE ND

(1 @ (30 cm X 30 cm))

SCUDR 203392-BS1 03/03/92 WIPE 41 as 1260

(4 @ (15 cm X 15 cm))

SCUDR 203392-RR 03/03/92 WIPE 15 as 1260

(4 @ (15 cm X 15 cm))

SCUDR 2042292-STSER/MECH 04/23/92 WIPE 0.7 as 1260 *MECH RM ON NEW MAP*

(4 @ (15 cm X 15 cm))

SCUDR 205692 BMA 05/06/92 WIPE 0.3 as 1260

(1 @ (30 cm X 30 cm))

LAUNDRY RM #1

4TH LEFT DRYER

POST-CLEAN

LAUNDRY RM #1

2ND LEFT WASHER

POST-CLEAN

LAUNDRY RM #1

2ND LEFT DRYER

POST-CLEAN

LAUNDRY ROOM #2

LAUNDRY RM #2

BASEMENT

FUR S1 2 SMALL TABLES,

CHAIR, DRESSER

*JANITOR'S BREAK RM

ON NEW MAP*

LIN SR RECYCLING RM

TABLE, VENT TRASH CAN

LID, TOP OF DUCTWORK

BASEMENT 1ST POST-CLEAN

BASEMENT MECH. RM

TOP OF TANK

1ST POST-CLEAN

(CONFIRMATION SAMPLE)

SCUDR 205692 BMB 05/06/92 WIPE 0.7 as 1260 (1 @ (30 cm X 30 cm))	<u>BASEMENT MECH. RM</u> TOP OF WATER HEATER 1ST POST-CLEAN (CONFIRMATION SAMPLE)
SCUDR 205692 BMC 05/06/92 WIPE 0.9 as 1260 (1 @ (30 cm X 30 cm))	<u>BASEMENT MECH. RM</u> TOP OF ELECTRICAL PANEL 1ST POST-CLEAN (CONFIRMATION SAMPLE)
SCUDR 205692 BMD 05/06/92 WIPE 2.7 as 1260 (1 @ (30 cm X 30 cm))	<u>BASEMENT MECH RM</u> TOP OF COMPRESSOR 1ST POST-CLEAN (CONFIRMATION SAMPLE)
SCUDR 2051192-MECH 05/11/92 WIPE 4.3 as 1260 (1 @ (30 cm X 30 cm))	<u>MECH RM</u> 2ND POST-CLEAN
SCUDR 2051392-MECH ROOM 05/13/92 WIPE ND	<u>MECH RM WALL</u> 3RD POST-CLEAN
SCUDR SWS-13 01/01/92 WIPE 1.2 as 1260 (1 @ (10 cm X 10 cm))	<u>HALLWAY-WALL LIGHT NEXT TO</u> ROOM B16 PRE-CLEAN
SCUDR B-1 12/31/91 WIPE 220 as 1260 (1 @ (10 cm X 10 cm))	<u>HALLWAY BETWEEN LAUNDRY RM</u> AND MAINTENANCE PRE-CLEAN
SCUDR 20BA1792 01/07/92 WIPE 1.7 as 1260 (1 @ (30 cm X 30 cm))	<u>HALLWAY NEAR ROOM B4</u> PRE-CLEAN
SCUDR 2042292-BHNW 04/22/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>BASEMENT HALL NORTH WALL</u> AT B5; POST-CLEAN
SCUDR 2042292-BHNF 04/22/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>BASEMENT HALL NORTH</u> FLOOR AT B1 POST-CLEAN

SCUDR 2042292-BHSW 04/22/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2042292-BHSF 04/22/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2042292-BSC 04/22/92 WIPE 0.3 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2042292-BSS 04/22/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2042292-BSN 04/22/92 WIPE ND
(1 @ (30 cm X 30 cm))

BASEMENT HALL SOUTH
WALL BY B15/B16

POST-CLEAN

BASEMENT HALL SOUTH
FLOOR BY B11/B12

POST-CLEAN

BASEMENT CENTRAL STAIRS

POST CLEAN

BASEMENT SOUTH STAIRS

POST-CLEAN

BASEMENT STAIRS NORTH

FLOOR; POST-CLEAN

SCUDR 2021092101 02/10/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021892-102 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021092103 02/10/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021892-104 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

RM 101

RM 102

1)RT DESK 2)LEFT FRIDGE
3)RT WINDOW SILL 4)1ST RT
DESK

RM 103

RM 104

1)1ST LEFT DESK 2)LEFT
DRESSER 3)LEFT DESK
4)FRIDGE IN BETWEEN DESKS

SCUDR 2021892-105 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

RM 105

1)LEFT DESK; 2)DESK ON LEFT
SIDE OF WALL; 3)FRIDGE ON
RIGHT; 4)DRESSER ON LEFT

SCUDR 2021892-106 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

RM 106

1)LEFT DESK 2)RT DESK
3)LEFT BOOKS

SCUDR 2021892-107 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

RM 107

1)1ST DESK ON LEFT; 2)2ND
DESK ON LEFT; 3)DRESSER ON
RIGHT; 4)DRESSER IN BETWEEN
BEDS (RIGHT)

SCUDR 2021892-108 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

RM 108

1)DESK ON LEFT CORNER;
2)DESK ON LEFT WALL
3)DRESSER ON LEFT; 4)DRES-
SER ON RIGHT

SCUDR 2021892-109 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

RM 109

1)LEFT DESK; 2)RIGHT DESK;
3)MIDDLE DRESSER (1ST);
4)MIDDLE DRESSER (2ND)

SCUDR 2021892-110 02/18/92 WIPE 0.2 as 1260
(4 @ (15 cm X 15 cm))

RM 110

1)LEFT DESK; 2)RIGHT DESK;
3)RIGHT DRESSER; 4)LEFT
SIDE WINDOW SILL

SCUDR 2021092111 02/10/92 WIPE ND
(4 @ (15 cm X 15 cm))

RM 111

SCUDR 2021092112 02/10/92 WIPE 0.2 as 1260
(4 @ (15 cm X 15 cm))

RM 112

SCUDR 2021092113 02/10/92 WIPE ND
(4 @ (15 cm X 15 cm))

RM 113

SCUDR 2021892-114 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

RM 114

- 1)DRESSER ON FAR WALL;
- 2)LEFT DESK; 3)RIGHT DESK;
- 4)LEFT DRESSER

SCUDR 2021892-115 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

RM 115

- 1)DESK ON FAR WALL; 2)RIGHT DESK; 3)LEFT DRESSER;
- 4)RIGHT DRESSER

SCUDR 2021892-116 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

RM 116

- 1)LEFT DESK; 2)DESK ON FAR WALL; 3)MIDDLE DRESSER;
- 4)RIGHT DRESSER

SCUDR 2021892-117 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

RM 117

- 1)RIGHT DESK; 2)RIGHT FRIDGE
- 3)RIGHT DRESSE; 4)ANSWERING MACHINE

SCUDR 2021892-118 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

RM 118

- 1)RIGHT CORNER DESK; 2)LEFT DESK; 3)RIGHT DRESSER;
- 4)LEFT DRESSER

SCUDR 2021892-119 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

RM 119

- 1)1ST DESK ON LEFT WALL;
- 2)2ND DESK ON LEFT WALL;
- 3)RIGHT DRESSER; 4)RIGHT FRIDGE

SCUDR 2021892-120 02/18/92 WIPE ND

(4 @ (15 cm X 15 cm))

RM 120

1)LEFT DESK; 2)RIGHT DESK;
3)RIGHT BOOKCASE; 4)CARD-
BOARD BOX IN LEFT CLOSET

SCUDR 2021892-121 02/18/92 WIPE ND

(4 @ (15 cm X 15 cm))

RM 121

1)MIDDLE DESK; 2)LEFT
DRESSER; 3)RIGHT DESK;
4)RIGHT DRESSER

SCUDR 2021892-122 02/18/92 WIPE ND

(4 @ (15 cm X 15 cm))

RM 122

1)TOP OF DRESSER ON LEFT;
2)FRIDGE ON RIGHT; 3)DESK
ON RIGHT; 4)DESK ON MIDDLE

SCUDR 2021092123 02/10/92 WIPE ND

(4 @ (15 cm X 15 cm))

RM 123

SCUDR 2021092124 02/10/92 WIPE 0.2 as 1260

(4 @ (15 cm X 15 cm))

RM 124

SCUDR 2021092125 02/10/92 WIPE ND

(4 @ (15 cm X 15 cm))

RM 125

SCUDR 2043092-125BR 04/30/92 0.5 as 1260

(1 @ (30 cm X 30 cm))

BATHRM IN RM 125

POST-CLEAN

SCUDR 2021892-126 02/18/92 WIPE ND

(4 @ (15 cm X 15 cm))

RM 126

1)STOVE; 2)CHAIR ON
CIRCULAR TABLE; 3)TV
TABLE; 4)TABLE IN BETWEEN
TWO COUCHES

SCUDR 2043092-126BED 04/30/92WIPE ND

(1 @ (30 cm X 30 cm))

POST-CLEAN

RM 126 1)DRESSER

2)BED TABLE3)NOTEBOOK
4)TABLE

SCUDR 2043092-126MAIN 04/30/92WIPE ND

(1 @ (30 cm X 30 cm))

SCUDR 2043092-126KIT 04/30/92WIPE ND

(1 @ (30 cm X 30 cm))

SCUDR 2043092-126BATH 04/30/92WIPE ND

(1 @ (30 cm X 30 cm))

SCUDR 1-3 12/31/91 WIPE 31 as 1260

(1 @ (10 cm X 10 cm))

SCUDR 2021892-DB 02/18/92 WIPE ND

(4 @ (15 cm X 15 cm))

SCUDR 2032492-1 03/04/92 WIPE ND

(4 @ (15 cm X 15 cm))

SCUDR 2042192-DIROFW 04/21/92 WIPE ND

(1 @ (30 cm X 30 cm))

SCUDR 2042192-DIROFF 04/21/92 WIPE ND

(1 @ (30 cm X 30 cm))

SCUDR 2043092-DIROFFA 04/30/92WIPE ND

(1 @ (30 cm X 30 cm))

SCUDR 2043092-DIROFFB 04/30/92WIPE ND

(1 @ (30 cm X 30 cm))

POST-CLEAN RM 126

1)MICROWAVE 2)FRIDGE

3)TV 4)TABLE

POST-CLEAN RM 126

1)STOVETOP (X2)

2)FRIDGE SHELF

POST-CLEAN RM 126

1)SINK LEDGE 2)TOILET

3)TUB LEDGE 4)TUB RIM

DIRECTOR'S OFFICE

PRE-CLEAN

DIRECTOR'S BED

1)DRESSER ON RIGHT 2)SEAT

ON LEFT CORNER; 3)NIGHT-

STAND ON LEFT; 4)SINK

IN BEDROOM

PRE-CLEAN

COMPOSITE FROM DESK IN

DIRECTOR'S OFFICE

DIR OFFICE WALL

POST-CLEAN

DIRECTOR'S OFFICE FLOOR

POST-CLEAN

DIR OFFICE LEFT WALL

POST-CLEAN

DIR OFFICE RT WALL

POST-CLEAN

SCUDR 2642192-SRN03 04/23/92 WIPE ND (4 @ (15 cm X 15 cm))	<u>SRN03</u> - 1ST FLOOR POST-CLEAN
SCUDR 2042192-SRN04 04/17/92 WIPE ND (4 @ (15 cm X 15 cm))	<u>BATH SRN04</u> - 1ST FLOOR 1ST FLOOR
SCUDR 2042192-PUBST 04/17/92 WIPE 0.6 as 1260 (4 @ (15 cm X 15 cm))	<u>PUB ST</u> - 1ST FLOOR PUBLIC BATHROOM - POST-CLEAN
SCUDR 2043092-PUBBR1 04/30/92 WIPE ND (1 @ (30 cm X 30 cm))	POST-CLEAN <u>PUB BATHRM</u> PAPER TOWEL DISPENSER (CONFIRMATION)
SCUDR 2021892-REC3 02/18/92 WIPE 0.2 as 1260 (4 @ (15 cm X 15 cm))	<u>REC 3</u> 1ST FL
SCUDR 2043092-JC117 04/30/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>JC</u> NEAR 117 SHELF POST-CLEAN
SCUDR 2043092-JC124 04/30/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>JC</u> NEAR 124 SHELF POST-CLEAN
SCUDR 2043092-JC101 04/30/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>JC</u> ACROSS FROM 101 - SHELF POST-CLEAN
SCUDR 2043092-JCSRN03 04/30/92 ND (1 @ (30 cm X 30 cm))	<u>JC</u> IN SRN03, 1ST SHELF POST-CLEAN 1ST FL
SCUDR 2642192-JCL4 04/21/92 WIPE ND (4 @ (15 cm X 15 cm))	<u>JC4</u> - 1ST FLOOR CENTRAL LOBBY - POST-CLEAN
SCUDR 201C1692 01/06/92 WIPE ND (1 @ (10 cm X 10 cm))	1ST FLOOR <u>MAIN LOBBY</u> TABLE
SCUDR 2042192-MAIN LOBBY 04/21/92 WIPE 110 as 1260 (4 @ (15 cm X 15 cm))	<u>1ST MAIN LOBBY</u> 1ST POST-CLEAN

SCUDR 2043092-MNLOBBYA 04/30/92WIPE 96 as 1260 (1 @ (30 cm X 30 cm))	<u>MAIN LOBBY</u> SILL LEFT 2ND POST-CLEAN
SCUDR 2043092-MNLOBBYB 04/30/92WIPE 2.9 as 1260 (1 @ (30 cm X 30 cm))	<u>MAIN LOBBY</u> 2ND SILL FROM LEFT 2ND POST-CLEAN
SCUDR 2043092-MNLOBBYC 04/30/92WIPE 0.8 as 1260 (1 @ (30 cm X 30 cm))	<u>MAIN LOBBY</u> 2ND SILL FROM LEFT 2ND POST-CLEAN
SCUDR 2043092-MNLOBBYD 04/30/92WIPE 0.6 as 1260 (1 @ (30 cm X 30 cm))	<u>MAIN LOBBY</u> LEFT SILL 2ND POST-CLEAN
SCUDR 205692 L1A 05/06/92 WIPE 0.5 as 1260 (1 @ (30 cm X 30 cm))	<u>MAIN LOBBY</u> 1ST FL WINDOWSILL EAST 3RD POST-CLEAN
SCUDR 205692 L1B 05/06/92 WIPE 14 as 1260 (1 @ (30 cm X 30 cm))	<u>MAIN LOBBY</u> 1ST FL WINDOWSILL WEST 3RD POST-CLEAN
SCUDR 205692 L1C 05/06/92 WIPE 0.4 as 1260 (1 @ (30 cm X 30 cm))	<u>MAIN LOBBY</u> 1ST FL FIREPLACE HEARTH 3RD POST-CLEAN
SCUDR 205692 L1D 05/06/92 WIPE 0.1 as 1260 (1 @ (30 cm X 30 cm))	<u>MAIN LOBBY</u> 1ST FL TOP OF FIRE EXT. CASE 3RD POST-CLEAN
SCUDR 205892 MLA 05/08/92 WIPE 0.5 as 1260 (1 @ (30 cm X 30 cm))	<u>MAIN LOBBY</u> WEST WINDOWSILL 4TH POST-CLEAN
SCUDR 205892 MLB 05/08/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>MAIN LOBBY</u> TOP OF WALL NEAR CEILING 4TH POST-CLEAN

SCUDR 2043092-MLKITA 04/30/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>MAIN LOBBY KIT STOVE</u>
SCUDR 2043092-MLKITB 04/30/92 WIPE 0.1 as 1260 (1 @ (30 cm X 30 cm))	<u>MAIN LOBBY KIT STOVE</u>
SCUDR 1-2 12/31/91 WIPE 710 as 1260 (1 @ (10 cm X 10 cm))	<u>CENTRAL LOBBY</u> PRE-CLEAN
SCUDR 201A1692 01/06/92 WIPE 1.8 as 1260 (1 @ (30 cm X 30 cm))	<u>CENTRAL LOBBY-</u> 1ST FL; TABLE PRE-CLEAN
SCUDR 201A1792 01/07/92 WIPE 0.7 as 1260 (1 @ (30 cm X 30 cm))	1ST FLOOR <u>CENTRAL LOBBY</u> PRE-CLEAN
SCUDR 2042192-LOBBYF 04/21/92 WIPE 0.1 as 1260 (1 @ (30 cm X 30 cm))	<u>CENTRAL LOBBY FLOOR</u> POST-CLEAN
SCUDR 2042192-LOBBYW 04/21/92 WIPE ND ● @ (30 cm X 30 cm))	1ST FL <u>CENTRAL LOBBY WALL</u> POST-CLEAN
SCUDR 2043092-CLA 04/30/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>CENTRAL LOBBY</u> FIRE DOOR POST-CLEAN
SCUDR 2043092-CLB 04/30/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>CENTRAL LOBBY WALL</u> POST-CLEAN
SCUDR 2043092-CLC 04/30/92 WIPE 0.2 as 1260 (1 @ (30 cm X 30 cm))	<u>CENTRAL LOBBY PHONE</u> BOOTH POST-CLEAN
SCUDR 2021892-OM 02/18/92 WIPE ND (4 @ (15 cm X 15 cm))	<u>OFFICE MR NEXT TO</u> DIRECTOR'S OFFICE 1ST FLOOR

1)DESK IN FRONT OF DOOR;
2)FILE CABINET ON RIGHT
CORNER; 3)BOOKCASE ON
LEFT; 4)WINDOWSILL ON
RIGHT FRONT WINDOW

SCUDR 1-1 12/31/91 WIPE 61 as 1260
(1 @ (10 cm X 10 cm))

SCUDR SWS-14 01/01/92 WIPE ND
(1 @ (10 cm X 10 cm))

SCUDR SWS-17 01/01/92 WIPE ND
(1 @ (10 cm X 10 cm))

SCUDR 2042192-HS113F 04/21/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2042192-HN108W 04/21/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2042192-HN103F 04/21/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2042292-HS1W 04/22/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2042192-1SN 04/21/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2042192-1SC 04/21/92 WIPE 0.3 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2042192-1SS 04/21/92 WIPE 0.2 as 1260
(1 @ (30 cm X 30 cm))

HALLWAY IN FRONT OF
SRN03 PRE-CLEAN

HALLWAY-LIGHT FIXTURE NEXT
RM 123 PRE-CLEAN

HALLWAY-WINDOW SILL NEXT TO
TO RM 101 PRE-CLEAN

HALL FLOOR BY 113
POST-CLEAN

HALL WALL NEAR RM 108
POST-CLEAN

HALL FLOOR IN FRONT OF
RM 103 POST-CLEAN

HALLWAY WALL 1ST FL
SOUTH WING
POST-CLEAN

NORTH STAIRS - 1ST FLOOR
POST-CLEAN

1ST FL CENTRAL STAIRS
POST-CLEAN

WINDOW SILL SOUTH
STAIRS 1ST FL
POST-CLEAN

SCUDR 2042292-COKEV 04/22/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>VENDING MACHINE</u>
SCUDR 2042292-VF 04/22/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>VENDING MACHINE</u>
SCUDR 2042292-CANDY 04/22/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>VENDING MACHINE</u>
SCUDR 2642192-PATIO 04/23/92 WIPE 0.4 as 1260 (4 @ (15 cm X 15 cm))	<u>PATIO</u> 1ST POST-CLEAN
SCUDR 205592-P1 05/05/92 WIPE 0.2 as 1260 (1 @ (30 cm X 30 cm))	<u>PATIO</u> - 1ST POST-CLEAN (CONFIRMATION SAMPLE)
SCUDR 205592-P2 05/05/92 WIPE 0.3 as 1260 (1 @ (30 cm X 30 cm))	<u>PATIO</u> - 1ST POST-CLEAN (CONFIRMATION SAMPLE)
SCUDR 205592-P3 05/05/92 WIPE 0.2 as 1260 (1 @ (30 cm X 30 cm))	<u>PATIO</u> - 1ST POST-CLEAN (CONFIRMATION SAMPLE)
SCUDR 205592-P4 05/05/92 WIPE 4.5 as 1260 (1 @ (30 cm X 30 cm))	<u>PATIO</u> - 1ST POST-CLEAN (CONFIRMATION SAMPLE)
SCUDR 205892 PA 05/08/92 WIPE ND (1 @ (30 cm X 30 cm))	WEST CORNER OF <u>PATIO</u> 2ND POST-CLEAN
SCUDR 205892 CA 05/08/92 WIPE ND (1 @ (30 cm X 30 cm))	COMPUTER KEYBOARD POST-CLEAN
SCUDR 2051292-PIANO 5/12/92 WIPE 1.3 as 1260 (1 @ (30 cm X 30 cm))	PIANO PRE-CLEAN
SCUDR 2021892-201 02/18/92 WIPE 0.3 as 1260 (4 @ (15 cm X 15 cm))	<u>ROOM 201</u> 1)RIGHT DESK; 2)LEFT DESK 3)LEFT DRESSER; 4)RIGHT DRESSER

SCUDR 2022892-201A 02/28/92 WIPE 0.2 as 1260
(1 @ (30 cm X 30 cm))

ROOM 201

RIGHT DRESSER

(CONFIRMATION SAMPLE)

SCUDR 2022892-201B 02/28/92 WIPE 0.3 as 1260
(1 @ (30 cm X 30 cm))

ROOM 201

RIGHT DESK

(CONFIRMATION SAMPLE)

SCUDR 2022892-201C 02/28/92 WIPE 0.4 as 1260
(1 @ (30 cm X 30 cm))

ROOM 201

LEFT DESK

(CONFIRMATION SAMPLE)

SCUDR 2022892-201D 02/28/92 WIPE 0.2 as 1260
(1 @ (30 cm X 30 cm))

ROOM 201

LEFT DRESSER

(CONFIRMATION SAMPLE)

SCUDR 2021892-202 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

ROOM 202

1)RIGHT DRESSER; 2)RIGHT
DESK; 3)LEFT DESK; 4)DRES-
SER ON LEFT

SCUDR 2021092203 02/10/92 WIPE ND
(4 @ (15 cm X 15 cm))

ROOM 203

1)RT DESK 2)LEFT DESK
3)BOOKCASE IN MIDDLE
OF RM 4)RT DRESSER

SCUDR 2021092204 02/10/92 WIPE ND
(4 @ (15 cm X 15 cm))

ROOM 204

1)RT DESK 2)LEFT DESK
3)WINDOW SILL 4)DRESSER
ON LEFT

SCUDR 2021892-205 02/18/92 WIPE 0.1 as 1260
(4 @ (15 cm X 15 cm))

ROOM 205

1)MIDDLE DESK; 2)RIGHT DESK
3)LEFT DRESSER; 4)RIGHT
DRESSER

SCUDR 2021892-206 02/18/92 WIPE 0.2 as 1260
(4 @ (15 cm X 15 cm))

ROOM 206

1)RIGHT DESK; 2)LEFT DESK
3)RIGHT DRESSER; 4)LEFT
DRESSER

SCUDR 2021892-207 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

ROOM 207

1)LEFT DESK; 2)LEFT DRESSER
3)RIGHT DRESSER; 4)RIGHT
DESK

SCUDR 2021892-208 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

ROOM 208

1)LEFT DESK; 2)RIGHT DRESSER
3)LEFT TABLE; 4)DRESSER ON
FAR RIGHT CORNER

SCUDR 2021892-209 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

ROOM 209

1)DESK IN MIDDLE FAR WALL
2)LEFT DESK; 3)LEFT DRESSER
4)RIGHT DRESSER

SCUDR 2021892-210 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

ROOM 210

1)LEFT FRIDGE; 2)LEFT
DRESSER; 3)DESK ON FAR
WALL; 4)DESK ON LEFT
CORNER

SCUDR 2021892-211 02/18/92 WIPE 0.1 as 1260
(4 @ (15 cm X 15 cm))

ROOM 211

1)RIGHT DESK; 2)LEFT DESK
3)LEFT DRESSER; 4)RIGHT
DRESSER

SCUDR 2021892-212 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

ROOM 212

1)LEFT DESK; 2)DESK ON FAR
WALL; 3)FRIDGE ON RIGHT
4)RIGHT DRESSER

SCUDR 2021892-213 02/18/92 WIPE ND

(4 @ (15 cm X 15 cm))

ROOM 213

1)LEFT DESK; 2)RIGHT DESK
3)PRINTER IN MIDDLE OF ROOM
4)LEFT DRESSER

SCUDR 2021092214 02/10/92 WIPE 0.2 as 1260

(4 @ (15 cm X 15 cm))

ROOM 214

1)LEFT DESK; 2)RIGHT DESK
3)WINDOW SILL; 4)MIDDLE
DRESSER

SCUDR 2021092215 02/10/92 WIPE ND

(4 @ (15 cm X 15 cm))

ROOM 215

1)LEFT DESK 2)MIDDLE
DESK 3)WINDOW SILL
4)RT DRESSER

SCUDR 2021092216 02/10/92 WIPE 0.1 as 1260

(4 @ (15 cm X 15 cm))

ROOM 216

1)RT DESK 2)LEFT DESK
3)MIDDLE DRESSER
4)WINDOW SILL

SCUDR 2021892-217 02/18/92 WIPE ND

(4 @ (15 cm X 15 cm))

ROOM 217

1)LEFT DESK; 2)LEFT DRESSER
3)RIGHT DESK; 4)RIGHT DESK

SCUDR 2021092218 02/10/92 WIPE ND

(4 @ (15 cm X 15 cm))

ROOM 218

1)RT DESK 2)LEFT DESK
3)WINDOW SILL 4)MIDDLE
DRESSER

SCUDR 2021892-219 02/18/92 WIPE ND

(4 @ (15 cm X 15 cm))

ROOM 219

1)LEFT DESK; 2)LEFT FRIDGE
3)RIGHT DESK; 4)RIGHT
DRESSER

SCUDR 2021892-220 02/18/92 WIPE ND

(4 @ (15 cm X 15 cm))

ROOM 220

1)RIGHT DESK; 2)LEFT DESK;
3)RIGHT DRESSER; 4)LEFT
DRESSER

SCUDR 2021892-221 02/18/92 WIPE 0.1 as 1260

(4 @ (15 cm X 15 cm))

ROOM 221

1)LEFT DESK (1ST); 2)LEFT
DESK (2ND); 3)RIGHT DRESSER
4)LEFT DRESSER

SCUDR 2021892-222 02/18/92 WIPE 0.1 as 1260

(4 @ (15 cm X 15 cm))

ROOM 222

1)RIGHT DESK; 2)COOLER ON
RIGHT; 3)FRIDGE ON LEFT;
4)LEFT DESK

SCUDR 2021892-223 02/18/92 WIPE ND

(4 @ (15 cm X 15 cm))

ROOM 223

1)NIGHT TABLE (RIGHT);
2)LEFT DESK; 3)1ST DRESSER
ON LEFT WALL; 4)2ND DRESSER
ON LEFT WALL

SCUDR 2021892-224 02/18/92 WIPE ND

(4 @ (15 cm X 15 cm))

ROOM 224

1)LEFT DESK; 2)RIGHT DESK;
3)LEFT DRESSER; 4)RIGHT
DRESSER

SCUDR 2021892-225 02/18/92 WIPE ND

(4 @ (15 cm X 15 cm))

ROOM 225

1)LEFT DESK; 2)RIGHT DESK
3)FRIDGE ON RIGHT; 4)LEFT
DRESSER

SCUDR 2021892-226 02/18/92 WIPE 0.2 as 1260

(4 @ (15 cm X 15 cm))

ROOM 226

1)DESK ON RIGHT; 2)DRESSER
ON RIGHT; 3)FRIDGE ON LEFT
4)WINDOW SILL (RIGHT)

SCUDR 2021892-227 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021892-228 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021092229 02/10/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021092230 02/10/92 WIPE 0.1 as 1260
(4 @ (15 cm X 15 cm))

SCUDR 2021892-231 02/18/92 WIPE 0.6 as 1260
(4 @ (15 cm X 15 cm))

SCUDR 2022892-231A 02/28/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2022892-231B 02/28/92 WIPE 0.1 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2022892-231C 02/28/92 WIPE ND
(1 @ (30 cm X 30 cm))

ROOM 227

1)DRAWING BOARD ON LEFT
2)DRESSER ON LEFT; 3)RIGHT
FRIDGE; 4)RIGHT DESK

ROOM 228

1)DESK ON LEFT; 2)STEREO
SYSTEM ON LEFT; 3)FRIDGE
ON RIGHT; 4)DRESSER ON
RIGHT

ROOM 229

1)RT DESK 2)LEFT DESK
3)DRESSER ON RT
4)WINDOW SILL

ROOM 230

1)RT DESK 2)LEFT DESK
3)WINDOW SILL 4)LEFT
DRESSER

ROOM 231

1)WINDOW SILL (LEFT);
2)DESK IN MIDDLE OF ROOM;
3)DESK ON RIGHT OF DOOR;
4)DRESSER ON LEFT

ROOM 231

RIGHT DESK
(CONFIRMATION SAMPLE)

ROOM 231

RIGHT DRESSER
(CONFIRMATION SAMPLE)

ROOM 231

DESK (CONFIRMATION SAMPLE)

SCUDR 2022892-231D 02/28/92 WIPE 0.4 as 1260 (1 @ (30 cm X 30 cm))	<u>ROOM 231</u> LEFT DRESSER (CONFIRMATION SAMPLE)
SCUDR 203C1692 01/06/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>SRN05-2ND FLOOR</u>
SCUDR 202A1792 01/07/92 WIPE 0.2 as 1260 (1 @ (30 cm X 30 cm))	<u>SRN05-2ND FLOOR</u>
SCUDR 2042192-SRN06 04/21/92 WIPE 1.4 as 1260 (4 @ (15 cm X 15 cm))	<u>BATH SRN06 - 2ND FLOOR</u> 1ST POST-CLEAN
SCUDR 2043092-SRN06A 04/30/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>SRN06 TOILET 2ND FL</u> 2ND POST-CLEAN
SCUDR 2043092-SRN06B 04/30/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>SRN06 TOILET 2ND FL</u> 2ND POST-CLEAN
SCUDR 2043092-SRN06C 04/30/92 WIPE ND @ (30 cm X 30 cm))	<u>SRN06 TOILET 2ND FL</u> 2ND POST-CLEAN
SCUDR 2043092-SRN06D 04/30/92 WIPE ND (1 @ (30 cm X 30 cm))	<u>SRN06 TOILET 2ND FL</u> 2ND POST-CLEAN
SCUDR 2021892-REC4 02/18/92 WIPE 0.2 as 1260 (4 @ (15 cm X 15 cm))	<u>REC. RM 4 - 2ND FLOOR</u>
SCUDR 2021892-REC2 2/18/92 WIPE 0.4 as 1260 (4 @ (15 cm X 15 cm))	<u>REC2 2ND FL</u> (KIT IN REC4 ON NEW MAP)
SCUDR 2043092-KITREC4A 04/30/92 ND (1 @ (30 cm X 30 cm))	<u>KIT. IN REC4 COUNTER</u> SAME ROOM AS REC2 POST-CLEAN (CONFIRMATION SAMPLE)

SCUDR 2043092-KITREC4B 04/30/92 ND

(1 @ (30 cm S 30 cm))

KIT. IN REC4 SILL

SAME ROOM AS REC4

POST-CLEAN

(CONFIRMATION SAMPLE)

SCUDR 2043092-STOR216 04/30/92 WIPE ND

(1 @ (30 cm X 30 cm))

2ND FL STORAGE NEAR

216; WALL

POST-CLEAN

SCUDR 2043092-STORREC4 04/30/92 WIPE ND

(1 @ (30 cm X 30 cm))

STORAGE IN REC4; WALL

2ND FL; POST-CLEAN

SCUDR 2043092-JC231 04/30/92 WIPE ND

(1 @ (30 cm X 30 cm))

JC ACROSS FROM 231

4TH SHELF UP

POST-CLEAN

SCUDR 2043092-JCSRNO6 04/30/92 WIPE ND

(1 @ (30 cm X 30 cm))

2ND FL JC NEXT TO SRNO6

4TH SHELF UP

POST-CLEAN

SCUDR 2043092-JC216 04/30/92 WIPE ND

(1 @ (30 cm X 30 cm))

2ND FL JC ACROSS 216

4TH SHELF UP

POST-CLEAN

SCUDR 2043092-JCST2 04/30/92 WIPE ND

(1 @ (30 cm X 30 cm))

JC IN STAIR 2 LOBBY

SHELF; POST-CLEAN

SCUDR 2043092-JCREC4 04/30/92 ND

(1 @ (30 cm X 30 cm))

JC IN REC 4 2ND FL

POST-CLEAN

SCUDR 2043092-JCREC4A 04/30/92 ND

(1 @ (30 cm X 30 cm))

JC IN REC4, LEFT SHELF

POST-CLEAN 2ND FL

SCUDR 2043092-JCSRNO5 04/30/92 ND

(1 @ (30 cm X 30 cm))

JC IN SRNO5, SHELF

POST-CLEAN 2ND FL

SCUDR 2043092-JC201 04/30/92 ND

(1 @ (30 cm X 30 cm))

JC NEAR 201, SHELF

POST-CLEAN

SCUDR 205692 L2A 05/06/92 WIPE ND
(1 @ (30 cm X 30 cm))
SCUDR 205692 L2B 05/06/92 WIPE ND
(1 @ (30 cm X 30 cm))
SCUDR 205692 L2C 05/06/92 WIPE 0.1 as 1260
(1 @ (30 cm X 30 cm))

2ND FL LOBBY WALL
POST-CLEAN
2ND FL LOBBY WINDOWSILL
POST-CLEAN
2ND FL LOBBY FLOOR
POST-CLEAN

SCUDR 2-1 12/31/91 WIPE 20 as 1260
(1 @ (10 cm X 10 cm))
SCUDR SWS-10 01/01/92 WIPE ND as 1260
(1 @ (10 cm X 10 cm))
SCUDR SWS-11 01/01/92 WIPE ND as 1260
(1 @ (10 cm X 10 cm))

HALL NEAR SRN06 - 2ND FL
PRE-CLEAN
HALLWAY OUTSIDE RM 201-
LIGHT FIXTURE PRE-CLEAN
HALLWAY FIRE ALARM
NEXT TO ROOM 229
PRE-CLEAN

SCUDR 202C1692 01/06/92 WIPE 15 as 1260
(1 @ (30 cm X 30 cm))

2ND FLOOR HALLWAY-LIGHT
FIXTURE PRE-CLEAN

SCUDR 203A1692 01/06/92 WIPE ND
(1 @ (30 cm X 30 cm))

HALLWAY OUTSIDE SRN05
2ND FLOOR PRE-CLEAN

SCUDR 2042192-HS225F 04/21/92 WIPE ND
(1 @ (30 cm X 30 cm))

HALL FLOOR IN FRONT OF 225
POST-CLEAN

SCUDR 2042292-HS2W 04/22/92 WIPE ND
(1 @ (30 cm X 30 cm))

2ND FL WALL SOUTH
POST-CLEAN

SCUDR 2042192-2N209W 04/21/92 WIPE ND
(1 @ (30 cm X 30 cm))

HALL NEAR 209 WALL
POST-CLEAN

SCUDR 2042192-HN205F 04/21/92 WIPE ND
(1 @ (30 cm X 30 cm))

NORTH HALL FLOOR IN
FRONT OF 205

POST-CLEAN

SCUDR 2042292-HN2W 04/22/92 WIPE ND
(1 @ (30 cm X 30 cm))

2ND FL WALL NORTH
POST-CLEAN

SCUDR 2042192-2SS 04/21/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2042192-2SC 04/21/92 WIPE 0.2 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2042192-2SN 04/21/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2021092301 02/10/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021092302 02/10/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021892-303 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021892-304 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021892-305 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021892-306 02/18/92 WIPE 0.1 as 1260
(4 @ (15 cm X 15 cm))

SOUTH STAIRS - 2ND FLOOR
POST CLEAN

CENTRAL STAIRS 2ND FL
POST CLEAN

NORTH HALL - STAIRS
POST CLEAN

ROOM 301

1)RT DESK 2)MIDDLE DESK
3)WINDOW SILL 4)LEFT DRESSER

ROOM 302

1)LEFT DESK 2)MIDDLE DESK
3)WINDOW SILL 4)FRIDGE ON
LEFT

ROOM 303

1)RIGHT DRESSER; 2)LEFT
DESK; 3)WINDOW SILL;
4)RIGHT DESK

ROOM 304

1)LEFT DESK; 2)RIGHT DESK;
3)LEFT DRESSER; 4)RIGHT
DRESSER

ROOM 305

1)LEFT DESK; 2)RIGHT DESK;
3)LEFT DRESSER; 4)RIGHT
DRESSER

ROOM 306

1)LEFT DESK; 2)RIGHT DESK;
3)LEFT DRESSER; 4)RIGHT
DRESSER

SCUDR 2021892-307 02/18/92 WIPE 0.4 as 1260
(4 @ (15 cm X 15 cm))

ROOM 307

1)LEFT DESK; 2)RIGHT DESK
3)LEFT DRESSER; 4)RIGHT
DRESSER

SCUDR 2022892-307A 02/28/92 WIPE 0.8 as 1260
(1 @ (30 cm X 30 cm))

ROOM 307 RIGHT DRESSER
(CONFIRMATION SAMPLE)

SCUDR 2022892-307B 02/28/92 WIPE 0.7 as 1260
(1 @ (30 cm X 30 cm))

ROOM 307 RIGHT DESK
(CONFIRMATION SAMPLE)

SCUDR 2022892-307C 02/28/92 WIPE 0.8 as 1260
(1 @ (30 cm X 30 cm))

ROOM 307 LEFT DESK
(CONFIRMATION SAMPLE)

SCUDR 2022892-307D 02/28/92 WIPE 0.7 as 1260
(1 @ (30 cm X 30 cm))

ROOM 307 LEFT DRESSER
(CONFIRMATION SAMPLE)

SCUDR 2021892-308 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

ROOM 308

1)LEFT DESK; 2)1ST RIGHT
DRESSER; 3)2ND RIGHT DRESSER
4)NIGHTSTAND ON RIGHT

SCUDR 2021892-309 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

ROOM 309**

1)LEFT DESK; 2)RIGHT DESK
3)LEFT DRESSER; 4)RIGHT
DRESSER

SCUDR 2021892-310 02/18/92 WIPE 0.1 as 1260
(4 @ (15 cm X 15 cm))

ROOM 310

1)RIGHT DESK; 2)LEFT DESK
3)LEFT DRESSER; 4)RIGHT
DESK

SCUDR 2021892-311 02/18/92 WIPE 0.1 as 1260
(4 @ (15 cm X 15 cm))

ROOM 311

1)FRIDGE ON RIGHT; 2)DESK
LEFT; 3)DRESSER ON LEFT;
4)DESK ON FAR RIGHT CORNER

SCUDR 2021892-312 02/18/92 WIPE 0.1 as 1254
(4 @ (15 cm X 15 cm))

SCUDR 2021892-313 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021092314 02/10/92 WIPE 0.1 as 1260
(4 @ (15 cm X 15 cm))

SCUDR 2021092-315 02/10/92 WIPE 0.1 as 1260
(4 @ (15 cm X 15 cm))

SCUDR 2021092-316 02/10/92 WIPE 0.4 as 1260
(4 @ (15 cm X 15 cm))

SCUDR 2022892-316A 02/28/92 WIPE 0.6 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2022892-316B 02/28/92 WIPE 0.4 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2022892-316C 02/28/92 WIPE 0.4 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2022892-316D 02/28/92 WIPE 0.5 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2021892-317 02/18/92 WIPE 0.3 as 1260
(4 @ (15 cm X 15 cm))

ROOM 312

1)LEFT DESK; 2)LEFT DRESSER
3)RIGHT DESK; 4)FRIDGE ON
FAR RIGHT CORNER

ROOM 313

1)DESK, FAR LEFT CORNER
2)DESK ON RT 3)DRESSER
ON LEFT 4)DRESSER ON RT

ROOM 314

1)RT DESK 2)LEFT DESK
3)WINDOW SILL 4)CHEST
IN LEFT CORNER

ROOM 315

1)RT DESK 2)MIDDLE
DESK 3)WINDOW SILL
4)DRESSER ON LEFT

ROOM 316

1)RT DESK 2)MIDDLE DESK
3)WINDOW SILL 4)CHEST
ON LEFT

ROOM 316 LEFT DRESSER
(CONFIRMATION SAMPLE)

ROOM 316 LEFT DESK
(CONFIRMATION SAMPLE)

ROOM 316 REFRIG. LEFT
(CONFIRMATION SAMPLE)

ROOM 316 RIGHT DESK
(CONFIRMATION SAMPLE)

ROOM 317

1)DESK ON FAR LEFT WALL

SCUDR 2022892-317A 02/28/92 WIPE 0.3 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2022892-317B 02/28/92 WIPE 0.4 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2022892-317C 02/28/92 WIPE 0.2 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2022892-317D 02/28/92 WIPE 0.4 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2021092-318 02/10/92 WIPE 0.2 as 1260
(4 @ (15 cm X 15 cm))

SCUDR 2021892-319 02/18/92 WIPE 0.1 as 1260
(4 @ (15 cm X 15 cm))

SCUDR 2021892-320 02/18/92 WIPE 0.3 as 1260
(4 @ (15 cm X 15 cm))

SCUDR 2022892-320A 02/28/92 WIPE 0.4 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2022892-320B 02/28/92 WIPE 0.5 as 1260
(1 @ (30 cm X 30 cm))

2)DESK ON FAR RT WALL

3)DRESSER ON LEFT

4)DRESSER ON RT

ROOM 317 LEFT DRESSER
(CONFIRMATION SAMPLE)

ROOM 317 LEFT DESK
(CONFIRMATION SAMPLE)

ROOM 317 RIGHT DESK
(CONFIRMATION SAMPLE)

ROOM 317 RIGHT DRESSER
(CONFIRMATION SAMPLE)

ROOM 318

1)RT DESK 2)LEFT DESK

3)WINDOW SILL 4)STEREO
CABINET ON RT

ROOM 319

1)DRESSER ON RT

2)DESK ON LEFT

3)DESK ON RT

4)FRIDGE ON LEFT

ROOM 320

1)DESK ON LEFT FAR WALL

2)DESK ON RT FAR WALL

3)DRESSER ON LEFT

4)DRESSER ON RT

ROOM 320 LEFT DRESSER
(CONFIRMATION SAMPLE)

ROOM 320 LEFT DESK
(CONFIRMATION SAMPLE)

SCUDR 2022892-320C 02/28/92 WIPE 0.5 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2022892-320D 02/28/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2021892-321 02/18/92 WIPE 0.3 as 1260
(4 @ (15 cm X 15 cm))

SCUDR 2022892-321A 02/28/92 WIPE 0.6 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2022892-321B 02/28/92 WIPE 0.5 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2022892-321C 02/28/92 WIPE 0.5 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2022892-321D 02/28/92 WIPE 0.2 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2021892-322 02/18/92 WIPE 0.5 as 1260
(4 @ (15 cm X 15 cm))

SCUDR 2022892-322A 02/28/92 WIPE 0.3 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2022892-322B 02/28/92 WIPE 0.7 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2022892-322C 02/28/92 WIPE 0.2 as 1260
(1 @ (30 cm X 30 cm))

ROOM 320 RIGHT DESK
(CONFIRMATION SAMPLE)

ROOM 320 RIGHT DRESSER
(CONFIRMATION SAMPLE)

ROOM 321
1) DESK (LEFT)
2) DESK (RT)
3) DRESSER (LEFT)
4) DRESSER (RT)

ROOM 321 LEFT DRESSER
(CONFIRMATION SAMPLE)

ROOM 321 LEFT DESK
(CONFIRMATION SAMPLE)

ROOM 321 RIGHT DESK
(CONFIRMATION SAMPLE)

ROOM 321 RIGHT DRESSER
(CONFIRMATION SAMPLE)

ROOM 322
1) DESK ON LEFT FAR WALL
2) DESK ON RT FAR WALL
3) DRESSER ON LEFT
4) DRESSER ON
RT

ROOM 322 LEFT DRESSER
(CONFIRMATION SAMPLE)

ROOM 322 LEFT DESK
(CONFIRMATION SAMPLE)

ROOM 322 RIGHT DESK
(CONFIRMATION SAMPLE)

SCUDR 2022892-322D 02/28/92 WIPE 0.4 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2021892-323 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021892-324 02/18/92 WIPE 0.2 as 1260
(4 @ (15 cm X 15 cm))

SCUDR 2021892-325 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021892-326 02/18/92 WIPE 0.1 as 1260
(4 @ (15 cm X 15 cm))

SCUDR 2021892-327 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021892-328 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

ROOM 322 RIGHT DRESSER
(CONFIRMATION SAMPLE)

ROOM 323

- 1) DESK ON RT 2) 1ST DRESSER ON LEFT
- 3) 2ND DRESSER ON LEFT
- 4) FRIDGE ON LEFT

ROOM 324

- 1) DESK ON LEFT 2) DESK ON RT 3) FRIDGE ON LEFT
- 4) DRESSER ON FAR WALL

ROOM 325

- 1) DESK ON LEFT 2) DESK ON RT 3) DRESSER ON LEFT
- 4) FRIDGE ON MIDDLE OF FAR WALL

ROOM 326

- 1) DESK ON LEFT
- 2) DESK ON RT
- 3) DRESSER ON LEFT
- 4) DRESSER ON RT

ROOM 327

- 1) FRIDGE ON LEFT
- 2) DRESSER ON RT
- 3) DESK ON FAR RT WALL
- 4) DESK ON FAR LEFT WALL

ROOM 328

- 1) DESK ON LEFT
- 2) DESK ON RT

UDR 2021092-329 02/10/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021892-330 02/18/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021092-331 02/10/92 WIPE 0.2 as 1260
(4 @ (15 cm X 15 cm))

SCUDR 204C1692 01/06/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 204A1692 01/06/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 203A1792 01/07/92 WIPE 5.6 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2042192-SRN07 04/21/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2042192-SRN08 04/21/92 WIPE ND
(4 @ (15 cm X 15 cm))

SCUDR 2021892-REC5 02/18/92 WIPE 0.4 as 1260
(4 @ (15 cm X 15 cm))

3)DRESSER ON LEFT

4)DRESSER ON RT

ROOM 329

1)RT DESK 2)LEFT DESK

3)WINDOW SILL 4)CHEST
ON RT

ROOM 330

1)FRIDGE ON RT 2)DRESSER
ON LEFT 3)DESK ON FAR WALL
LEFT 4)DRESSER ON FAR RT
WALL

ROOM 331

1)RT DESK 2)LEFT DESK
3)WINDOW SILL 4)TOP
OF BOOKCASE ON LEFT

SRN07-3RD FLOOR

SRN07-3RD FLOOR

SRN07-3RD FLOOR

PRE-CLEAN

SRN07

POST-CLEAN

SRN08

POST-CLEAN

REC. RM 5 3RD FL

1)CIRCULAR TABLE IN MIDDLE

SCUDR 2043092-REC5A 04/30/92 WIPE 0.5 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2043092-REC5B 04/30/92 WIPE 0.4 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2043092-REC5C 04/30/92 WIPE 0.1 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2043092-REC5D 04/30/92 WIPE 0.3 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2043092-REC3A 04/30/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2043092-REC3B 04/30/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2021892-REKN3 2/18/92 WIPE 0.5 AS 1260
(4 @ (15 cm X 15 cm))

2)TV SET 3)SMALL SQUARE
TABLE IN FRONT OF COUCHES
4)SM SQUARE TABLE IN FRONT
OF COUCHES

POST-CLEAN

3RD FL REC5 MIDDLE SILL
(CONFIRMATION SAMPLE)

POST-CLEAN

3RD FL REC5 LEFT SILL
(CONFIRMATION SAMPLE)

POST-CLEAN

3RD FL REC5 RT SILL
(CONFIRMATION SAMPLE)

POST-CLEAN

3RD FL REC5 RT SILL
ON LEFT

(CONFIRMATION SAMPLE)

POST-CLEAN

3RD FL REC3 4TH SHELF
UP; POST-CLEAN

3RD FL REC3 CENTER
4TH SHELF UP

POST-CLEAN

REKN3 3RD FL

REC 5 KITCHEN ON NEW MAP

1)WINDOW SILL ON RT

2)KITCHEN COUNTER ON RT

3)SINK 4)STOVE TOP

SCUDR 2043092-RECK1 04/30/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2043092-RECK2 04/30/92 WIPE 0.1 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2042192-STCR11 04/21/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2042192-STOR10 04/21/92 WIPE ND

SCUDR 2042192-JC10 04/21/92 WIPE ND
(1 @ (30 cm x 30 cm))

SCUDR 2042192-JC11 04/21/92 WIPE 0.4 as 1260
(1 @ (30 cm X 30 cm))

SCUDR 2043092-JC318 04/30/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2043092-JCSRNO8 04/30/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2043092-JC302 04/30/92 WIPE ND
(1 @ 30 cm X 30 cm))

SCUDR 2043092-JCSRNO7 04/30/92 WIPE ND
(1 @ (30 cm X 30 cm))

SCUDR 2043092-JC331 04/30/92 WIPE ND
(1 @ (30 cm X 30 cm))

KITCHEN IN REC5-3RD FLOOR

COUNTER

POST-CLEAN

(CONFIRMATION SAMPLE)

KITCHEN IN REC5-3RD FLOOR

SILL

POST-CLEAN

(CONFIRMATION SAMPLE)

POST-CLEAN STOR11

3RD FL

POST-CLEAN STOR10

3RD FL

POST-CLEAN JC10

3RD FL

POST-CLEAN JC11

3RD FL

JC NEAR 318 SHELF

POST-CLEAN

JC NEAR SRNO8 SHELF

POST-CLEAN

3RD FL JC NEAR 302

POST-CLEAN

3RD FL JC NEXT TO SRNO7

POST-CLEAN

JC ACROSS 331; 5TH SHELF

POST-CLEAN

SCUDR 205692 L3A 05/06/92 WIPE ND

(1 @ (30 cm X 30 cm))

SCUDR 205692 L3B 05/06/92 WIPE 0.2 as 1260

(1 @ (30 cm X 30 cm))

SCUDR 205692 L3C 05/06/92 WIPE ND

(1 @ (30 cm X 30 cm))

3RD FL LOBBY WALL

POST-CLEAN

3RD FL LOBBY WINDOWSILL

POST-CLEAN

3RD FL LOBBY FLOOR

POST-CLEAN

SCUDR 3-1 12/31/91 WIPE 52 as 1260

(1 @ (10 cm X 10 cm))

SCUDR SWS-15 01/01/92 WIPE ND

(1 @ (10 cm X 10 cm))

SCUDR SWS-16 01/01/92 WIPE ND

(1 @ (10 cm X 10 cm))

SCUDR 2042192-HN308F 04/21/92 WIPE ND

(1 @ (30 cm X 30 cm))

SCUDR 2042192-HN310W 04/21/92 WIPE ND

(1 @ (30 cm X 30 cm))

HALLWAY OUTSIDE SRN07

PRE-CLEAN

HALLWAY-LIGHT FIXTURE NEXT

TO ROOM 301 PRE-CLEAN

HALLWAY-FIRE ALARM NEXT TO

ROOM 329 PRE-CLEAN

HALLWAY FLOOR BY 308

POST-CLEAN

HALL NORTH WALL

POST-CLEAN

NEAR RM 310

HALLWAY FLOOR BY 321

POST-CLEAN

HALL NEAR RM 325 WALL

POST-CLEAN

HALLWAY FLOOR

POST-CLEAN

OUTSIDE RM 321

HALLWAY FLOOR

POST-CLEAN

BETWEEN RM 317-319

SCUDR 2042192-HS321F 04/21/92 WIPE ND

(1 @ (30 cm X 30 cm))

SCUDR 2042192-HS325W 04/21/92 WIPE ND

(1 @ (30 cm X 30 cm))

SCUDR 2042292-HS3F 04/22/92 WIPE ND

(1 @ (30 cm X 30 cm))

SCUDR 2042492-HS3F 04/24/92 WIPE ND

(1 @ (30 cm X 30 cm))

SCUDR 2042492-HS3W 04/24/92 WIPE ND

(1 @ (30 cm X 30 cm))

HALLWAY WALL

POST-CLEAN

BETWEEN 324-325

SCUDR 2042192-3SN 04/21/92 WIPE ND

(1 @ (30 cm X 30 cm))

3RD FL NORTH STAIRS

POST CLEAN

SCUDR 2042192-3SC 04/21/92 WIPE ND

(1 @ (30 cm X 30 cm))

CENTRAL STAIRS 3RD FL

POST CLEAN

SCUDR 2042192-3SS 04/21/92 WIPE ND

(1 @ (30 cm X 30 cm))

SOUTH STAIRS 3RD FL

POST CLEAN

SCUDR 2042292-W8 04/23/92 WIPE 0.5 as 1260

** ID# ON CHAIN OF CUSTODY WRITTEN "309"; ID# ON SUMMARY WRITTEN "319";

CHAIN OF CUSTODY IS CORRECT

VENT SAMPLES (ug/100 sq cm)

LOCATION	ID #	DATE	TYPE	RESULT	COMMENTS
SCUDR	2042492-LAUN2	04/24/92	WIPE	0.3 as 1260	VENT LAUNDRY RM SOUTH
	(1 @ 900 sq cm)				SIDE BASEMENT
SCUDR	204292-SRN02	04/24/92	WIPE	0.3 as 1260	VENT IN BATHRM BASEMENT
	(1 @ 900 sq cm)				
SCUDR	2042292-STOR7	VENT			
		04/23/92	WIPE	3.7 as 1260	STOR7 VENT
	(1 @ 900 sq cm)				
SCUDR	2032692-L1	03/27/92	WIPE	0.3 as 1260	<u>LAUNDRY RM #1</u>
	(1 @ 900 sq cm)				
SCUDR	2032692-FH	03/26/92	WIPE	3.4 as 1260	<u>F HELP</u> *JANITOR'S LOCKER
	(1 @ 900 sq cm)				RM ON NEW MAP*
SCUDR	2032692-BTH	03/27/92	WIPE	0.7 as 1260	<u>BATH SRN01</u> (LISTED AS
	(1 @ 900 sq cm)				BATH SRNEL ON COC)
SCUDR	2042292-CHNY	04/23/92	WIPE	0.3 as 1260	CHIMNEY
	(1 @ 900 sq cm)				
SCUDR	2042292-RV1	04/23/92	WIPE	2.4 as 1260	ROOF VENT #1
	(1 @ 900 sq cm)				
SCUDR	2042292-RV2	04/23/92	WIPE	0.6 as 1260	ROOF VENT #2
	(1 @ 900 sq cm)				
SCUDR	2042292-RV3	04/23/92	WIPE	1.9 as 1260	ROOF VENT #3
	(1 @ 900 sq cm)				
SCUDR	2042292-RV4	04/23/92	WIPE	0.7 as 1260	ROOF VENT #4
	(1 @ 900 sq cm)				

SCUDR 2042292-RV5 04/23/92 WIPE 1.2 as 1260 ROOF VENT #5

(1 @ 900 sq cm)

UDR 2042292-RV6 04/23/92 WIPE 14 as 1260 ROOF VENT #6

(1 @ 900 sq cm)

SCUDR 2032692-LSR 03/27/92 WIPE 5.6 as 1260 LIN SR (RECYCLING RM)

(1 @ 900 sq cm)

SCUDDER DIOXIN/FURAN SAMPLES (ng/m2)

LOCATION	ID #	DATE	TYPE	RESULT	COMMENTS
(E.T.C. ANALYSIS)					
20111192-10		01/11/92	WIPE	ND	RM 101 RT DESK CENTER
(1 @ (30 cm X 30 cm))					
20211191-11		01/11/92	WIPE	ND	RM 229 RT TABLE CENTER
(1 @ (30 cm X 30 cm))					
20311192-12		01/11/92	WIPE	ND	RM 314 TABLE IN CENTER
(1 @ (30 cm X 30 cm))					
(NEW YORK D.O.H. ANALYSIS)					
D-3			WIPE	230	VAULT AREA
20B12292D(F)		01/22/92	WIPE	ND	OUTSIDE VAULT ON WALL
● @ (30 cm X 30 cm))					
(The following results given are the total 2378-TCDD equivalence. The area sampled equalled 1 m2. Twin Cities Laboratories performed the analysis.)					
SCUDR	2021092-DB8	02/10/92	WIPE	.052	BASEMENT: ROOM B8
SCUDR	2021092-DB8	02/10/92	WIPE	.034	RESHOOT OF ABOVE SAMPLE
SCUDR	2021092-D125	02/10/92	WIPE	.053	1ST FLOOR: ROOM 125
SCUDR	2021092-D214	02/10/92	WIPE	.027	2ND FLOOR: ROOM 214
SCUDR	2021092-D214	02/10/92	WIPE	.028	RESHOOT OF ABOVE SAMPLE
SCUDR	2021092-D314	02/10/92	WIPE	.058	3RD FLOOR: ROOM 314
SCUDR	2021092-D2ND STAIR				
		02/10/92	WIPE	.031	2ND FLOOR STAIRCASE: WALL
SCUDR	2021092-D1ST STAIR				
		02/10/92	WIPE	.0081	1ST FLOOR STAIRCASE: WALL
SCUDR	2021092-D3RD STAIR				
		02/10/92	WIPE	.035	3RD FLOOR STAIR CASE: WALL

VAULT SAMPLES (ug/100 sq cm)

LOCATION	ID #	DATE	TYPE	RESULT	COMMENTS
SCUDR B-2 (1 @ (10 cm X 10cm))		12/31/91	WIPE	30,000 as 1260	HALLWAY OUTSIDE TRANSFORMER RM PRE-CLEAN
SCUDR 2031892 (1 @ (30 cm X 30 cm))		01/08/92	WIPE	9000 as 1260	TRANSFORMER VAULT
SCUDR 2032092-1 (9 @ (10 cm X 10 cm))		03/20/92	WIPE	220 as 1260	VAULT-POST-CLEAN WALL ACROSS FROM DOOR
SCUDR 2032092-2 (9 @ (10 cm X 10 cm))		03/20/92	WIPE	210 as 1260	VAULT-POST-CLEAN CEILING
SCUDR 2032092-3 (9 @ (10 cm X 10 cm))		03/20/92	WIPE	150 as 1260	VAULT-POST-CLEAN WALL WITH DOOR
SCUDR 2032092-4 (9 @ (10 cm X 10 cm))		03/20/92	WIPE	210 as 1260	VAULT-POST-CLEAN RIGHT WALL
SCUDR 2032092-5 (9 @ (10 cm X 10 cm))		03/20/92	WIPE	420 as 1260	VAULT-POST-CLEAN LEFT WALL
SCUDR 2032092-6 (9 @ (10 cm X 10 cm))		03/20/92	WIPE	4,300 as 1260	VAULT-POST-CLEAN FLOOR
SCUDR 2042892-VFL (9 @ (10 cm X 10 cm))		04/30/92	WIPE	1,400 as 1260	VAULT FLOOR
SCUDR 2042892-VCL (9 @ (10 cm X 10 cm))		04/30/92	WIPE	4.2 as 1260	VAULT CEILING
SCUDR 2042992-TOPB (9 @ (10 cm X 10 cm))		04/30/92	WIPE	64 as 1260	VAULT - TOP BEAM
SCUDR 2042992-LFTB (9 @ (10 cm X 10 cm))		04/30/92	WIPE	260 as 1260	VAULT - LEFT BEAM

SCUDR 2042992-FLRB 04/30/92 WIPE 240 as 1260

VAULT - FLOOR BEAM

(9 @ (10 cm X 10 cm))

SCUDR 2032092-C 03/20/92 WIPE 320 as 1260

WIPE OF COTTON BETWEEN
VAULT WALL AND OUTSIDE
WALL1

SCUDDER AIR SAMPLES

LOCATION	ID#	DATE	RESULT	COMMENTS
SCUDR	20BC1792	01/07/92	30 as 1260	BASEMENT
SCUDR	20B11292-3	01/12/92	0.43 as 1232	BASEMENT - OUTSIDE
			0.25 as 1260	VAULT
SCUDR	31292	03/12/92	0.37 as 1260	AREA OF VAULT
SCUDR	SCUDDER LOBBY	04/22/92	0.25 as 1254	SCUDDER LOBBY-BASEMENT
SCUDR	201C1792	01/07/92	0.27 as 1232	FIRST FLOOR
			2.4 as 1260	
SCUDR	31092	03/10/92	0.15 as 1254	SCUDDER LEVEL B/ KITCHEN 1ST FLOOR
SCUDR	015-31192	03/11/92	ND	SCUDDER LEVEL D/DECON
SCUDR	074-31192	03/11/92	0.80 as 1254	SCUDDER LEVEL C/ 1ST FLOOR
SCUDR	20-41092-1	04/10/92	0.41 as 1232	1ST FLOOR
			0.96 as 1260	
SCUDR	2043092-1	04/30/92	0.04 as 1242	SODA MACHINE ON 1ST FLOOR
			0.05 as 1254	
SCUDR	205192-1	05/01/92	0.05 as 1242	1ST FLOOR LOBBY
			0.45 as 1254	
SCUDR	2C1792	01/07/92	0.08 as 1260	SECOND FLOOR
SCUDR	204792-2	04/07/92	ND	2ND FLOOR
SCUDR	203C1792	01/07/92	2.6 as 1260	THIRD FLOOR
SCUDR	204792-3	04/07/92	ND	3RD FLOOR

SCUDDER AIR SAMPLES

LOCATION	ID#	DATE	RESULT	COMMENTS
SCUDR	20BC1792	01/07/92	30 as 1260	BASEMENT
SCUDR	20B11292-3	01/12/92	0.43 as 1232	BASEMENT - OUTSIDE
			0.25 as 1260	VAULT
SCUDR	31292	03/12/92	0.37 as 1260	AREA OF VAULT
SCUDR	SCUDDER LOBBY	04/22/92	0.25 as 1254	SCUDDER LOBBY-BASEMENT
SCUDR	201C1792	01/07/92	0.27 as 1232	FIRST FLOOR
			2.4 as 1260	
SCUDR	31092	03/10/92	0.15 as 1254	SCUDDER LEVEL B/ KITCHEN 1ST FLOOR
SCUDR	015-31192	03/11/92	ND	SCUDDER LEVEL D/DECON
SCUDR	074-31192	03/11/92	0.80 as 1254	SCUDDER LEVEL C/ 1ST FLOOR
SCUDR	20-41092-1	04/10/92	0.41 as 1232	1ST FLOOR
			0.96 as 1260	
SCUDR	2043092-1	04/30/92	0.04 as 1242	SODA MACHINE ON 1ST
			0.05 as 1254	FLOOR
SCUDR	205192-1	05/01/92	0.05 as 1242	1ST FLOOR LOBBY
			0.45 as 1254	
SCUDR	2C1792	01/07/92	0.08 as 1260	SECOND FLOOR
SCUDR	204792-2	04/07/92	ND	2ND FLOOR
SCUDR	203C1792	01/07/92	2.6 as 1260	THIRD FLOOR
SCUDR	204792-3	04/07/92	ND	3RD FLOOR

SCUDDER AIR SAMPLES

LOCATION	ID#	DATE	RESULT	COMMENTS
SCUDR	20801792	01/07/92	30 as 1260	BASEMENT
SCUDR	20811292-3	01/12/92	0.43 as 1232 0.25 as 1260	BASEMENT - OUTSIDE VAULT
SCUDR	31292	03/12/92	0.37 as 1260	AREA OF VAULT
SCUDR	SCUDDER LOBBY	04/22/92	0.25 as 1254	SCUDDER LOBBY-BASEMENT
SCUDR	20101792	01/07/92	0.27 as 1232 2.4 as 1260	FIRST FLOOR
SCUDR	31092	03/10/92	0.15 as 1254	SCUDDER LEVEL B/ KITCHEN 1ST FLOOR
SCUDR	015-31192	03/11/92	ND	SCUDDER LEVEL D/DECON
SCUDR	074-31192	03/11/92	0.80 as 1214	SCUDDER LEVEL C/ 1ST FLOOR
SCUDR	20-41092-1	04/10/92	0.41 as 1232 0.95 as 1230	1ST FLOOR
SCUDR	2043092-1	04/30/92	0.04 as 1242 0.05 as 1254	SODA MACHINE ON 1ST FLOOR
SCUDR	205192-1	05/01/92	0.05 as 1242 0.45 as 1254	1ST FLOOR LOBBY
SCUDR	201792	01/07/92	0.00 as 1260	SECOND FLOOR
SCUDR	204792-2	04/07/92	ND	2ND FLOOR
SCUDR	20301792	01/07/92	2.6 as 1260	THIRD FLOOR
SCUDR	204792-3	04/07/92	ND	3RD FLOOR