

APPENDICIES

Appendix 1 – Field Audit Notes

See attached CD

Appendix 2 – ASHRAE Audit Forms

See Attached CD

Appendix 3 – Cost Estimates

Project Name: **SUNY New Paltz**
 Project No.: **4013032.01**
 Calculated by: _____
 Checked by: _____

Sheet No: _____ **1** of _____ **1**
 Date: **14-Dec-15**
 Date: _____

Measure: ECM LNC2 Condenser Water Temperature Reset

Div.	Description	Qty.	Unit	Unit Labor	Cost Material	Total Labor	Total Material	Total	Ref.
	Implement Programing	6		\$1,500.00	\$0.00	\$9,000.00	\$0.00	\$9,000.00	Prior experience
	Subtotal					\$9,000.00	\$0.00	\$9,000.00	
	Contingency (10%)					\$900.00	\$0.00	\$900.00	
	Total					\$9,900.00	\$0.00	\$9,900.00	
	Asbestos Abatement					\$0.00	\$0.00		
	Bonds IDIC Add					\$0.00	\$0.00		
	Audit, Design, and Construction Management							\$1,287.00	
	NYPA Project Management							\$1,237.50	
	ECM Total (Roundoff)							\$12,425	

The costs noted above are estimates only and may be modified by changing conditions or the passage of time.

Project Name: **SUNY New Paltz**
 Project No.: 4013032.01
 Calculated by: _____
 Checked by: _____

Sheet No: 1 of 1
 Date: 14-Dec-15
 Date: _____

Measure: ECM LNC3 Steam Traps

Div.	Description	Qty.	Unit	Unit Labor	Cost Material	Total Labor	Total Material	Total	Ref.
	Steam Traps (Thermostatic, 2 in.)	6	ea	\$156.00	\$485.00	\$963.30	\$2,994.88	\$3,958.18	RSMeans 2014, Includes Removal of failed trap
	Subtotal					\$963.30	\$2,994.88	\$3,958.18	
	Contingency (10%)					\$96.33	\$299.49	\$395.82	
	Total					\$1,059.63	\$3,294.36	\$4,353.99	
	Asbestos Abatement					\$0.00	\$0.00		
	Bonds IDIC Add					\$0.00	\$0.00		
	Audit, Design, and Construction Management							\$566.02	
	NYPA Project Management							\$544.25	
	ECM Total (Roundoff)							\$5,464	

The costs noted above are estimates only and may be modified by changing conditions or the passage of time.

Project Name: SUNY New Paltz
 Project No.: 4013032.01
 Calculated by: _____
 Checked by: _____

Sheet No: 1 of 1
 Date: 14-Dec-15
 Date: _____

Measure: ECM LNC4 Window AC Timers

Div.	Description	Qty.	Unit	Unit Labor	Cost Material	Total Labor	Total Material	Total	Ref.
	Programmable Outlet Thermostat	56	ea	\$8.55	\$40.00	\$478.98	\$2,240.00	\$2,718.98	RSMMeans / Contractor Est.
	Subtotal					\$478.98	\$2,240.00	\$2,718.98	
	Contingency (10%)					\$47.90	\$224.00	\$271.90	
	Total					\$526.88	\$2,464.00	\$2,990.88	
	Asbestos Abatement					\$0.00	\$0.00		
	Bonds IDIC Add					\$0.00	\$0.00		
	Audit, Design, and Construction Management							\$388.81	
	NYPA Project Management							\$373.86	
	ECM Total (Roundoff)							\$3,754	

The costs noted above are estimates only and may be modified by changing conditions or the passage of time.

Project Name: **SUNY New Paltz**

Project No.: 4013032

Calculated by: _____

Checked by: _____

Sheet No: _____ 1 _____ of _____ 1

Date: 14-Dec-15

Date: _____

Measure: ECM O&M1 Weatherization

Div.	Description	Qty.	Unit	Unit Labor	Cost Material	Total Labor	Total Material	Total	Ref.
	Door Weatherstripping	441	ea	\$138.92	\$49.71	\$61,265	\$21,921	\$83,186	RS Means 08 71 25.10 2700
	Window Weatherstripping	220	ea	\$90.74	\$19.44	\$19,962	\$4,277	\$24,239	RS Means 08 75 30.10 0500
	Subtotal					\$81,226.73	\$26,198.56	\$107,425.29	
	Contingency (10%)					\$8,122.67	\$2,619.86	\$10,742.53	
	Total					\$89,349.40	\$28,818.42	\$118,167.82	
	Asbestos Abatement					\$0.00	\$0.00		
	Bonds IDIC Add					\$0.00	\$0.00		
	Audit, Design, and Construction Management							\$15,361.82	
	NYPA Project Management							\$14,770.98	
	ECM Total (Roundoff)							\$148,301	

The costs noted above are estimates only and may be modified by changing conditions or the passage of time.

Project Name: SUNY New Paltz

Project No.: 4013032.01

Calculated by: _____

Checked by: _____

Sheet No: 1 of 1

Date: 14-Dec-15

Date: _____

Measure: ECM O&M3 Building Schedules

Div.	Description	Qty.	Unit	Unit Labor	Cost Material	Total Labor	Total Material	Total	Ref.
	Control Changes	548	ea	\$500.00	\$750.00	\$273,984.93	\$410,977.40	\$684,962.33	Previous Experience
	Subtotal					\$273,984.93	\$410,977.40	\$684,962.33	
	Contingency (10%)					\$27,398.49	\$41,097.74	\$68,496.23	
	Total					\$301,383.42	\$452,075.14	\$753,458.56	
	Asbestos Abatement					\$0.00	\$0.00		
	Bonds IDIC Add					\$0.00	\$0.00		
	Audit, Design, and Construction Management							\$97,949.61	
	NYPA Project Management							\$94,182.32	
	ECM Total (Roundoff)							\$945,590	

The costs noted above are estimates only and may be modified by changing conditions or the passage of time.

Project Name: **SUNY New Paltz Energy Master Plan**
 Project No.: 4013032
 Calculated by: S. Tully
 Checked by:

Sheet No: 1 of 1
 Date: 14-Dec-15
 Date:

Measure: ECM O&M4 Piping Insulation

138.8 114.3

Div.	Description	Qty.	Unit	Unit each				Total	Ref.
	Heat Exchangers	1	lot	\$7,158.25				\$7,158.25	Contractor Est./RSMeans
	10" Fittings	1	ea	\$198.04				\$198.04	Contractor Est./RSMeans
	8" Fittings		ea						
	6" Fittings	4	ea	\$232.40				\$929.60	Contractor Est./RSMeans
	4" Fittings	27	ea	\$191.88				\$5,180.83	Contractor Est./RSMeans
	3" Fittings	38	ea	\$228.85				\$8,696.38	Contractor Est./RSMeans
	2-1/2" Fittings	10	ea	\$174.87				\$1,748.70	Contractor Est./RSMeans
	2" Fittings	42	ea	\$217.89				\$9,151.22	Contractor Est./RSMeans
	1-1/2" Fittings	5	ea	\$180.10				\$900.48	Contractor Est./RSMeans
	1" Fittings	4	ea	\$155.96				\$623.83	Contractor Est./RSMeans
	Subtotal					\$0.00	\$0.00	\$34,587.33	
	Contingency (10%)					\$0.00	\$0.00	\$3,458.73	
	Total					\$0.00	\$0.00	\$38,046.06	
	Asbestos Abatement					\$0.00	\$0.00		
	Bonds IDIC Add					\$0.00	\$0.00		
	Audit, Design, and Construction Management							\$4,945.99	
	NYPA Project Management							\$4,755.76	
	ECM Total (Roundoff)							\$47,748	

The costs noted above are estimates only and may be modified by changing conditions or the passage of time.

Project Name: **SUNY New Paltz Energy Master Plan**
 Project No.: 4013032
 Calculated by: S. Tully
 Checked by: _____

Sheet No: 1 of 1
 Date: 14-Dec-15

Measure: **ECM C1 High Efficiency Lighting & Controls**

Div.	Description	Qty.	Unit	Unit Labor	Cost Material	Total Labor	Total Material	Total	Ref.
	Academic Stairwell Ceiling Occ Sensor	72	ea	\$69.36	\$88.07	\$4,959.03	\$6,296.65	\$11,255.67	RMeans 26 09 23.10 0100
	Dorm Stairwell Ceiling Occ Sensor	62	ea	\$69.36	\$88.07	\$4,282.79	\$5,438.01	\$9,720.81	RMeans 26 09 23.10 0100
	Dorm Corridors Ceiling Occ Sensor	168	ea	\$69.36	\$88.07	\$11,628.86	\$14,765.57	\$26,394.42	RMeans 26 09 23.10 0100
	Academic Misc Ceiling Occ Sensor	62	ea	\$69.36	\$88.07	\$4,300.13	\$5,460.03	\$9,760.16	RMeans 26 09 23.10 0100
	Academic Restroom Auto Wall Switches	8	ea	\$20.24	\$59.79	\$168.66	\$498.26	\$666.92	RMeans 26 09 23.10 0150
	F42LL T8 Retrofit (4' 2 lamp 32W T8)	12	ea	\$60.83	\$62.11	\$729.95	\$745.31	\$1,475.26	RMeans 26 51 13.50 2310
	Compact Florescent Lamp Retrofit	56	ea	\$0.54	\$0.40	\$30.24	\$22.17	\$52.41	RMeans 26 61 23.10 0560
	F46ILL T8 Retrofit (4' 6 lamp 32W T8)	20	ea	\$113.70	\$92.70	\$2,274.00	\$1,854.00	\$4,128.00	RMeans 26 51 13.50 2310
	200W Equivalent LED Retrofit.	63	ea	\$148.95	\$769.41	\$9,383.66	\$48,472.83	\$57,856.49	RMeans 26 51 13.55 6100
	Subtotal					\$37,757.33	\$83,552.82	\$121,310.15	
	Contingency (10%)					\$3,775.73	\$8,355.28	\$12,131.01	
	Total					\$41,533.06	\$91,908.11	\$133,441.16	
	Asbestos Abatement					\$0.00	\$0.00		
	Bonds IDIC Add					\$0.00	\$0.00	\$0.00	
	Audit, Design, and Construction Management							\$17,347.35	
	NYPA Project Management							\$16,680.15	
	ECM Total (Roundoff)							\$167,469	

The costs noted above are estimates only and may be modified by changing conditions or the passage of time.

Project Name: **SUNY New Paltz**
 Project No.: 4013032.01
 Calculated by: Kalyan P.
 Checked by: _____

Sheet No: 1 of 1
 Date: 14-Dec-15
 Date: _____

Measure: ECM C2 Site Lighting

Div.	Description	Qty.	Unit	Unit Labor	Cost Material	Total Labor	Total Material	Total	Ref.
	Wall Pack mounted at High Level - LED	50	ea	\$184.42	\$494.35	\$9,221.01	\$24,717.51	\$33,938.52	Contractor Est.
	Wall Pack mounted at Low Level - LED	70	ea	\$184.42	\$296.61	\$12,909.41	\$20,762.71	\$33,672.13	Contractor Est.
	Pole Fixture - Acorn Type - LED	162	ea	\$110.65	\$271.89	\$17,925.64	\$44,046.61	\$61,972.25	Contractor Est.
	Pole Fixture - Moon Type - LED	159	ea	\$110.65	\$271.89	\$17,593.69	\$43,230.93	\$60,824.62	Contractor Est.
	Pole Fixture - Metal Halide Type - LED	58	ea	\$221.30	\$444.92	\$12,835.65	\$25,805.08	\$38,640.73	Contractor Est.
	Pole Fixture - StandardType - LED	218	ea	\$147.54	\$593.22	\$32,162.88	\$129,322.03	\$161,484.92	Contractor Est.
	Subtotal					\$102,648.28	\$287,884.89	\$390,533.17	
	Contingency (10%)					\$10,264.83	\$28,788.49	\$39,053.32	
	Total					\$112,913.11	\$316,673.38	\$429,586.49	
	Asbestos Abatement					\$0.00	\$0.00		
	Bonds IDIC Add					\$0.00	\$0.00		
	Audit, Design, and Construction Management							\$55,846.24	
	NYPA Project Management							\$53,698.31	
	ECM Total (Roundoff)							\$539,131	

The costs noted above are estimates only and may be modified by changing conditions or the passage of time.

Project Name: SUNY New Paltz
 Project No.: 4013032.01
 Calculated by: _____
 Checked by: _____

Sheet No: 1 of 1
 Date: 14-Dec-15
 Date: _____

Measure: ECM C3 VFDs

Div.	Description	Qty.	Unit	Unit Labor	Cost Material	Total Labor	Total Material	Total	Ref.
	Premium Efficiency Motor - 3HP	1	ea	\$500.00	\$190.00	\$500.00	\$190.00	\$690.00	RSMeans, Installation Cost Doubled to account of removal of existing motor
	Premium Efficiency Motor - 5HP	2	ea	\$600.00	\$190.00	\$1,200.00	\$380.00	\$1,580.00	RSMeans, Installation Cost Doubled to account of removal of existing motor
	Premium Efficiency Motor - 7.5HP	17	ea	\$700.00	\$204.00	\$11,900.00	\$3,468.00	\$15,368.00	RSMeans, Installation Cost Doubled to account of removal of existing motor
	Premium Efficiency Motor - 10HP	12	ea	\$855.00	\$214.00	\$10,260.00	\$2,568.00	\$12,828.00	RSMeans, Installation Cost Doubled to account of removal of existing motor
	Premium Efficiency Motor - 15HP	5	ea	\$1,200.00	\$266.00	\$6,000.00	\$1,330.00	\$7,330.00	RSMeans, Installation Cost Doubled to account of removal of existing motor
	Premium Efficiency Motor - 20HP	3	ea	\$1,525.00	\$328.00	\$4,575.00	\$984.00	\$5,559.00	RSMeans, Installation Cost Doubled to account of removal of existing motor
	Premium Efficiency Motor - 25HP	1	ea	\$1,925.00	\$342.00	\$1,925.00	\$342.00	\$2,267.00	RSMeans, Installation Cost Doubled to account of removal of existing motor
	Premium Efficiency Motor - 30HP	2	ea	\$2,200.00	\$356.00	\$4,400.00	\$712.00	\$5,112.00	RSMeans, Installation Cost Doubled to account of removal of existing motor
	VFD - 3HP	1	ea	\$535.00	\$1,475.00	\$535.00	\$1,475.00	\$2,010.00	RSMeans
	VFD - 5HP	2	ea	\$535.00	\$1,675.00	\$1,070.00	\$3,350.00	\$4,420.00	RSMeans
	VFD - 7.5HP	17	ea	\$635.00	\$2,000.00	\$10,795.00	\$34,000.00	\$44,795.00	RSMeans
	VFD - 10HP	12	ea	\$635.00	\$2,325.00	\$7,620.00	\$27,900.00	\$35,520.00	RSMeans
	VFD - 15HP	5	ea	\$960.00	\$2,825.00	\$4,800.00	\$14,125.00	\$18,925.00	RSMeans
	VFD - 20HP	3	ea	\$960.00	\$3,325.00	\$2,880.00	\$9,975.00	\$12,855.00	RSMeans
	VFD - 25HP	1	ea	\$1,275.00	\$4,100.00	\$1,275.00	\$4,100.00	\$5,375.00	RSMeans
	VFD - 30HP	2	ea	\$1,275.00	\$5,100.00	\$2,550.00	\$10,200.00	\$12,750.00	RSMeans
	Controls Programming	43	ea	\$1,800.00	\$0.00	\$77,400.00	\$0.00	\$77,400.00	Contractor Quote
	Subtotal					\$149,685.00	\$115,099.00	\$264,784.00	
	Contingency (10%)					\$14,968.50	\$11,509.90	\$26,478.40	
	Total					\$164,653.50	\$126,608.90	\$291,262.40	
	Asbestos Abatement					\$0.00	\$0.00		
	Bonds IDIC Add					\$0.00	\$0.00		
	Audit, Design, and Construction Management							\$37,864.11	
	NYPAs Project Management							\$36,407.80	
	ECM Total (Roundoff)							\$365,534	

The costs noted above are estimates only and may be modified by changing conditions or the passage of time.

Project Name: **SUNY New Paltz**
 Project No.: 4013032.01
 Calculated by: _____
 Checked by: _____

Sheet No: 1 of 1
 Date: 14-Dec-15
 Date: _____

Measure: ECM C4 Chilled Water Temperature Reset

Div.	Description	Qty.	Unit	Unit Labor	Cost Material	Total Labor	Total Material	Total	Ref.
	Implement Programing	6		\$1,500.00	\$0.00	\$9,000.00	\$0.00	\$9,000.00	Prior experience
	Subtotal					\$9,000.00	\$0.00	\$9,000.00	
	Contingency (10%)					\$900.00	\$0.00	\$900.00	
	Total					\$9,900.00	\$0.00	\$9,900.00	
	Asbestos Abatement					\$0.00	\$0.00		
	Bonds IDIC Add					\$0.00	\$0.00		
	Audit, Design, and Construction Management							\$1,287.00	
	NYPA Project Management							\$1,237.50	
	ECM Total (Roundoff)							\$12,425	

The costs noted above are estimates only and may be modified by changing conditions or the passage of time.

Project Name: **SUNY New Paltz**
 Project No.: 4013032.01
 Calculated by: _____
 Checked by: _____

Sheet No: 1 of 1
 Date: 14-Dec-15
 Date: _____

Measure: ECM C6 Kitchen Hood Controls

Div.	Description	Qty.	Unit	Unit Labor	Cost Material	Total Labor	Total Material	Total	Ref.
	VFD - 3HP	4	ea	\$535.00	\$1,475.00	\$2,140.00	\$5,900.00	\$8,040.00	RSMeans
	Controls Programming	4	ea	\$1,800.00	\$0.00	\$7,200.00	\$0.00	\$7,200.00	Contractor Quote
	Subtotal					\$9,340.00	\$5,900.00	\$15,240.00	
	Contingency (10%)					\$934.00	\$590.00	\$1,524.00	
	Total					\$10,274.00	\$6,490.00	\$16,764.00	
	Asbestos Abatement					\$0.00	\$0.00		
	Bonds IDIC Add					\$0.00	\$0.00		
	Audit, Design, and Construction Management							\$2,179.32	
	NYPA Project Management							\$2,095.50	
	ECM Total (Roundoff)							\$21,039	

The costs noted above are estimates only and may be modified by changing conditions or the passage of time.

Appendix 4 – Savings Calculations



Project Name:	SUNY New Paltz
Project Number:	4013032.01
ECM-LNC1	Winter Domestic Hot Water

Utility Costs	
Electricity:	0.107 \$/kWh
Natural Gas:	0.858 \$/therm

Building	Existing Water Usage			Projected Water Usage			Hot Water Savings		
	Annual Water Use (kGal)	Energy (MMBTU)	Central Plant Efficiency	Distribution System Losses	Estimated Therm Consumption	Local Boiler Efficiency	Estimated Therm Consumption	Therm Savings	Cost Savings
College Hall, Shango Hall	116.8	141	78%	5%	1,906	85%	1,661	244	\$ 210
Capen Hall	90.4	109	78%	5%	1,475	90%	1,214	261	\$ 224
LeFevre Hall	90.4	109	78%	5%	1,475	90%	1,214	261	\$ 224
Dubois Hall	107.1	130	78%	5%	1,748	90%	1,439	309	\$ 265
Deyo Hall	103.6	125	78%	5%	1,690	90%	1,392	299	\$ 256
Scudder Hall	103.6	125	78%	5%	1,690	90%	1,392	299	\$ 256
Bevier Hall	111.7	135	78%	5%	1,823	90%	1,501	322	\$ 276
Bliss Hall	105.1	127	78%	5%	1,715	90%	1,412	303	\$ 260
Gage Hall	163.5	198	78%	5%	2,668	90%	2,197	471	\$ 404
Crispell Hall	105.1	127	78%	5%	1,715	90%	1,412	303	\$ 260
Bouton Hall	148.8	180	78%	5%	2,428	90%	1,999	429	\$ 368
Lenape Hall	118.8	144	78%	5%	1,939	78%	1,842	97	\$ 83
Esopus Hall	118.8	144	78%	5%	1,939	78%	1,842	97	\$ 83
Total Units		1,794			24,212		20,518	3,694	\$ 3,169

Savings Summary	
Site Electricity Savings (kWh):	0
Site Gas Savings (Therms):	3,694
Energy Savings (MMBTU Source):	387
Cost Savings (\$):	\$ 3,169
Emissions Reduction (lb CO ₂):	45,011

Assumptions:
 - Annual Water Use based on assumptions from ECM-O&M2 - Water Conservation for 8 months.



Project Name: SUNY New Paltz

Project Number: 4013032.01

ECM-LNC2 Condenser Water Reset - Summary

Summary	
Estimated Cost to Implement	\$12,425
Site Electric Savings [kWh]	123,646
Site Heating Savings (therm)	-
Total Source Savings (MIMBTU)	1,409
Cost Savings (\$)	\$ 11,071
Simple Payback [years]	1.12
Emissions Reduction (lb CO ₂):	252,330

Utility Costs	
Electricity:	\$0.090 /kWh
Natural Gas:	\$0.858 /Therm

	Existing Case	Proposed Case	Savings [unit]	Savings [\$]
Electrical Consumption [kwh / yr]	1,575,322.22	1,451,676.04	123,646.18	\$ 11,071
Natural Gas Consumption [therms / yr]	-	-	-	-
Implementation Cost [\$]		\$12,425		
Totals				\$ 11,071

Building	Prior Existing Conditions		Revised Conditions	
	Yearly Energy Consumption (kWh)	Yearly Energy Cost (\$)	Yearly Energy Consumption (kWh)	Yearly Energy Cost (\$)
Lecture Center	492,500	44,099	453,844	40,637
Old Main Building	185,072	16,571	170,546	15,271
Student Union	417,878	37,417	385,080	34,480
Esopus Residence Hall	213,628	19,128	196,861	17,627
Lenape Residence Hall	213,628	19,128	196,861	17,627
Health Services	52,616	4,711	48,484	4,341
Totals	1,575,322	141,055	1,451,676	129,984



Project Name: SUNY New Paltz
 Project Number: 4010032.01
 ECOM/NC2
 Building: Lecture Center

Summary	
Estimated Cost to Implement	\$ 1,500.00
Estimated Annual consumption savings (kWh)	38,655
Estimated recurring yearly savings (\$)	3,461.20
Simple Payback (years)	0.4

	Existing Case	Proposed Case	Savings (and)	Savings (\$)
Electrical Consumption (kWh/yr)	492,489.56	453,844.40	38,655.16	\$ 3,461.20
Natural Gas Consumption (therms/yr)	N/A	N/A	N/A	N/A
Implementation Cost (\$)	\$ 1,500.00			
Totals				\$ 3,461.20

Calculation Inputs

Cooling Load Profile	Cooling tower approach	
	WBET (F)	Approach Temp (F)
OA/T (F)	50	10
55	75	7
65		
70		
75		
80		
85		
90		
95		
100		

Chiller Part Load Performance	
% Load	kWh/Ton
100%	0.59
75%	0.43
50%	0.32
25%	0.45
Part Load	0.38

Calculations

Bin	Weather Data		Performance Data		Existing Operating Parameter		Proposed Operation Strategy			Estimated Energy Savings							
	DBT	WBET	Hours	Estimated Cooling Load (ton)	% Load	Estimated kW/Ton	Cooling Tower Approach Temperature (F)	Existing Condenser Water Temperature (F)	Existing Energy Consumption (kWh)	Net Change in Temperature (F)	Reduction in Chiller Flow Consumption (%)	Proposed Energy Consumption (kWh)	Change in Chiller Power Consumption (kW)	% Cooling Penalty	Estimated Power Reduction (kW)	Estimated Energy Savings (kWh)	
90 to 95	82.5	72.6	12	665	95%	0.56	7	80	4,478	0	0%	4,473	0.34	0.42	0	5	
85 to 90	81.5	71.4	31	525	75%	0.43	7	80	2,928	0	2%	2,928	5.27	2.64	0	820	
80 to 85	82.5	71.4	31	525	75%	0.43	7	80	2,928	1	2%	2,928	5.27	2.64	0	820	
75 to 80	77.5	68.2	381	455	65%	0.39	8	80	68,866	76	8%	66,209	14.05	7.03	7	2,747	
70 to 75	72.5	66.3	579	385	55%	0.35	8	80	76,860	74	11%	72,588	15.03	7.52	8	4,352	
65 to 70	67.5	62.5	774	315	45%	0.35	9	80	84,882	71	18%	77,343	18.77	9.88	10	7,649	
60 to 65	62.5	58.5	885	175	25%	0.45	10	80	176,820	63	34%	116,820	26.33	13.37	13	11,683	
55 to 60	57.5	53.6	885	175	25%	0.45	10	80	176,820	63	34%	116,820	26.33	13.37	13	11,683	
50 to 55	52.5	48.4	837	0	0%	0.00	10	80	0	58	22	43%	0.00	0.00	0.00	0	0
45 to 50	47.5	43.6	604	0	0%	0.00	10	80	0	55	25	50%	0.00	0.00	0.00	0	0
40 to 45	42.5	39.2	756	0	0%	0.00	10	80	0	55	25	50%	0.00	0.00	0.00	0	0
35 to 40	37.5	34.0	553	0	0%	0.00	10	80	0	55	25	50%	0.00	0.00	0.00	0	0
30 to 35	32.5	30	553	0	0%	0.00	10	80	0	55	25	50%	0.00	0.00	0.00	0	0
25 to 30	27.5	25.3	374	0	0%	0.00	10	80	0	55	25	50%	0.00	0.00	0.00	0	0
20 to 25	22.5	20.4	337	0	0%	0.00	10	80	0	55	25	50%	0.00	0.00	0.00	0	0
15 to 20	17.5	15.6	214	0	0%	0.00	10	80	0	55	25	50%	0.00	0.00	0.00	0	0
10 to 15	12.5	10.4	110	0	0%	0.00	10	80	0	55	25	50%	0.00	0.00	0.00	0	0
5 to 10	7.5	5.6	77	0	0%	0.00	10	80	0	55	25	50%	0.00	0.00	0.00	0	0
0 to 5	2.5	1.4	33	0	0%	0.00	10	80	0	55	25	50%	0.00	0.00	0.00	0	0
-5 to 0	-2.5	-3.1	20	0	0%	0.00	10	80	0	55	25	50%	0.00	0.00	0.00	0	0
-10 to -5	-7.5	-8	10	0	0%	0.00	10	80	0	55	25	50%	0.00	0.00	0.00	0	0
-15 to -10	-12.5	-12.7	10	0	0%	0.00	10	80	482,600	55	25	50%	453,844	0.00	0.00	0	38,655

Assumptions:

- Existing condenser water setpoint is 80 deg. F
- Proposed condenser water setpoint is 55 deg. F
- 2.5% decrease in energy consumption per degree Fahrenheit rise in temperature from http://appst1.aere.energy.gov/buildings/publications/pdfs/allanachseha_chillers_tsl.pdf



Project Name: STONY New Plaza
 Project Number: 4010032.01
 Building: ECLIN2
 Condenser Water Reset
 04 Main Building

Summary	
Estimated Cost to Implement	\$ 1,500.00
Estimated Annual consumption savings [kWh]	14,526
Estimated recurring yearly savings [\$/yr]	1,300.65
Simple Payback (years)	1.2

Existing Case	Proposed Case	Savings (und)	Savings (\$)
Electrical Consumption [kWh/yr]	170,546.39	14,525.90	\$ 1,300.65
Natural Gas Consumption [therms/yr]	N/A	N/A	N/A
Implementation Cost [\$/]	\$ 1,500.00		
Totals			\$ 1,300.65

Calculation Inputs

Cooling Load Profile		Cooling tower approach	
OAT (F)	Cooling Load (Tons)	WBET (F)	Approach Temp (F)
55	50	50	10
65	250	75	7

OAT Lockout of chiller plant (F) _____
 Condenser Water Setpoint (F) _____
 Existing chilled water temp. setpoint (F) _____
 Existing chilled water return temp. (F) _____
 % decrease in energy consumption per 1°F drop in condenser water temp _____
 Condenser Water Temp. Low Limit (F) _____
 Condenser Water Temp. High Limit (F) _____
 %Cooling Tower Penalty w.r.t chiller savings _____
 50%

Chiller Part Load Performance	
% Load	kWh/Ton
100%	0.63
75%	0.45
50%	0.34
25%	0.47
Part V	0.40

Calculations

Bin	Weather Data			Performance Data			Existing Operating Parameter			Proposed Operation Strategy			Estimated Energy Savings			
	DBT	WBET	Hours	Estimated Cooling Load (tons)	% Load	Estimated kW/Ton	Cooling Tower Approach Temperature (F)	Existing Condenser Water Setpoint	Existing Energy Consumption (kWh)	Net Change in Temperature (F)	Reduction in Chiller Flow Consumption (%)	Proposed Energy Consumption (kWh)	Change in Chiller Power Consumption (kW)	%Cooling Tower Penalty	Estimated Power Reduction (kW)	Estimated Energy Savings (kWh)
90 to 85	82.5	72.6	12	238	95%	0.59	7	80	1,683	0	0%	1,683	0.31	0.16	0	2
85 to 80	77.5	71.4	311	168	75%	0.45	7	80	26,075	0	2%	25,815	1.98	0.99	0	308
80 to 75	72.5	68.2	381	163	65%	0.41	8	80	25,912	4	8%	24,880	5.28	2.64	3	1,032
75 to 70	67.5	66.3	579	138	55%	0.38	8	80	28,916	6	11%	27,281	5.65	2.82	3	1,636
70 to 65	62.5	62.5	774	113	45%	0.37	9	80	31,889	7	18%	29,064	7.43	3.71	4	2,374
65 to 60	57.5	61.6	885	95	35%	0.41	10	80	36,025	12	34%	34,813	8.80	4.40	5	2,879
60 to 55	52.5	63.6	837	65	25%	0.47	10	80	28,095	17	34%	21,630	8.00	4.00	5	4,379
55 to 50	47.5	48.4	604	0	0%	0.00	10	80	0	22	43%	0	0.00	0.00	0	0
50 to 45	42.5	43.6	756	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
45 to 40	39.2	39.2	756	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
40 to 35	32.5	30.0	553	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
35 to 30	27.5	30.0	374	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
30 to 25	22.5	25.3	337	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
25 to 20	17.5	15.6	214	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
20 to 15	12.5	14.4	110	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
15 to 10	7.5	5.6	110	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
10 to 5	2.5	1.4	33	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
-5 to 0	-2.5	-3.1	20	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
-10 to -5	-7.5	-8	10	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
-15 to -10	-12.5	-12.7	10	0	0%	0.00	10	80	18,672	25	50%	170,546	0.00	0.00	0	14,526

- Existing condenser water setpoint is 80 deg. F
 - Proposed condenser water setpoint is 56 deg. F
 - 2.5% decrease in energy consumption per degree Fahrenheit rise in temperature from http://apps1.eere.energy.gov/buildings/publications/pdfs/aiaancest/hea_chillers_ls.pdf



Project Name: SUNY New Paltz
 Project Number: 401002.01
 ECOM/NC2
 Building: Condenser Water Reset
 Student Union

Summary	
Estimated Cost to Implement	\$ 1,500.00
Estimated Annual consumption savings (kWh)	32,798
Estimated recurring yearly savings (\$)	2,936.77
Simple Payback (years)	0.5

	Existing Case	Proposed Case	Savings (und)	Savings (\$)
Electrical Consumption (kwh/yr)	417,678.41	385,080.10	32,798.32	\$ 2,936.77
Natural Gas Consumption (therms/yr)	N/A	N/A	N/A	N/A
Implementation Cost (\$)	\$ 1,500.00			
Totals				\$ 2,936.77

Calculation Inputs

Cooling Load Profile		Cooling tower approach	
OM (F)	Cooling Load (Tons)	WBET (F)	Approach Temp (F)
55	120	50	10
65	600	75	7

OMT Lockout of chiller plant (F)	65
Condenser Water Setpoint (F)	80
Existing chilled water temp. setpoint (F)	44
Existing chilled water return temp. (F)	54
% decrease in energy consumption per 1°F drop in condenser water temp	2.0%
Condenser Water Temp. Low Limit (F)	55
Condenser Water Temp. High Limit (F)	85
%Cooling Tower Penalty w.r.t chiller savings	50%

Chiller Part Load Performance	
% Load	kWh/Ton
100%	0.59
75%	0.43
50%	0.32
25%	0.44
Part V	0.37

Calculations

Bin	Weather Data		Performance Data		Existing Operating Parameter		Proposed Operation Strategy		Estimated Energy Savings								
	DBT	WBET	Hours	Estimated Cooling Load (ton)	% Load	Estimated kW/Ton	Cooling Tower Approach Temperature (F)	Existing Condenser Water Setpoint	Existing Energy Consumption (kWh)	Recommended Condenser Water Setpoint (F)	Net Change in Temperature (F)	Reduction in Chiller Flow Consumption (%)	Proposed Energy Consumption (kWh)	Change in Chiller Power Consumption (kW)	%Cooling Tower Penalty	Estimated Power Reduction (kW)	Estimated Energy Savings (kWh)
90 to 95	82.5	72.6	12	570	95%	0.58	7	80	3300	80	0	0%	3,796	0.71	0.35	0	4
85 to 90	81.5	71.4	31	450	75%	0.43	7	80	2,470	79	1	2%	4,670	4.47	2.24	2	698
80 to 85	82.5	71.4	311	400	75%	0.43	7	80	59,871	79	1	2%	59,872	4.47	2.24	2	698
75 to 80	77.5	68.2	381	390	65%	0.38	8	80	59,508	76	4	8%	56,177	11.92	5.96	6	2,331
70 to 75	72.5	66.3	579	330	55%	0.34	8	80	65,291	74	6	11%	61,588	12.76	6.38	6	3,693
65 to 70	67.5	62.5	774	270	45%	0.35	9	80	72,115	71	9	18%	65,624	16.77	8.39	8	4,480
60 to 65	62.5	58.5	885	210	35%	0.36	10	80	81,440	68	12	24%	72,446	22.24	11.17	11	5,297
55 to 60	57.5	53.6	885	150	25%	0.44	10	80	58,740	63	17	34%	48,853	22.24	11.17	11	5,297
50 to 55	52.5	48.4	837	0	0%	0.00	10	80	0	58	22	43%	0	0.00	0.00	0	0
45 to 50	47.5	43.6	604	0	0%	0.00	10	80	0	55	25	50%	0	0.00	0.00	0	0
40 to 45	42.5	39.2	756	0	0%	0.00	10	80	0	55	25	50%	0	0.00	0.00	0	0
35 to 40	37.5	35.0	553	0	0%	0.00	10	80	0	55	25	50%	0	0.00	0.00	0	0
30 to 35	32.5	30.0	553	0	0%	0.00	10	80	0	55	25	50%	0	0.00	0.00	0	0
25 to 30	27.5	25.3	374	0	0%	0.00	10	80	0	55	25	50%	0	0.00	0.00	0	0
20 to 25	22.5	20.4	337	0	0%	0.00	10	80	0	55	25	50%	0	0.00	0.00	0	0
15 to 20	17.5	15.6	214	0	0%	0.00	10	80	0	55	25	50%	0	0.00	0.00	0	0
10 to 15	12.5	10.4	110	0	0%	0.00	10	80	0	55	25	50%	0	0.00	0.00	0	0
5 to 10	7.5	5.6	110	0	0%	0.00	10	80	0	55	25	50%	0	0.00	0.00	0	0
0 to 5	2.5	1.4	77	0	0%	0.00	10	80	0	55	25	50%	0	0.00	0.00	0	0
-5 to 0	-2.5	-3.1	33	0	0%	0.00	10	80	0	55	25	50%	0	0.00	0.00	0	0
-10 to -5	-7.5	-8	20	0	0%	0.00	10	80	0	55	25	50%	0	0.00	0.00	0	0
-15 to -10	-12.5	-12.7	10	0	0%	0.00	10	80	0	55	25	50%	0	0.00	0.00	0	0
Totals									417,678				385,080				32,798

- Existing condenser water setpoint is 80 deg. F
 - Proposed condenser water setpoint is 56 deg. F
 - 2.5% decrease in energy consumption per degree Fahrenheit rise in temperature from http://apps1.eere.energy.gov/buildings/publications/pdfs/aiaa/ncse/hea_chillers_ls.pdf



Project Name: STONY New Plaza
 Project Number: 4010032.01
 ECOM/NC2
 Building: Condenser Water Reset
 Esopus Residence Hall

Summary	
Estimated Cost to Implement	\$ 1,500.00
Estimated Annual consumption savings (kWh)	46,767
Estimated recurring yearly savings (\$)	1,501.34
Simple Payback (years)	1.0

	Existing Case	Proposed Case	Savings (und)	Savings (\$)
Electrical Consumption (kWh/yr)	213,027.89	196,960.73	16,767.16	\$ 1,501.34
Natural Gas Consumption (therms/yr)	N/A	N/A	N/A	N/A
Implementation Cost (\$)	\$ 1,500.00			
Totals				\$ 1,501.34

Calculation Inputs

Cooling Load Profile		Cooling tower approach	
OM (F)	Cooling Load (Tons)	WBET (F)	Approach Temp (F)
55	33	50	10
65	165	75	7
OMT (setpoint of chiller plant) (F)			
Condenser Water Setpoint (F)			80
Existing chilled water temp. setpoint (F)			44
Existing chilled water return temp. (F)			54
% decrease in energy consumption per 1°F drop in condenser water temp			2.0%
Condenser Water Temp. Low Limit (F)			55
Condenser Water Temp. High Limit (F)			85
%Cooling Tower Penalty w.r.t chiller savings			50%

Chiller Part Load Performance	
% Load	kWh/Ton
100%	1.09
75%	0.79
50%	0.60
25%	0.82
Part V	0.69

Calculations

Bin	Weather Data			Performance Data			Existing Operating Parameter			Proposed Operation Strategy			Estimated Energy Savings			
	DBT	WBET	Hours	Estimated Cooling Load (tons)	% Load	Estimated kW/Ton	Cooling Tower Approach Temperature (F)	Existing Condenser Water Setpoint	Existing Energy Consumption (kWh)	Net Change in Temperature (F)	Reduction in Chiller Flow Consumption (%)	Proposed Energy Consumption (kWh)	Change in Chiller Power Consumption (kW)	%Cooling Tower Penalty	Estimated Power Reduction (kW)	Estimated Energy Savings (kWh)
90 to 95	82.5	72.6	12	157	85%	1.03	7	80	1,343	0	0%	1,340	0.38	0.18	0	2
85 to 90	77.5	71.4	31	124	75%	0.79	7	80	1,025	1	2%	1,025	2.29	1.14	0	396
80 to 85	72.5	68.2	381	107	65%	0.71	8	80	29,911	4	8%	29,719	6.10	3.05	3	1,192
75 to 80	72.5	66.3	579	91	55%	0.64	8	80	33,278	74	11%	31,480	6.52	3.26	3	1,888
65 to 70	67.5	62.5	774	74	45%	0.64	9	80	36,866	71	18%	33,548	8.57	4.29	4	3,319
60 to 65	62.5	57.5	885	56	35%	0.64	10	80	41,625	63	24%	38,455	11.42	5.71	5	4,044
55 to 60	57.5	53.6	885	41	25%	0.82	10	80	30,029	58	34%	24,975	11.42	5.71	6	5,054
50 to 55	52.5	48.4	837	0	0%	0.00	10	80	0	22	43%	0	0.00	0.00	0	0
45 to 50	47.5	43.6	604	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
40 to 45	42.5	39.2	756	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
35 to 40	37.5	35.0	553	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
30 to 35	32.5	30.0	553	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
25 to 30	27.5	25.3	374	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
20 to 25	22.5	20.4	337	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
15 to 20	17.5	15.6	214	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
10 to 15	12.5	10.4	110	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
5 to 10	7.5	5.6	110	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
0 to 5	2.5	1.4	33	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
-5 to 0	-2.5	-3.1	33	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
-10 to -5	-7.5	-8	20	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
-15 to -10	-12.5	-12.7	10	0	0%	0.00	10	80	233,238	25	50%	196,861	0.00	0.00	0	16,767

- Existing condenser water setpoint is 80 deg. F
 - Proposed condenser water setpoint is 56 deg. F
 - 2.5% decrease in energy consumption per degree Fahrenheit rise in temperature from http://apps1.eere.energy.gov/buildings/publications/pdfs/aiaa/ncse/hea_chillers_ls.pdf



Project Name: STONY New Plaza
 Project Number: 4010032.01
 ECOM/ENC2
 Building: Condenser Water Reset
 Lamp: Residence Hall

Summary	
Estimated Cost to Implement	\$ 1,500.00
Estimated Annual consumption savings (kWh)	46,767
Estimated recurring yearly savings (\$)	1,501.34
Simple Payback (years)	1.0

	Existing Case	Proposed Case	Savings (und)	Savings (\$)
Electrical Consumption (kWh/yr)	213,027.89	196,960.73	16,767.16	\$ 1,501.34
Natural Gas Consumption (therms/yr)	N/A	N/A	N/A	N/A
Implementation Cost (\$)	\$ 1,500.00			
Totals				\$ 1,501.34

Calculation Inputs

Cooling Load Profile	Cooling tower approach	
	WBET (F)	Approach Temp (F)
OA/T (F)	50	10
55	75	7
65		
OA/T Lockout of chiller plant (F)		65
Condenser Water Setpoint (F)		80
Exhaust chilled water temp. setpoint (F)		44
Exhaust chilled water return temp. (F)		54
% decrease in energy consumption per 1°F drop in condenser water temp		2.0%
Condenser Water Temp. Low Limit (F)		55
Condenser Water Temp. High Limit (F)		85
%Cooling Tower Penalty w.r.t chiller savings		50%

Chiller Part Load Performance	
% Load	kWh/Ton
100%	1.09
75%	0.79
50%	0.60
25%	0.82
Part Load	0.69

Calculations

Bin	Weather Data		Performance Data		Existing Operating Parameter		Proposed Operation Strategy			Estimated Energy Savings						
	DBT	WBET	Hours	Estimated Cooling Load (ton)	% Load	Estimated kW/Ton	Cooling Tower Approach Temperature (F)	Existing Condenser Water Setpoint	Existing Energy Consumption (kWh)	Net Change in Temperature (F)	Reduction in Chiller Flow Consumption (%)	Proposed Energy Consumption (kWh)	Change in Chiller Power Consumption (kW)	%Cooling Tower Penalty	Estimated Power Reduction (kW)	Estimated Energy Savings (kWh)
90 to 85	82.5	72.6	12	157	85%	1.03	7	80	1,940	0	0%	1,940	0.38	0.18	0	2
80 to 85	82.5	71.4	311	124	75%	0.79	7	80	30,028	1	2%	30,028	2.29	1.14	0	396
75 to 80	77.5	68.2	381	107	65%	0.71	8	80	29,911	76	8%	29,719	6.10	3.05	3	1,192
70 to 75	72.5	66.3	579	91	55%	0.64	8	80	33,278	74	11%	31,480	6.52	3.26	3	1,888
65 to 70	67.5	62.5	774	74	45%	0.64	9	80	36,866	71	18%	33,548	8.57	4.29	4	3,319
60 to 65	62.5	58.5	885	56	35%	0.64	10	80	41,625	63	24%	38,455	11.42	5.71	5	4,654
55 to 60	57.5	53.6	885	41	25%	0.82	10	80	30,029	58	34%	24,975	11.42	5.71	6	5,054
50 to 55	52.5	48.4	837	0	0%	0.00	10	80	0	22	43%	0	0.00	0.00	0	0
45 to 50	47.5	43.6	604	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
40 to 45	42.5	39.2	756	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
35 to 40	37.5	35.0	553	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
30 to 35	32.5	30.0	553	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
25 to 30	27.5	25.3	374	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
20 to 25	22.5	20.4	337	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
15 to 20	17.5	15.6	214	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
10 to 15	12.5	10.4	110	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
5 to 10	7.5	5.6	110	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
0 to 5	2.5	1.4	33	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
-5 to 0	-2.5	-3.1	20	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
-10 to -5	-7.5	-8	20	0	0%	0.00	10	80	0	25	50%	0	0.00	0.00	0	0
-15 to -10	-12.5	-12.7	10	0	0%	0.00	10	80	213,028	25	50%	196,961	0.00	0.00	0	16,767

- Existing condenser water setpoint is 80 deg. F
 - Proposed condenser water setpoint is 56 deg. F
 - 2.5% decrease in energy consumption per degree Fahrenheit rise in temperature from http://apps1.eere.energy.gov/buildings/publications/pdfs/aiaa/ncse/hea_chillers_ls.pdf



Project Name: SUNY New Paltz
 Project Number: 40.1302.01
 EPC/EN/C2
 Building: Condenser Water Reset
 Health Services

Summary	
Estimated Cost to Implement	\$ 1,500.00
Estimated Annual Consumption Savings (kWh)	4,132
Estimated recurring yearly savings (\$)	\$ 370.02
Simple Payback [years]	4.1

	Existing Case	Proposed Case	Savings [unit]	Savings (\$)
Electrical Consumption [kwh / yr]	52,616.18	46,483.70	4,132.48	\$ 370.02
Natural Gas Consumption [therms / yr]	N/A	N/A	N/A	N/A
Implementation Cost (\$)		\$ 1,500.00		
Totals				\$ 370.02

Calculation Inputs

	Cooling Load Profile		Cooling tower approach	
	OAT (F)	Cooling Load (Tons)	WBT (F)	Approach Temp (F)
55	5	50	10	
85	25	75	7	
OAT lockout of chiller plant (F)				55
Condenser Water Setpoint (F)				80
Existing chilled water temp. setpoint (F)				44
Existing chilled water return temp. (F)				54
% decrease in energy consumption per 1°F drop in condenser water temp				2.0%
Condenser Water Temp. Low Limit (F)				55
Condenser Water Temp. High Limit (F)				85
%Cooling Tower Penalty w.r.t chiller savings				50%

Chiller Part Load Performance		
% Load	Existing Water Temperature (F)	KW/Ton
100%	7	1.18
75%	8	1.18
50%	9	1.18
25%	10	1.18
PLV		
		1.18

Calculations

Bin	Weather Data		Performance Data		Existing Operating Parameter		Proposed Operation Strategy		Estimated Energy Savings						
	DBT	WBT	Hours	Estimated Cooling Load (ton)	% Load	Refrim. kW/Ton	Cooling Tower Approach Temperature (F)	Existing Water Temperature (F)	Existing Energy Consumption (kWh)	Recommended Condenser Water Setpoint (F)	Net Change in Temperature (F)	Reduction in Chiller Power Consumption (%)	Proposed Energy Consumption (kWh)	Change in Chiller Power Consumption (kW)	Estimated Energy Savings (kWh)
80 to 85	92.5	72.8	12	24	95%	1.18	7	80	3.35	80	0%	3.35	0.00	0	
85 to 90	87.5	73.6	98	21	85%	1.18	7	81	2,450	81	0%	2,450	0.00	0	
80 to 85	82.5	71.4	311	19	75%	1.18	7	80	6,860	79	2%	6,780	0.52	80	
75 to 80	77.5	69.2	391	16	65%	1.18	8	80	7,475	76	4%	7,177	1.52	298	
70 to 75	72.5	67.0	479	14	55%	1.18	9	80	8,090	74	6%	7,777	2.38	413	
65 to 70	67.5	62.3	579	11	45%	1.18	9	80	10,244	71	9%	9,922	3.32	820	
60 to 65	62.5	59.1	911	9	35%	1.18	9	80	9,378	67	13%	8,171	2.65	1,207	
55 to 60	57.5	53.6	865	6	25%	1.18	10	80	6,507	63	17%	5,412	2.48	1,095	
50 to 55	52.5	48.4	837	0	0%	0.00	10	80	0	58	22%	0	0.00	0	
45 to 50	47.5	43.6	604	0	0%	0.00	10	80	0	55	25%	0	0.00	0	
40 to 45	42.5	39.5	346	0	0%	0.00	10	80	0	55	25%	0	0.00	0	
35 to 40	37.5	34.6	742	0	0%	0.00	10	80	0	55	25%	0	0.00	0	
30 to 35	32.5	30	553	0	0%	0.00	10	80	0	55	25%	0	0.00	0	
25 to 30	27.5	25.3	374	0	0%	0.00	10	80	0	55	25%	0	0.00	0	
20 to 25	22.5	20.4	337	0	0%	0.00	10	80	0	55	25%	0	0.00	0	
15 to 20	17.5	15.6	214	0	0%	0.00	10	80	0	55	25%	0	0.00	0	
10 to 15	12.5	10.7	110	0	0%	0.00	10	80	0	55	25%	0	0.00	0	
5 to 10	7.5	5.6	44	0	0%	0.00	10	80	0	55	25%	0	0.00	0	
-5 to 0	0.0	0.0	77	0	0%	0.00	10	80	0	55	25%	0	0.00	0	
-10 to -5	-2.5	-3.1	33	0	0%	0.00	10	80	0	55	25%	0	0.00	0	
-15 to -10	-7.5	-8	20	0	0%	0.00	10	80	0	55	25%	0	0.00	0	
		-12.7	10	0	0%	0.00	10	80	0	55	25%	0	0.00	0	
									52,616				48,484		4,132

- Existing condenser water setpoint is 80 deg. F
 - Proposed condenser water setpoint is 55 deg. F
 - 2.5% decrease in energy consumption per degree Fahrenheit rise in temperature from http://apps1.eere.energy.gov/buildings/publications/pdfs/alliances/hea_chillers.is.pdf



Project Location: SUNY New Paltz
Project Number: 4013032.01
ECM-LNC3 Steam Trap Replacement

Assumptions	
Total Building Area with Steam Traps:	308,750 ft ²
Hours of Operation:	4,368 Hours
Estimated Steam Trap Density:	1.500 ft ² / Trap
Estimated Number of Traps:	206 Traps
Expected Failed Trap %:	15.0%
Expected No. of Traps upstream of control valves	20.0%
Estimated Trap Orifice:	0.250 in. dia
Low Pressure Traps, % of Total:	100%

From DOE's Industrial Technologies Program

Utility Data	
Natural Gas Cost/MMBTU	\$8.58
Equivalent Cost / Mlb:	\$8.11 \$/1000 lb

Steam Trap Calculations			
System Operating Pressure	Steam Loss Per Trap, lb/hr (From DOE)	Expected # of Failed Traps	Potential Pounds of Lost Steam
Low Pressure 15 PSI	54.7	6	1,475,390
			Potential Savings
			\$11,961

Equivalent Fuel Usage Calculation		
Assumed Boiler Efficiency	BTUs /lb of Steam generated (@15psig)	Equivalent Thermos of NG
73.5%	945.4	1,395 18,977

Total Trap Replacement Cost	\$5,464
------------------------------------	---------

Savings Summary	
Electricity Usage (kWh):	0
Gas Savings (Therms):	18,977
Energy Savings (MMBTU Source):	1,987
Cost Savings (\$):	\$ 11,961
Emissions Reduction (lb CO2):	231,229
Cost Estimate (\$):	\$ 5,464
Simple payback:	0.5

Assumptions:

- Number of traps based on national averages. Cost of steam based on New Paltz NG rates and steam pressure
- 15% failed trap rate is the most conservative value from the DOE for plants without ongoing maintenance of steam traps.
 - For further information refer to Steam Tip Sheet #1 - Inspect and Repair Steam Traps, published by the Department of Energy
- Cost of trap based on price listed in 2014 RS Means for 2" Thermostatic Trap
- Steam loss based on 15 psi steam and 0.25 in. dia. Orifice. Source: Repair Steam leaks publication from the New York State Energy Office, 1988
- Number of traps assumed to be all low pressure.
- Operating hours assume shutdown from April 15th to October 15
- Boiler Efficiency is based upon actual tested combustion efficiency, derated 10% for skin, condensate, and piping losses.



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-LNC4 Window AC Timer

Equipment		
Cooling System Capacity:	10,000	Btu/hr
Existing Cooling System Efficiency:	1.20	kW/ton
No. of Window AC Units	56	

Utility Costs	
Electricity:	\$0.090 kWh

Weather Data		Total Savings	
Avg Existing Hours (°F)	Proposed Hours	Cooling Energy Savings (kWh)	Electric Energy Savings (\$)
92.5	8	202	\$18
87.5	69	1,646	\$147
82.5	218	5,225	\$468
77.5	391	6,569	\$588
72.5	579	9,727	\$871
67.5	774	13,003	\$1,164
Total		36,170	\$3,239

Savings Summary	
Electricity Savings (kWh):	36,170
Gas Savings (Therms):	-
Energy Savings (MMBTU Source):	412.20
Cost Savings (\$):	\$ 3,239
Emissions Reduction (lb CO ₂):	73,814
Cost Estimate (\$):	\$ 3,754
Simple payback:	1.2

- Assumptions:**
- Energy savings calculated based on unit shutting off during unoccupied periods. A 30% reduction in operation hours due to occupancy controls has been assumed.
 - Bin Hours are for unoccupied hours based on 7AM-7PM Mon-Fri occupancy.



Project Name:	SUNY New Paltz
Project Number:	4013032.01
ECM-O&M1	Weatherization Upgrades - Summary

Savings Summary	
Estimated Cost to Implement	\$148,301
Site Electric Savings [kWh]	56,163
Site Heating Savings (therm)	29,314
Total Source Savings (MMBTU)	3,709
Cost Savings (\$)	\$ 31,161
Simple Payback [years]	4.76
Emissions Reduction (lb CO ₂):	471,810

Utility Costs	
Electricity:	\$0.107 /kWh
Natural Gas:	\$0.858 /Therm

	Savings [unit]	Savings [\$]
Electrical Consumption [kwh / yr]	56,163	\$ 6,023
Natural Gas Consumption [therms / yr]	29,314	\$ 25,139
Totals		\$ 31,161

Project Name: SUNY New Paltz
 Project Number: 4013032.01
 ECM: O&M Door Weatherization

Equipment	
Heating System Efficiency	78%
Cooling System COP	2.5

Weather Data	
Heating Degree Days	6,391
Cooling Degree Days	2,666
Average Wind Velocity	602 ft/min

Utility Costs	
Electricity:	0.107 \$/kWh
Natural Gas:	0.858 \$/therm

Building	Exterior Door Count	Infiltration Openings (sq. in.)			Adjustment Factors			Energy Savings Calculations				Annual Cost Savings					
		Threshold	Head	Jambs	Total Per.	Eff. of Opening	Fraction Infil. Avoidable	Fraction of Year Infil. Occurs	Typical Heat Loss Coeff. (Btu/yr/m ²)	Typical Heating Energy Savings (MBtu/yr/Door)	Total Heating Energy Savings (Therms/yr)	Typical Infiltration Cooling Loss Constant (Btu/yr/in ²)	Typical Cooling Energy Savings (MBtu/yr/Door)	Total Cooling Energy Savings (kWh/yr)	Typical Heating Savings (\$)	Typical Cooling Savings (\$)	Total Savings (\$)
Maintenance Warehouse	6	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	266	285,036	577	1,353.34	\$228	\$0	\$228
Sojourner Truth Library	8	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	355	285,036	577	1,353.34	\$304	\$145	\$450
College Hall, Shangho Hall	32	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	1,419	285,036	577	1,353.34	\$1,218	\$0	\$1,218
Van den Berg Hall	18	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	798	285,036	577	1,353.34	\$685	\$327	\$1,012
Caplan Hall	3	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	133	285,036	577	1,353.34	\$114	\$0	\$114
LeFevre Hall	5	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	222	285,036	577	1,353.34	\$190	\$0	\$190
Dubois Hall	6	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	266	285,036	577	1,353.34	\$228	\$0	\$228
Devo Hall	6	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	266	285,036	577	1,353.34	\$228	\$0	\$228
Scudder Hall	6	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	266	285,036	577	1,353.34	\$228	\$0	\$228
Beaver Hall	6	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	266	285,036	577	1,353.34	\$228	\$0	\$228
Bliss Hall	7	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	310	285,036	577	1,353.34	\$266	\$0	\$266
Fine Arts Building	23	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	1,109	285,036	577	1,353.34	\$951	\$454	\$1,405
Elling Gym	23	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	1,020	285,036	577	1,353.34	\$875	\$417	\$1,292
Gage Hall	8	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	355	285,036	577	1,353.34	\$304	\$0	\$304
Old Main	26	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	1,153	285,036	577	1,353.34	\$989	\$472	\$1,461
Crispell Hall	6	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	266	285,036	577	1,353.34	\$228	\$0	\$228
Bouton Hall	8	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	355	285,036	577	1,353.34	\$304	\$145	\$450
South Classroom Building	8	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	355	285,036	577	1,353.34	\$304	\$145	\$450
Old Library	4	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	177	285,036	577	1,353.34	\$152	\$73	\$225
Child Care Center	6	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	266	285,036	577	1,353.34	\$228	\$109	\$337
Service Building	18	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	798	285,036	577	1,353.34	\$685	\$0	\$685
Student Health Center	5	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	222	285,036	577	1,353.34	\$190	\$91	\$281
Hopfer Alumni Center	9	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	399	285,036	577	1,353.34	\$342	\$163	\$506
Faculty Office Building	8	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	355	285,036	577	1,353.34	\$304	\$145	\$450
Smiley Arts Building	25	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	1,109	285,036	577	1,353.34	\$951	\$454	\$1,405
Dorsky Museum	2	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	89	285,036	577	1,353.34	\$76	\$36	\$112
McKenna Theatre	5	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	222	285,036	577	1,353.34	\$190	\$91	\$281
Humanities	12	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	532	285,036	577	1,353.34	\$457	\$218	\$675
Jacobson Faculty Tower	10	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	443	285,036	577	1,353.34	\$381	\$181	\$562
Lenape Hall	6	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	266	285,036	577	1,353.34	\$228	\$109	\$337
Esopus Hall	9	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	399	285,036	577	1,353.34	\$342	\$163	\$506
Lecture Center	18	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	798	285,036	577	1,353.34	\$685	\$327	\$1,012
Athletic Center	17	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	754	285,036	577	1,353.34	\$647	\$308	\$955
Parker Theatre	10	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	443	285,036	577	1,353.34	\$381	\$181	\$562
Student Union Building	20	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	887	285,036	577	1,353.34	\$761	\$363	\$1,124
Coykendall Science Building	15	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	665	285,036	577	1,353.34	\$571	\$272	\$843
Haggerty Admin Building	10	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	443	285,036	577	1,353.34	\$381	\$181	\$562
Hasbrouck Dining Hall	20	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	887	285,036	577	1,353.34	\$761	\$363	\$1,124
Resnick Engineering Hall	5	2.25	2.25	10.5	15	0.375	90%	100%	683,295	4,435	222	285,036	577	1,353.34	\$190	\$91	\$281
Total Units	441										19,558			56,163			\$22,803

Total Savings Summary	
Site Electricity Savings (kWh):	56,163
Site Gas Savings (Therms):	19,558
Source Energy Savings (MMBTU):	2,688
Cost Savings (\$):	\$ 22,803

Assumptions:
 Typical Cooling Loss Coeff = specific heat of air (0.24 Btu/lb) x density of air (0.074, 1 lb/ft³), avg. velocity of wind x degree cooling hours x 24 (hr/day) x 60 (min/hr) / 144 (in²/ft²)
 Typical Heat Loss Coeff = specific heat of air (0.24 Btu/lb) x density of air (0.074, 1 lb/ft³), x avg. velocity of wind x degree heating hours x 24 (hr/day) x 60 (min/hr) / 144 (in²/ft²)



Project Name: SUNY New Paltz
 Project Number: 4013032.01
 ECM-O&MI Window Weatherization

Equipment	
Heating System Efficiency	78%
Cooling System COP	2.5

Weather Data	
Heating Degree Days	6,391
Cooling Degree Days	2,666
Average Wind Velocity	602 ft/min

Utility Costs	
Electricity:	0.107 \$/kWh
Natural Gas:	0.858 \$/therm

Building	Exterior Window Count	Infiltration Openings (sq. in.)					Adjustment Factors					Energy Savings Calculations					Annual Cost Savings		
		Threshold	Head	Jambs	Total Per.	Effectiveness Opening	Fraction Infil. Avoidable	Fraction of Year Infil. Occurs	Typical Heat Loss Coeff (Btu/yr/in ²)	Typical Heating Energy Savings (MBtu/yr/Window)	Total Heating Energy Savings (Therms/yr)	Typical Infiltration Cooling Loss Constant (Btu/yr/in ²)	Typical Cooling Energy Savings (MBtu/yr/Window)	Total Cooling Energy Savings (kWh/yr)	Typical Heating Savings (\$)	Typical Cooling Savings (\$)	Total Savings (\$)		
																		Typical Heating Energy Savings (MBtu/yr/Window)	Total Heating Energy Savings (Therms/yr)
College Hall, Shango Hall	20	0	0	0	15	0.375	90%	100%	683,295	4,435	887	285,036	577	577	\$761	\$0	\$761		
Capen Hall	20	0	0	0	15	0.375	90%	100%	683,295	4,435	887	285,036	577	577	\$761	\$0	\$761		
LeFevre Hall	20	0	0	0	15	0.375	90%	100%	683,295	4,435	887	285,036	577	577	\$761	\$0	\$761		
Dubois Hall	20	0	0	0	15	0.375	90%	100%	683,295	4,435	887	285,036	577	577	\$761	\$0	\$761		
Deyo Hall	20	0	0	0	15	0.375	90%	100%	683,295	4,435	887	285,036	577	577	\$761	\$0	\$761		
Scudder Hall	20	0	0	0	15	0.375	90%	100%	683,295	4,435	887	285,036	577	577	\$761	\$0	\$761		
Bever Hall	20	0	0	0	15	0.375	90%	100%	683,295	4,435	887	285,036	577	577	\$761	\$0	\$761		
Bliss Hall	20	0	0	0	15	0.375	90%	100%	683,295	4,435	887	285,036	577	577	\$761	\$0	\$761		
Gage Hall	20	0	0	0	15	0.375	90%	100%	683,295	4,435	887	285,036	577	577	\$761	\$0	\$761		
Crispell Hall	20	0	0	0	15	0.375	90%	100%	683,295	4,435	887	285,036	577	577	\$761	\$0	\$761		
Bouton Hall	20	0	0	0	15	0.375	90%	100%	683,295	4,435	887	285,036	577	577	\$761	\$0	\$761		
Total Units	220				15	0.375	90%	100%	683,295	4,435	887	285,036	577	9,757	\$761	\$0	\$8,371		

Total Savings Summary	
Site Electricity Savings (kWh):	0
Site Gas Savings (Therms):	9,757
Source Energy Savings (MMBTU):	1,022
Cost Savings (\$):	\$ 8,371

Assumptions.

Typical Cooling Loss Coeff = specific heat of air (0.24 btu/lb) x density of air (0.074, 1 lb/ft³) x avg. velocity of wind x degree cooling hours x 24 (hr/day) x 60 (min/hr) / 144 (in²/ft²)
 Typical Heat Loss Coeff = specific heat of air (0.24 btu/lb) x density of air (0.074, 1 lb/ft³) x avg. velocity of wind x degree heating hours x 24 (hr/day) x 60 (min/hr) / 144 (in²/ft²)

Project Name:	SUNY New Paltz
Project Number:	4013032.01
ECM-O&M2	Water Conservation

Utility Costs	
Electricity:	0.107 \$/kWh
Natural Gas:	0.858 \$/therm

Building	Annual Occupied Days	Full Time Occupants	Male Toilet Uses / Day	Male Urinal Uses / Day	Female Uses / Day	Lavatory Use (Min / use)	Existing Water Usage		Projected Water Usage		Hot Water Savings	
							Water Use, Gal	Annual (kGal)	Water Use, Gal	Annual (kGal)	Water Savings (kGal)	Energy Savings (MMBTU)
Maintenance Warehouse	251		4	0	4	0.25	4.7	0.0	2.0	0.0	0.0	0.0
Sojourner Truth Library	238		4	0	4	0.25	2.2	0.0	0.5	0.0	0.0	0.0
College Hall, Shango Hall	238	230	4	0	4	0.25	4.7	175	2.0	60	66.2	44.8
Van den berg Hall	238		4	0	4	0.25	2.2	0	0.5	0	0.0	0.0
Capen Hall	238	178	4	0	4	0.25	4.7	136	2.0	47	51.3	34.0
LeFevre Hall	238	178	4	0	4	0.25	4.7	136	2.0	47	51.3	34.0
Dubois Hall	238	211	4	0	4	0.25	4.7	161	2.0	55	60.8	40.4
Deyo Hall	238	204	4	0	4	0.25	4.7	155	2.0	53	58.7	39.0
Scudder Hall	238	204	4	0	4	0.25	4.7	155	2.0	53	58.7	39.0
Bevier Hall	238	220	4	0	4	0.25	4.7	168	2.0	58	63.4	42.1
Bliss Hall	238	207	4	0	4	0.25	4.7	158	2.0	54	59.6	39.6
Fine Arts Building	238		4	0	4	0.25	2.2	0	0.5	0	0.0	0.0
Elting Gym / Athletic Center	365	200	4	0	4	0.25	4.7	234	2.0	80	88.3	61.4
Gage Hall	238	322	4	0	4	0.25	4.7	245	2.0	84	92.7	61.6
Old Main	238		4	0	4	0.25	2.2	0	0.5	0	0.0	0.0
Crispell Hall	238	207	4	0	4	0.25	4.7	158	2.0	54	59.6	39.6
Bouton Hall	238	293	4	0	4	0.25	4.7	223	2.0	77	84.4	56.0
South Classroom Building	238		4	4	4	0.25	4.7	0	2.0	0	0.0	0.0
Old Library	238		4	0	4	0.25	2.2	0	0.5	0	0.0	0.0
Child Care Center	238		4	0	4	0.25	2.2	0	0.5	0	0.0	0.0
Service Building	238		4	0	4	0.25	2.2	0	0.5	0	0.0	0.0
Student Health Center	238		4	0	4	0.25	2.2	0	0.5	0	0.0	0.0
Hopfer Alumni Center	238		4	0	4	0.25	2.2	0	0.5	0	0.0	0.0
Faculty Office Building	238		4	0	4	0.25	2.2	0	0.5	0	0.0	0.0
Smiley Arts Building	238		4	0	4	0.25	2.2	0	0.5	0	0.0	0.0
Dorsky Museum	238		4	0	4	0.25	2.2	0	0.5	0	0.0	0.0
McKenna Theatre	238		4	0	4	0.25	2.2	0	0.5	0	0.0	0.0
Humanities	238		4	0	4	0.25	2.2	0	0.5	0	0.0	0.0
Jacobson Faculty Tower	238		4	0	4	0.25	2.2	0	0.5	0	0.0	0.0
Lenape Hall	238	234	4	0	4	0.25	4.7	178	2.0	61	67.4	44.8
Esopus Hall	238	234	4	0	4	0.25	4.7	178	2.0	61	67.4	44.8
Lecture Center	238		4	0	4	0.25	2.2	0	0.5	0	0.0	0.0
Athletic Center	238		4	0	4	0.25	4.7	0	2.0	0	0.0	0.0
Parker Theatre	238		4	0	4	0.25	2.2	0	0.5	0	0.0	0.0
Student Union Building	238		0.25	0	0.25	0.25	2.2	0	0.5	0	0.0	0.0
Coykendall Science Building	238		4	0	4	0.25	2.2	0	0.5	0	0.0	0.0
Haggerty Admin Building	238		4	0	4	0.25	2.2	0	0.5	0	0.0	0.0
Hasbrouck Dining Hall	238		0.25	0	0.25	0.25	2.2	0	0.5	0	0.0	0.0
Resnick Engineering Hall	238		4	0	4	0.25	2.2	0	0.5	0	0.0	0.0
Faculty	238	423	4	0	4	0.25	2.2	221	0.5	50	85.5	59.4
Commuter Students	238	2,368	4	0	4	0.25	2.2	1,240	0.5	282	479.0	332.9
Total Units		2,922									1,494.3	1,013.3

Savings Summary	
Site Electricity Savings (kWh):	0
Site Gas Savings (Therms):	10,133
Energy Savings (MMBTU Source):	1,061
Cost Savings (\$):	\$ 8,695
Emissions Reduction (lb CO ₂):	123,476
Cost Estimate (\$):	\$ 32,541
Simple payback:	3.7

Assumptions:

- Site water use based on floor plans, double occupancy
- Site Fixture count based on estimate from floor plan
- Residence Hall occupancy based on check-in and check-out dates for 2013-2014 Academic Calendar.
- Faculty savings calculated on 347 Full-time faculty and 302 part-time (transient) faculty. (Common Data Set 2013-2014 Instructional Faculty and Class Size)
- Commuter Students based on enrollment minus dormitory occupancy (Common Data Set 2013-2014 Instructional Faculty and Class Size)



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-O&M3 Reduced Campus Building AHU schedules

Building	Prior Existing Conditions			Revised Conditions			Savings Summary			Utility Costs	
	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Building Area (SF)	Heating Energy Savings (Therm/SF)	Electric Energy Savings (kWh/SF)	Electricity: \$/kWh	Natural Gas: \$/Therm
Coykendall Hall	138,510	101,079	241,877	126,968	88,863	234,665	21,057	0.58	0.89		
Fine Arts Building	198,243	132,032	284,122	187,229	123,079	275,064	67,616	0.13	0.30		
Service Building	13,917	10,408	22,349	12,061	9,125	19,030	8,674	0.15	0.60		
Vandenberg Hall	145,494	32,017	70,736	136,400	29,155	69,352	88,441	0.03	0.12		
Humanities Bldg	100,391	71,606	122,449	64,806	39,561	52,235	69,634	0.46	1.52		
Parker Theatre	83,968	31,739	60,389	62,181	21,473	51,046	103,813	0.10	0.30		
Student Union Bldg	215,590	58,837	45,417	154,461	44,215	38,997	15,755	0.93	4.29		
Hasbrouck Dining Hall	87,296	26,852	45,918	71,760	21,091	41,127	70,778	0.08	0.29		
Haggerty Admin Bldg	261,889	80,557	137,755	215,281	63,272	123,382	83,597	0.21	0.73		
Totals	1,245,297	545,128	1,031,011	1,031,148	439,834	904,898	529,365	0.20	0.64		

Building	Potential Energy Savings		
Building Area (SF)	Heating Energy Savings (Therm)	Electric Energy Savings (kWh)	Electric Energy Savings (kWh)
Resnick Engineering Building	30,015	5,970	19,293
Athletic Center	60366	12,007	38,802
Lecture Center	61,262	12,185	39,378
Smiley/Dorsky	68,035	13,533	43,731
Faculty Office Building	33,180	6,600	21,327
Student Health Center	11,787	2,345	7,576
Child Care Center	14,103	2,805	9,065
Old Library	67,500	13,426	43,387
South Classroom Building	5,906	1,175	3,796
Elting Gym	18,216	3,623	11,709
Sojourner Truth Library	110,983	22,075	71,337
Totals	481,353	95,744	309,401

Savings Summary	
Site Electricity Savings (kWh):	649,663
Site Gas Savings (Therms):	201,038
Energy Savings (MMBTU Source):	28,452
Cost Savings (\$):	\$ 230,573
Emissions Reduction (lb CO ₂):	3,775,433
Cost Estimate (\$):	\$ 945,590
Simple payback:	4.1

Assumptions:
 - Assume that 7 control points are needed per AHU, plus a controller and Networking
 - Industry standard of \$1000 per point used for controls costs, plus 25% coverage to cover existing conditions
 - For new buildings, the same level of average savings per building area can be assumed in all other buildings.



Project Name: SUNY New Paltz
 Project Number: 4013032.01
 ECM-O&M3 Coykendall Science Building AHU schedule

Unit:	AHU details							Totals
	AHU-1	AHU-2	AHU-3	AHU-5	AHU-7			
Motor Nameplate Size	15	60	15	7.5	7.5	105		
Calculated Air Flow: (cfm)	9,000	42,000	13,000	15,200	16,000	95,200		
% Outdoor Air Flow:	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%		
Fan Static Efficiency: (%)	53%	53%	53%	53%	53%	53%		
Total Static Pressure: (in)	1.50	1.50	1.50	1.50	1.50	1.50		
Calculated Fan Power: (BHP)	4.0	18.7	5.8	6.8	7.1	42		
Calculated Fan Power: (kW)	2.99	13.95	4.32	5.05	5.31	32		
Calculated OA Flow: (cfm)	9,000	42,000	13,000	15,200	16,000	95,200		

Heating/Cooling	
Cooling Supply Enthalpy:	25.3 Btu/lb
Heating Supply Temp:	70 °F
Cooling System Efficiency:	0.857 kW/ton
Heating System Efficiency:	78%

Utility Costs	
Natural Gas:	\$0.86 /Therm
Electricity:	\$0.09 / kWh

Operational Hours			
Existing (AHUs):	6am	to	6pm
Proposed (all):	7am	to	6pm
	6am	to	6pm
	7am	to	6pm

Weather Data		Existing Conditions				Proposed Conditions					
ΔT (°F)	Mid-pt (°F)	Total Run Hours	h (Btu/lb)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Total Run Hours	h (Btu/lb)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)
90 to 95	92.5	12	36.3	379	-	4,026	12	36.3	379	-	4,026
85 to 90	87.5	95	37.3	3,004	-	34,776	95	37.3	3,004	-	34,776
80 to 85	82.5	256	35	8,096	-	75,699	256	35	8,096	-	75,699
75 to 80	77.5	286	32.3	9,044	-	60,945	284	32.3	8,981	-	60,519
70 to 75	72.5	337	30.1	10,657	-	49,129	327	30	10,341	-	46,671
65 to 70	67.5	386	26.8	12,207	-	17,301	364	26.5	11,511	-	12,974
60 to 65	62.5	449	24.3	14,199	-	-	401	23.9	12,681	-	-
55 to 60	57.5	400	21.6	12,649	6,591	-	364	21.4	11,511	5,998	-
50 to 55	52.5	381	18.4	12,048	8,789	-	343	18.2	10,847	7,912	-
45 to 50	47.5	295	16.4	9,329	8,749	-	271	16.3	8,570	8,037	-
40 to 45	42.5	381	14.5	12,048	13,811	-	347	14.4	10,973	12,578	-
35 to 40	37.5	298	12.7	9,424	12,766	-	256	12.6	8,096	10,967	-
30 to 35	32.5	231	10.8	7,305	11,419	-	206	10.8	6,514	10,183	-
25 to 30	27.5	163	8.8	5,155	9,132	-	140	8.7	4,427	7,843	-
20 to 25	22.5	153	7.2	4,838	9,580	-	126	7.1	3,985	7,889	-
15 to 20	17.5	92	5.5	2,909	6,367	-	80	5.5	2,530	5,536	-
10 to 15	12.5	61	3.8	1,929	4,623	-	58	3.8	1,834	4,396	-
5 to 10	7.5	46	2.6	1,455	3,790	-	41	2.6	1,297	3,378	-
0 to 5	2.5	32	1.3	1,012	2,847	-	24	1.3	759	2,135	-
-5 to 0	-2.5	13	0	411	1,242	-	11	0	348	1,051	-
-10 to -5	-7.5	6	-1.4	190	613	-	3	-1.3	95	306	-
-15 to -10	-12.5	7	-2.6	221	761	-	6	-2.6	190	652	-
Totals		4,380	-	138,510	101,079	241,877	4,015	-	126,968	88,863	234,665

Savings Summary	
Fan Energy Savings (kWh, \$):	11,543 \$1,039
Heating Energy Savings (therm, \$):	12,216 \$10,506
Cooling Energy Savings (kWh, \$):	7,212 \$649
Total Cost Savings (\$):	\$12,194
Estimated BAS Cost	\$43,750
Simple Payback	3.6

Assumptions:
 - Assume that 7 control points are needed per AHU, plus a controller and Networking
 - Industry standard of \$1000 per point used for controls costs, plus 25% coverage to cover existing conditions



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-O&M3 Fine Arts Building AHU schedule

AHU details						
Unit:	AHU-2	AHU-3	AHU-4	AHU-5	AHU-6	Totals
Motor Nameplate Size	15	15	15	15	5	65
Calculated Air Flow: (cfm)	18,100	22,500	19,000	15,850	4,700	80,150
% Outdoor Air Flow:	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%
Fan Static Efficiency: (%)	53%	53%	53%	53%	53%	53%
Total Static Pressure: (in)	1.70	1.70	1.70	1.70	1.70	
Calculated Fan Power: (BHP)	9.1	11.4	9.6	8.0	2.4	40
Calculated Fan Power: (kW)	6.81	8.47	7.15	5.97	1.77	30
Calculated OA Flow: (cfm)	18,100	22,500	19,000	15,850	4,700	80,150

Heating/Cooling	
Cooling Supply Enthalpy:	25.3 Btu/lb
Heating Supply Temp:	70 °F
Cooling System Efficiency:	0.857 kW/ton
Heating System Efficiency:	78%

Utility Costs	
Natural Gas:	\$0.86 / Therm
Electricity:	\$0.09 / kWh

Operational Hours				
Existing (AHUs):	6am to 6am	12am to 6am	Mon - Fri	Mon - Fri
Proposed (all):	6am to 6am	11pm to 6am	Mon - Fri	Mon - Fri

Weather Data	Existing Conditions				Proposed Conditions				
	Total Run Hours	h (Btu/lb)	Fan Energy (kWh)	Heating Energy (therm)	Total Run Hours	h (Btu/lb)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)
90 to 95	12	36.3	362	-	12	36.3	362	-	3,389
85 to 90	98	37.2	2,957	-	98	37.2	2,957	-	29,951
80 to 85	311	35.2	9,384	-	311	35.2	9,384	-	79,027
75 to 80	383	32.5	11,557	-	379	32.4	11,436	-	68,971
70 to 75	501	30.6	15,117	-	481	30.5	14,514	-	63,993
65 to 70	594	27.5	17,923	-	559	27.4	16,867	-	29,734
60 to 65	686	24.6	20,699	-	645	24.5	19,462	-	-
55 to 60	638	21.9	19,251	8,850	597	21.8	18,014	8,282	-
50 to 55	583	18.9	17,591	11,322	544	18.8	16,415	10,565	-
45 to 50	465	16.7	14,031	11,611	434	16.6	13,095	10,837	-
40 to 45	555	14.6	16,747	16,938	528	14.5	15,932	16,114	-
35 to 40	499	12.6	15,057	17,998	464	12.6	14,001	16,735	-
30 to 35	382	10.9	11,526	15,897	347	10.8	10,470	14,441	-
25 to 30	231	8.8	6,970	10,895	217	8.8	6,548	10,235	-
20 to 25	233	7.2	7,031	12,282	217	7.1	6,548	11,439	-
15 to 20	151	5.5	4,556	8,798	142	5.5	4,285	8,273	-
10 to 15	93	3.8	2,806	5,934	87	3.8	2,625	5,552	-
5 to 10	75	2.5	2,263	5,202	70	2.5	2,112	4,855	-
0 to 5	46	1.2	1,388	3,446	43	1.2	1,297	3,221	-
-5 to 0	19	0	573	1,529	16	0	483	1,287	-
-10 to -5	8	-1.4	241	688	7	-1.4	211	602	-
-15 to -10	7	-2.6	211	641	7	-2.6	211	641	-
Totals	6,570	-	198,243	132,032	6,205	-	187,229	123,079	275,064

Savings Summary	
Fan Energy Savings (kWh, \$):	11,013 \$991
Heating Energy Savings (therm, \$):	8,953 \$7,700
Cooling Energy Savings (kWh, \$):	9,057 \$815
Total Cost Savings (\$):	\$9,506
Estimated BAS Cost	\$43,750
Simple Payback	4.6

Assumptions:
 - Assume that 7 control points are needed per AHU, plus a controller and networking
 - Industry standard of \$1000 per point used for controls costs, plus 25% overage to cover existing conditions



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-O&M3 Service Building AHU schedule

AHU details				
Unit:	HV-1	AC-1	AC-2	Totals
Motor Nameplate Size	3	2		7
Calculated Air Flow: (cfm)	4,500	3,000	3,000	10,500
% Outdoor Air Flow:	100.0%	100.0%	100.0%	
Fan Static Efficiency: (%)	53%	53%	53%	
Total Static Pressure: (in)	1.50	1.50	1.50	
Calculated Fan Power: (BHP)	2.0	1.3	1.3	5
Calculated Fan Power: (kW)	1.49	1.00	1.00	3
Calculated OA Flow: (cfm)	4,500	3,000	3,000	10,500

Heating/Cooling	
Cooling Supply Enthalpy:	25.3 Btu/lb
Heating Supply Temp:	70 °F
Cooling System Efficiency:	0.857 kW/ton
Heating System Efficiency:	78%

Utility Costs	
Natural Gas:	\$0.86 /Therm
Electricity:	\$0.09 /kWh

Operational Hours				
Existing (AHUs):	5am	to	8pm	Mon - Fri
Proposed (all):	5am	to	6pm	Mon - Fri

Weather Data	Existing Conditions				Proposed Conditions				
	Total Run Hours	h (Btu/lb)	Fan Energy (kWh)	Heating Energy (therm)	Total Run Hours	h (Btu/lb)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)
90 to 95	4	36.3	14	-	4	36.3	14	-	148
85 to 90	60	37.5	209	-	59	37.6	206	-	2,442
80 to 85	213	35.2	743	-	181	34.9	631	-	5,842
75 to 80	258	32.3	900	-	212	32.2	739	-	4,911
70 to 75	273	30.2	952	-	230	30.1	802	-	3,698
65 to 70	353	27.1	1,231	-	316	27.2	1,102	-	1,989
60 to 65	421	24.3	1,468	-	357	24.4	1,245	-	-
55 to 60	379	21.9	1,322	689	327	21.9	1,141	594	-
50 to 55	368	18.8	1,284	936	327	18.7	1,141	832	-
45 to 50	281	16.5	980	919	230	16.5	802	752	-
40 to 45	361	14.5	1,259	1,443	316	14.6	1,102	1,263	-
35 to 40	282	12.8	984	1,332	247	12.8	862	1,167	-
30 to 35	215	10.8	750	1,172	187	10.8	652	1,020	-
25 to 30	143	9	499	884	129	9.1	450	797	-
20 to 25	145	7.2	506	1,001	131	7.3	457	905	-
15 to 20	88	5.6	307	672	72	5.6	251	550	-
10 to 15	46	3.7	160	385	41	3.7	143	343	-
5 to 10	50	2.5	174	454	42	2.6	146	382	-
0 to 5	30	1.3	105	294	30	1.3	105	294	-
-5 to 0	7	0.1	24	74	7	0.1	24	74	-
-10 to -5	5	-1.4	17	56	5	-1.4	17	56	-
-15 to -10	8	-2.6	28	96	8	-2.6	28	96	-
Totals	3,990	-	13,917	10,408	22,349	-	12,061	9,125	19,030

Savings Summary	
Fan Energy Savings (kWh, \$):	1,856 \$167
Heating Energy Savings (therm, \$):	1,283 \$1,104
Cooling Energy Savings (kWh, \$):	3,320 \$299
Total Cost Savings (\$):	\$1,569
Estimated BAS Cost	\$26,250
Simple Payback	16.7

Assumptions:
 - Assume that 7 control points are needed per AHU, plus a controller and Networking
 - Industry standard of \$1000 per point used for controls costs, plus 25% coverage to cover existing conditions



Project Name: SUNY New Paltz
 Project Number: 4013032.01
 ECM-O&M3 Vandenberg Hall

Unit:	AHU details						Totals
	AHU-2	AHU-3	AHU-4	AHU-5	AHU-6		
Motor Nameplate Size	15	15	15	15	15	75	
Calculated Air Flow: (cfm)	15,000	15,000	15,000	15,000	15,000	75,000	
% Outdoor Air Flow:	29.3%	29.3%	29.3%	29.3%	29.3%	n/a	
Fan Static Pressure: (%)	5.5	5.5%	5.5%	5.5%	5.5%	n/a	
Total Static Pressure: (in)	1.5	1.5	1.5	1.5	1.5	n/a	
Calculated Fan Power: (BHP)	6.7	6.7	6.7	6.7	6.7	33	
Calculated Fan Power: (kW)	4.98	4.98	4.98	4.98	4.98	25	
Calculated OA Flow: (cfm)	4,395	4,395	4,395	4,395	4,395	21,975	

Heating/Cooling	
Cooling Supply Enthalpy:	25.3 Btu/lb
Heating Supply Temp:	70 °F
Cooling System Efficiency:	0.857 kW/ton
Heating System Efficiency:	78%

Utility Costs	
Natural Gas:	\$0.86 /Therm
Electricity:	\$0.09 / kWh

Operational Hours			
Existing:	5am	to	9pm
Proposed:	6am	to	9pm
			Sun-Sat
			Sun-Sat

Weather Data	Existing Conditions				Proposed Conditions							
	ΔT (°F)	Mid-pt (°F)	Total Run Hours	h (Btu/lb)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Total Run Hours	h (Btu/lb)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)
90 to 95	92.5	12	36.3	299	-	929	12	36.3	299	-	929	-
85 to 90	87.5	98	37.2	2,442	-	8,212	98	37.2	2,442	-	8,212	-
80 to 85	82.5	307	35.2	7,648	-	21,388	307	35.2	7,648	-	21,388	-
75 to 80	77.5	368	32.3	9,168	-	18,101	368	32.3	9,168	-	18,101	-
70 to 75	72.5	442	30.4	11,012	-	15,810	430	30.3	10,713	-	15,077	-
65 to 70	67.5	505	27.1	12,581	-	6,295	480	27	11,958	-	5,644	-
60 to 65	62.5	595	24.4	14,823	-	-	562	24.3	14,001	-	-	-
55 to 60	57.5	560	21.8	13,951	2,130	-	516	21.7	12,855	1,963	-	-
50 to 55	52.5	509	18.8	12,681	2,710	-	468	18.6	11,659	2,492	-	-
45 to 50	47.5	403	16.6	10,040	2,759	-	383	16.5	9,542	2,622	-	-
40 to 45	42.5	505	14.6	12,581	4,226	-	468	14.5	11,659	3,916	-	-
35 to 40	37.5	437	12.6	10,887	4,321	-	394	12.6	9,816	3,896	-	-
30 to 35	32.5	319	10.9	7,947	3,640	-	287	10.8	7,150	3,275	-	-
25 to 30	27.5	216	8.8	5,381	2,793	-	195	8.8	4,858	2,522	-	-
20 to 25	22.5	212	7.2	5,282	3,064	-	187	7.1	4,659	2,703	-	-
15 to 20	17.5	131	5.5	3,264	2,093	-	122	5.5	3,039	1,949	-	-
10 to 15	12.5	78	3.8	1,943	1,365	-	73	3.8	1,819	1,277	-	-
5 to 10	7.5	69	2.5	1,719	1,312	-	63	2.5	1,570	1,198	-	-
0 to 5	2.5	43	1.3	1,071	883	-	36	1.2	897	739	-	-
-5 to 0	-2.5	14	0	349	309	-	13	0	324	287	-	-
-10 to -5	-7.5	9	-1.4	224	212	-	6	-1.4	149	141	-	-
-15 to -10	-12.5	8	-2.6	199	201	-	7	-2.6	174	176	-	-
Totals		5,840	-	145,494	32,017	70,736	5,475	-	136,400	29,155	69,352	69,352

Savings Summary	
Fan Energy Savings (kWh, \$):	9,093 \$818
Heating Energy Savings (therm, \$):	2,862 \$2,462
Cooling Energy Savings (kWh, \$):	1,384 \$125
Total Cost Savings (\$):	\$3,405
Estimated BAS Cost	\$43,750
Simple Payback	12.9

Assumptions:
 - Assume that 7 control points are needed per AHU, plus a controller and networking
 - Industry standard of \$1000 per point used for controls costs, plus 25% overage to cover existing conditions



Project Name: SUNY New Paltz
 Project Number: 4013032.01
 ECM-O&M3 Humanities Building AHU schedule

AHU details				
Unit:	HS-1	HS-3	HS-4	Totals
Motor Nameplate Size	10	1	10	21
Calculated Air Flow: (cfm)	14,000	1,500	13,000	28,500
% Outdoor Air Flow:	100.0%	100.0%	100.0%	
Fan Static Efficiency: (%)	53%	53%	53%	
Total Static Pressure: (in)	1.50	1.50	1.50	
Calculated Fan Power: (BHP)	6.2	0.7	5.8	13
Calculated Fan Power: (kW)	4.65	0.50	4.32	9
Calculated OA Flow: (cfm)	14,000	1,500	13,000	28,500

Heating/Cooling	
Cooling Supply Enthalpy:	25.3 Btu/lb
Heating Supply Temp:	70 °F
Cooling System Efficiency:	0.857 kW/ton
Heating System Efficiency:	78%

Utility Costs	
Natural Gas:	\$0.86 /Therm
Electricity:	\$0.09 / kWh

Operational Hours				
Existing (AHUs):	12am to 6am	6am to 10pm	10pm to 12am	Sun-Sat
Proposed (all):				M-F
Proposed (all):				Sat-Sun

Weather Data		Existing Conditions				Proposed Conditions					
ΔT (°F)	Mid-pt (°F)	Total Run Hours	h (Btu/lb)	Fan Energy (kW/h)	Heating Energy (therm)	Total Run Hours	h (Btu/lb)	Fan Energy (kW/h)	Heating Energy (therm)	Cooling Energy (kW/h)	
90 to 95	92.5	12	36.3	114	-	1,205	12	36.3	114	-	613
85 to 90	87.5	98	37.2	928	-	10,650	98	37.2	928	-	5,418
80 to 85	82.5	311	35.2	2,944	-	28,101	310	35.2	2,935	-	14,251
75 to 80	77.5	391	32.6	3,702	-	26,018	374	32.4	3,541	-	12,313
70 to 75	72.5	579	31	5,481	-	30,042	452	30.4	4,279	-	10,668
65 to 70	67.5	774	28.2	7,328	-	20,311	517	27.2	4,894	-	4,493
60 to 65	62.5	911	25.2	8,624	-	-	588	24.3	5,567	-	-
55 to 60	57.5	885	22.3	8,378	-	-	550	21.7	5,207	-	-
50 to 55	52.5	837	19.4	7,924	5,780	-	496	18.6	4,696	3,245	-
45 to 50	47.5	604	17	5,718	5,363	-	398	16.5	3,768	3,348	-
40 to 45	42.5	756	14.9	7,157	8,204	-	486	14.5	4,601	4,996	-
35 to 40	37.5	747	12.8	7,072	9,580	-	423	12.6	4,005	5,139	-
30 to 35	32.5	553	10.9	5,235	8,183	-	306	10.8	2,897	4,290	-
25 to 30	27.5	374	9	3,541	6,272	-	203	8.7	1,922	3,225	-
20 to 25	22.5	337	7.3	3,190	6,317	-	193	7.1	1,827	3,427	-
15 to 20	17.5	214	5.6	2,026	4,434	-	128	5.5	1,212	2,512	-
10 to 15	12.5	127	3.9	1,202	2,882	-	76	3.8	719	1,634	-
5 to 10	7.5	110	2.6	1,041	2,713	-	67	2.5	634	1,565	-
0 to 5	2.5	77	1.2	729	2,051	-	38	1.2	360	959	-
-5 to 0	-2.5	33	0	312	944	-	14	0	133	379	-
-10 to -5	-7.5	20	-1.4	189	612	-	5	-1.4	47	145	-
-15 to -10	-12.5	10	-2.6	95	326	-	7	-2.6	66	216	-
Totals		8,760	-	82,931	68,026	116,326	5,741	-	54,350	37,652	47,757

Savings Summary	
Fan Energy Savings (kWh, \$):	28,581 \$2,572
Heating Energy Savings (therm, \$):	30,374 \$26,122
Cooling Energy Savings (kWh, \$):	68,570 \$6,171
Total Cost Savings (\$):	\$34,865
Estimated BAS Cost	\$26,250
Simple Payback	0.8

Assumptions:
 - Assume that 7 control points are needed per AHU, plus a controller and Networking
 - Industry standard of \$1000 per point used for controls costs, plus 25% overage to cover existing conditions



Project Name: SUNY New Paltz
 Project Number: 4013032.01
 ECM-O&M3 Humanities Building AHU schedule

AHU details			
Unit:	HS-5	HS-6	Totals
Motor Nameplate Size	2	2	4
Calculated Air Flow: (cfm)	3,000	3,000	6,000
% Outdoor Air Flow:	50.0%	50.0%	
Fan Static Efficiency: (%)	53%	53%	
Fan Static Pressure: (in)	1.50	1.50	
Total Static Pressure: (BHP)	1.3	1.3	3
Calculated Fan Power: (kW)	1.00	1.00	2
Calculated OA Flow: (cfm)	1,500	1,500	3,000

Heating/Cooling	
Cooling Supply Enthalpy:	25.3 Btu/lb
Heating Supply Temp:	70 °F
Cooling System Efficiency:	0.857 kW/ton
Heating System Efficiency:	78%

Utility Costs	
Natural Gas:	\$0.86 /Therm
Electricity:	\$0.09 / kWh

Operational Hours			
Existing (AHUs):	12am to 6am	12am to 5pm	Sun-Sat M-F
Proposed (all):	6am to 7am	10pm to 5pm	Sat-Sun

Weather Data		Existing Conditions			Proposed Conditions						
ΔT (°F)	Mid-pt (°F)	Total Run Hours	h (Btu/lb)	Fan Energy (kW/h)	Heating Energy (therm)	Cooling Energy (kW/h)	Total Run Hours	h (Btu/lb)	Fan Energy (kW/h)	Heating Energy (therm)	Cooling Energy (kW/h)
90 to 95	92.5	12	36.3	24	-	63	11	36.2	22	-	58
85 to 90	87.5	98	37.2	195	-	561	92	37.3	183	-	531
80 to 85	82.5	311	35.2	620	-	1,479	286	35.3	570	-	1,374
75 to 80	77.5	391	32.6	779	-	1,369	342	32.4	682	-	1,165
70 to 75	72.5	579	31	1,154	-	1,581	398	30.3	793	-	953
65 to 70	67.5	774	28.2	1,543	-	1,069	468	27.1	933	-	398
60 to 65	62.5	911	25.2	1,816	-	-	549	24.3	1,094	-	-
55 to 60	57.5	885	22.3	1,764	230	-	504	21.7	1,005	131	-
50 to 55	52.5	837	19.4	1,668	304	-	457	18.7	911	166	-
45 to 50	47.5	604	17	1,204	282	-	371	16.5	739	173	-
40 to 45	42.5	756	14.9	1,507	432	-	453	14.5	903	259	-
35 to 40	37.5	747	12.8	1,489	504	-	371	12.6	739	250	-
30 to 35	32.5	553	10.9	1,102	431	-	277	10.8	552	216	-
25 to 30	27.5	374	9	745	330	-	186	8.8	371	164	-
20 to 25	22.5	337	7.3	672	332	-	172	7.2	343	170	-
15 to 20	17.5	214	5.6	427	233	-	120	5.5	239	131	-
10 to 15	12.5	127	3.9	253	152	-	69	3.8	138	82	-
5 to 10	7.5	110	2.6	219	143	-	59	2.5	118	77	-
0 to 5	2.5	77	1.2	153	108	-	36	1.2	72	50	-
-5 to 0	-2.5	33	0	66	50	-	13	0	26	20	-
-10 to -5	-7.5	20	-1.4	40	32	-	5	-1.4	10	8	-
-15 to -10	-12.5	10	-2.6	20	17	-	7	-2.6	14	12	-
Totals		8,760	-	17,459	3,580	6,122	5,246	-	10,456	1,909	4,478

Savings Summary	
Fan Energy Savings (kWh, \$):	7,004 \$630
Heating Energy Savings (therm, \$):	1,671 \$1,437
Cooling Energy Savings (kWh, \$):	1,645 \$148
Total Cost Savings (\$):	\$2,216
Estimated BAS Cost Simple Payback	\$17,500 7.9

Assumptions:
 - Assume that 7 control points are needed per AHU, plus a controller and Networking
 - Industry standard of \$1000 per point used for controls costs, plus 25% overage to cover existing conditions



Project Name: SUNY New Paltz
 Project Number: 4013032.01
 ECM-O&M3 Parker Theater AHU schedule

AHU details		AC-1	AC-2	AC-4	AC-5	Totals
Unit:		1	8	2		11
Motor Nameplate Size		1,050	1,500	3,000		16,800
Calculated Air Flow: (cfm)		50.0%	50.0%	50.0%		53%
% Outdoor Air Flow:		53%	53%	53%		53%
Fan Static Efficiency: (%)		1.50	1.50	1.75	1.4	
Total Static Pressure: (in)		0.5	0.7	5.8	1.2	8
Calculated Fan Power: (BHP)		0.35	0.50	4.36	0.93	6
Calculated Fan Power: (kW)		52.5	750	5,625	1,500	8,400
Calculated OA Flow: (cfm)						

Heating/Cooling		Btu/lb
Cooling Supply Enthalpy:		25.3
Heating Supply Temp:		70 °F
Cooling System Efficiency:		0.857 kW/ton
Heating System Efficiency:		78%

Utility Costs		\$/Therm
Natural Gas:		\$0.86 /Therm
Electricity:		\$0.09 / kWh

Operational Hours			
Existing (AHUs):	6am to 7am	12am to 11pm	Sun-Sat
Proposed (all):			Sun-Sat

Weather Data	Existing Conditions				Proposed Conditions						
	Mid-pt (°F)	Total Run Hours	h (Btu/lb)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Total Run Hours	h (Btu/lb)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)
90 to 95	92.5	12	36.3	74	-	355	12	36.3	74	-	355
85 to 90	87.5	98	37.2	601	-	3,139	98	37.2	601	-	3,139
80 to 85	82.5	311	35.2	1,909	-	8,282	310	35.2	1,902	-	8,256
75 to 80	77.5	383	32.5	2,350	-	7,408	368	32.3	2,258	-	6,919
70 to 75	72.5	501	30.6	3,075	-	7,121	440	30.3	2,700	-	5,897
65 to 70	67.5	594	27.5	3,645	-	3,472	504	27.1	3,093	-	2,401
60 to 65	62.5	686	24.6	4,210	-	-	573	24.3	3,516	-	-
55 to 60	57.5	638	21.9	3,915	928	-	531	21.7	3,259	772	-
50 to 55	52.5	583	18.9	3,578	1,187	-	482	18.6	2,958	981	-
45 to 50	47.5	465	16.7	2,854	1,217	-	390	16.5	2,393	1,021	-
40 to 45	42.5	555	14.6	3,406	1,775	-	476	14.5	2,921	1,522	-
35 to 40	37.5	499	12.6	3,062	1,886	-	410	12.6	2,516	1,550	-
30 to 35	32.5	382	10.9	2,344	1,666	-	295	10.8	1,810	1,287	-
25 to 30	27.5	231	8.8	1,418	1,142	-	193	8.7	1,184	954	-
20 to 25	22.5	233	7.2	1,430	1,287	-	187	7.1	1,148	1,033	-
15 to 20	17.5	151	5.5	927	922	-	122	5.5	749	745	-
10 to 15	12.5	93	3.8	571	622	-	74	3.8	454	495	-
5 to 10	7.5	75	2.5	460	545	-	65	2.5	399	473	-
0 to 5	2.5	46	1.2	282	361	-	37	1.2	227	290	-
-5 to 0	-2.5	19	0	117	160	-	13	0	80	110	-
-10 to -5	-7.5	8	-1.4	49	72	-	5	-1.4	31	45	-
-15 to -10	-12.5	7	-2.6	43	67	-	7	-2.6	43	67	-
Totals		6,570	-	40,320	13,837	29,777	5,592	-	34,318	11,344	26,968

Savings Summary	
Fan Energy Savings (kWh, \$):	6,002 \$540
Heating Energy Savings (therm, \$):	2,493 \$2,144
Cooling Energy Savings (kWh, \$):	2,809 \$253
Total Cost Savings (\$):	\$2,937
Estimated BAS Cost	\$35,000
Simple Payback	11.9

Assumptions:
 - Assume that 7 control points are needed per AHU, plus a controller and Networking
 - Industry standard of \$1000 per point used for controls costs, plus 25% average to cover existing conditions



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-O&M3 Parker Theater AHU schedule

AHU details	
Unit:	AC-3 Totals
Motor Nameplate Size	10
Calculated Air Flow: (cfm)	15,000
% Outdoor Air Flow:	50.0%
Fan Static Efficiency: (%)	53%
Total Static Pressure: (in)	1.5
Calculated Fan Power: (BHP)	6.7
Calculated Fan Power: (kW)	4.98
Calculated OA Flow: (cfm)	7,500

Operational Hours	
Existing:	5am-11pm M-F / 5am-12am Sat-Sun
Proposed:	6am-9pm M-F / 7am-10pm Sat-Sun

Heating/Cooling	
Cooling Supply Enthalpy:	25.3 Btu/lb
Heating Supply Temp:	70 °F
Cooling System Efficiency:	0.857 kW/ton
Heating System Efficiency:	78%

Utility Costs	
Natural Gas:	\$0.86 / Therm
Electricity:	\$0.09 / kWh

Weather Data	Existing Conditions				Proposed Conditions						
	ΔT (°F)	Mid-pt (°F)	Total Run Hours	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Total Run Hours	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	
90 to 95	92.5	92.5	12	36.3	60	317	12	36.3	60	317	
85 to 90	87.5	87.5	98	37.2	488	2,803	98	37.2	488	2,803	
80 to 85	82.5	82.5	311	35.2	1,550	7,395	310	35.2	1,545	7,371	
75 to 80	77.5	77.5	391	32.6	1,948	6,847	368	32.3	1,834	6,178	
70 to 75	72.5	72.5	579	31	2,885	7,906	440	30.3	2,192	5,266	
65 to 70	67.5	67.5	774	28.2	3,857	5,345	504	27.1	2,511	2,144	
60 to 65	62.5	62.5	911	25.2	4,539	-	573	24.3	2,855	-	
55 to 60	57.5	57.5	885	22.3	4,410	1,149	531	21.7	2,646	689	
50 to 55	52.5	52.5	837	19.4	4,170	1,521	482	18.6	2,402	876	
45 to 50	47.5	47.5	604	17	3,010	1,411	390	16.5	1,943	911	
40 to 45	42.5	42.5	756	14.9	3,767	2,159	476	14.5	2,372	1,359	
35 to 40	37.5	37.5	747	12.8	3,722	2,521	410	12.6	2,043	1,384	
30 to 35	32.5	32.5	553	10.9	2,755	2,154	295	10.8	1,470	1,149	
25 to 30	27.5	27.5	374	9	1,864	1,651	193	8.7	962	852	
20 to 25	22.5	22.5	337	7.3	1,679	1,662	187	7.1	932	922	
15 to 20	17.5	17.5	214	5.6	1,066	1,167	122	5.5	608	665	
10 to 15	12.5	12.7	3.9	3.9	633	758	74	3.8	369	442	
5 to 10	7.5	11.0	2.6	548	714	-	65	2.5	324	422	
0 to 5	2.5	7.7	1.2	384	540	-	37	1.2	184	259	
-5 to 0	-2.5	3.3	0	164	248	-	13	0	65	98	
-10 to -5	-7.5	20	-1.4	100	161	-	5	-1.4	25	40	
-15 to -10	-12.5	10	-2.6	50	86	-	7	-2.6	35	60	
Totals			8,760		43,648	17,992	30,612		27,863	10,129	24,078

Savings Summary	
Fan Energy Savings (kWh, \$):	15,785 \$1,421
Heating Energy Savings (therm, \$):	7,773 \$6,684
Cooling Energy Savings (kWh, \$):	6,534 \$588
Total Cost Savings (\$):	\$8,693
Estimated BAS Cost	\$8,750
Simple Payback	1.0

Assumptions:
 - Assume that 7 control points are needed per AHU, plus a controller and networking
 - Industry standard of \$1,000 per point used for controls costs, plus 25% coverage to cover existing conditions



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-O&M3 Student Union, AC-1

AHU details	
Unit:	AC-1 Totals
Motor Nameplate Size	30
Calculated Air Flow: (cfm)	30,000
% Outdoor Air Flow:	12.0%
Fan Static Efficiency: (%)	53%
Total Static Pressure: (in)	1.5
Calculated Fan Power: (BHP)	13.4
Calculated Fan Power: (kW)	9.97
Calculated OA Flow: (cfm)	3,600

Heating/Cooling	
Cooling Supply Enthalpy:	25.3 Btu/lb
Heating Supply Temp:	70 °F
Cooling System Efficiency:	0.373 kW/ton
Heating System Efficiency:	78%

Utility Costs	
Natural Gas:	\$0.86 / Therm
Electricity:	\$0.09 / kWh

Operational Hours	
Existing:	5am-11pm M-F / 5am-12am Sat-Sun
Proposed:	6am-9pm M-F / 7am-10pm Sat-Sun

Weather Data	Existing Conditions				Proposed Conditions						
	ΔT (°F)	Mid-pits (°F)	Total Run Hours	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Total Run Hours	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	
90 to 95	12	36.3	120	-	66	12	36.3	120	-	66	
85 to 90	87.5	98	37.2	977	-	586	98	37.2	977	-	
80 to 85	82.5	311	35.2	3,099	-	1,547	307	35.2	3,059	-	
75 to 80	77.5	380	32.4	3,787	-	1,358	371	32.4	3,697	-	
70 to 75	72.5	502	30.7	5,003	-	1,358	433	30.3	4,315	-	
65 to 70	67.5	591	27.5	5,890	-	645	487	27	4,853	-	
60 to 65	62.5	689	24.6	6,866	-	-	560	24.2	5,581	-	
55 to 60	57.5	652	21.9	6,497	406	-	518	21.7	5,162	323	
50 to 55	52.5	598	18.9	5,959	522	-	467	18.6	4,654	407	
45 to 50	47.5	461	16.7	4,594	517	-	381	16.5	3,797	427	
40 to 45	42.5	571	14.6	5,690	783	-	462	14.4	4,604	633	
35 to 40	37.5	517	12.7	5,152	838	-	396	12.6	3,946	642	
30 to 35	32.5	385	10.9	3,837	720	-	286	10.8	2,850	535	
25 to 30	27.5	242	8.8	2,412	513	-	196	8.7	1,953	415	
20 to 25	22.5	248	7.2	2,471	587	-	185	7.1	1,844	438	
15 to 20	17.5	154	5.5	1,535	403	-	120	5.5	1,196	314	
10 to 15	12.5	93	3.9	927	267	-	71	3.8	708	203	
5 to 10	7.5	78	2.5	777	243	-	65	2.5	648	203	
0 to 5	2.5	51	1.2	508	172	-	35	1.2	349	118	
-5 to 0	-2.5	18	0	179	65	-	13	0	130	47	
-10 to -5	-7.5	10	-1.4	100	39	-	5	-1.4	50	19	
-15 to -10	-12.5	8	-2.6	80	33	-	7	-2.6	70	29	
Totals		6,669	-	66,459	6,105	5,555	5,475	-	54,560	4,753	4,993

Savings Summary	
Fan Energy Savings (kWh, \$):	11,899 \$1,071
Heating Energy Savings (therm, \$):	1,352 \$1,163
Cooling Energy Savings (kWh, \$):	562 \$51
Total Cost Savings (\$):	\$2,285
Estimated BAS Cost	\$8,750
Simple Payback	3.8

Assumptions:

- Assume that 7 control points are needed per AHU, plus a controller and networking
- Industry standard of \$1000 per point used for controls costs, plus 25% coverage to cover existing conditions



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-O&M3 Student Union, AC-2

AHU details		AC-2	Totals
Unit:		10	
Motor Nameplate Size		10,000	10,000
Calculated Air Flow: (cfm)		12.0%	12%
% Outdoor Air Flow:		53%	53%
Fan Static Efficiency: (%)		1.5	1.5
Total Static Pressure: (in)		4.5	4.5
Calculated Fan Power: (BHP)		3.32	3.3
Calculated Fan Power: (kW)		1,200	1,200

Heating/Cooling		Btu/lb	kW/ton
Cooling Supply Enthalpy:		25.3	
Heating Supply Temp:		70	°F
Cooling System Efficiency:		0.373	
Heating System Efficiency:		78%	

Utility Costs		\$/Therm	\$/kWh
Natural Gas:		\$0.86	
Electricity:		\$0.09	

Operational Hours	
Existing:	24 hours, 7 days/week
Proposed:	7am-7pm M-F / Off Sat-Sun

Weather Data		Existing Conditions			Proposed Conditions						
ΔT (°F)	Mid-pt (°F)	Total Run Hours	h (Btu/lb)	Fan Energy (kWh)	Heating Energy (therm)	Total Run Hours	h (Btu/lb)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	
90 to 95	92.5	12	36.3	40	-	22	4	36.3	13	7	
85 to 90	87.5	98	37.2	326	-	195	60	37.5	199	123	
80 to 85	82.5	311	35.2	1,033	-	516	199	35.1	661	-	
75 to 80	77.5	391	32.6	1,299	-	477	239	32.2	794	276	
70 to 75	72.5	579	31	1,923	-	551	242	29.9	804	186	
65 to 70	67.5	774	28.2	2,571	-	373	294	26.6	977	62	
60 to 65	62.5	911	25.2	3,026	-	-	330	23.8	1,096	-	
55 to 60	57.5	885	22.3	2,940	184	-	291	21.6	967	60	
50 to 55	52.5	837	19.4	2,780	243	-	288	18.3	957	84	
45 to 50	47.5	604	17	2,006	226	-	227	16.3	754	85	
40 to 45	42.5	756	14.9	2,511	345	-	293	14.4	973	134	
35 to 40	37.5	747	12.8	2,481	403	-	191	12.6	634	102	
30 to 35	32.5	553	10.9	1,837	345	-	164	10.8	545	103	
25 to 30	27.5	374	9	1,242	264	-	98	8.8	326	69	
20 to 25	22.5	337	7.3	1,119	266	-	99	7	329	78	
15 to 20	17.5	214	5.6	711	187	-	67	5.5	223	58	
10 to 15	12.5	127	3.9	422	121	-	42	3.7	140	40	
5 to 10	7.5	110	2.6	365	114	-	34	2.5	113	35	
0 to 5	2.5	77	1.2	256	86	-	17	1.2	56	19	
-5 to 0	-2.5	33	0	110	40	-	6	0.1	20	7	
-10 to -5	-7.5	20	-1.4	66	26	-	1	-1.2	3	1	
-15 to -10	-12.5	10	-2.6	33	14	-	6	-2.6	20	8	
Totals		8,760	-	29,099	2,864	2,134	3,192	-	10,603	885	980

Savings Summary	
Fan Energy Savings (kWh, \$):	18,496 \$1,665
Heating Energy Savings (therm, \$):	1,979 \$1,702
Cooling Energy Savings (kWh, \$):	1,154 \$104
Total Cost Savings (\$):	\$3,470
Estimated BAS Cost	\$8,750
Simple Payback	2.5

Assumptions:
 - Assume that 7 control points are needed per AHU, plus a controller and networking
 - Industry standard of \$1,000 per point used for controls costs, plus 25% coverage to cover existing conditions



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-O&M3 Student Union, AC-3

AHU details		AC-3	Totals
Unit:		15	
Motor Nameplate Size		15,000	15,000
Calculated Air Flow: (cfm)		12.0%	12%
% Outdoor Air Flow:		55%	53%
Fan Static Efficiency: (%)		2.0	2
Total Static Pressure: (in)		8.9	9
Calculated Fan Power: (BHP)		6.64	7
Calculated Fan Power: (kW)		1800	1,800

Operational Hours	
Existing:	6am-12am, 7 days/week
Proposed:	6am-9pm M-F / Off Sat-Sun

Heating/Cooling	
Cooling Supply Enthalpy:	25.3 Btu/lb
Heating Supply Temp:	70 °F
Cooling System Efficiency:	0.373 kW/ton
Heating System Efficiency:	78%

Utility Costs	
Natural Gas:	\$0.86 / Therm
Electricity:	\$0.09 / kWh

Weather Data	Existing Conditions				Proposed Conditions						
	ΔT (°F)	Mid-pt (°F)	Total Run Hours	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Total Run Hours	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	
90 to 95	12	36.3	80	-	33	4	36.3	27	-	11	
85 to 90	87.5	98	37.2	651	-	293	60	37.5	399	-	
80 to 85	82.5	311	35.2	2,066	-	773	217	35.2	1,442	-	
75 to 80	77.5	383	32.5	2,544	-	692	271	32.3	1,800	-	
70 to 75	72.5	501	30.6	3,328	-	665	288	30.2	1,913	-	
65 to 70	67.5	594	27.5	3,946	-	324	357	27.1	2,372	-	
60 to 65	62.5	686	24.6	4,557	-	-	424	24.2	2,817	-	
55 to 60	57.5	638	21.9	4,239	199	-	383	21.8	2,544	119	
50 to 55	52.5	583	18.9	3,873	254	-	361	18.7	2,398	157	
45 to 50	47.5	465	16.7	3,089	261	-	290	16.5	1,927	163	
40 to 45	42.5	555	14.6	3,687	380	-	357	14.5	2,372	245	
35 to 40	37.5	499	12.6	3,315	404	-	275	12.6	1,827	223	
30 to 35	32.5	382	10.9	2,538	357	-	206	10.8	1,369	193	
25 to 30	27.5	231	8.8	1,535	245	-	133	8.9	884	141	
20 to 25	22.5	233	7.2	1,548	276	-	133	7.2	884	157	
15 to 20	17.5	151	5.5	1,003	198	-	94	5.5	624	123	
10 to 15	12.5	93	3.8	618	133	-	46	3.7	306	66	
5 to 10	7.5	75	2.5	498	117	-	47	2.5	312	73	
0 to 5	2.5	46	1.2	306	77	-	27	1.2	179	45	
-5 to 0	-2.5	19	0	126	34	-	7	0.1	47	13	
-10 to -5	-7.5	8	-1.4	53	15	-	3	-1.4	20	6	
-15 to -10	-12.5	7	-2.6	47	14	-	7	-2.6	47	14	
Totals		6,570	-	43,648	2,965	2,780	3,990	-	26,508	1,738	1,722

Savings Summary	
Fan Energy Savings (kWh, \$):	17,140 \$1,543
Heating Energy Savings (therm, \$):	1,227 \$1,055
Cooling Energy Savings (kWh, \$):	1,058 \$95
Total Cost Savings (\$):	\$2,693
Estimated BAS Cost	\$8,750
Simple Payback	3.2

Assumptions:

- Assume that 7 control points are needed per AHU, plus a controller and networking
- Industry standard of \$1000 per point used for controls costs, plus 25% coverage to cover existing conditions



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-O&M3 Student Union, AC-4, HV-1,2

AHU details				
Unit:	AC-4	HV-1	HV-2	Totals
Motor Nameplate Size	5	7.5	5	
Calculated Air Flow: (cfm)	7,500	11,250	7,500	26,250
% Outdoor Air Flow:	12.0%	100.0%	100.0%	75%
Fan Static Efficiency: (%)	55%	53%	53%	53%
Total Static Pressure: (in)	1.5	1.5	1.5	5
Calculated Fan Power: (BHP)	3.3	5.0	3.3	12
Calculated Fan Power: (kW)	2.49	3.74	2.49	9
Calculated OA Flow: (cfm)	900	11,250	7,500	19,650

Heating/Cooling	
Cooling Supply Enthalpy:	25.3 Btu/lb
Heating Supply Temp:	70 °F
Cooling System Efficiency:	0.373 kW/ton
Heating System Efficiency:	78%

Utility Costs	
Natural Gas:	\$0.86 / Therm
Electricity:	\$0.09 / kWh

Operational Hours	
Existing:	24 hours, 7 days/week
Proposed:	4am-12am M-F / 4am-11pm Sat-Sun

Weather Data	Existing Conditions				Proposed Conditions				
	Total Run Hours	h (Btu/lb)	Fan Energy (kWh)	Heating Energy (therm)	Total Run Hours	h (Btu/lb)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)
90 to 95	12	36.3	105	-	12	36.3	105	-	362
85 to 90	98	37.2	855	-	98	37.2	855	-	3,199
80 to 85	311	35.2	2,712	-	311	35.2	2,712	-	8,442
75 to 80	391	32.6	3,409	-	383	32.5	3,340	-	7,551
70 to 75	579	31	5,049	-	514	30.7	4,482	-	7,588
65 to 70	774	28.2	6,749	-	639	27.7	5,572	-	4,158
60 to 65	911	25.2	7,944	-	745	24.8	6,496	-	-
55 to 60	885	22.3	7,717	3,010	713	22.1	6,217	2,425	-
50 to 55	837	19.4	7,298	3,985	653	19.1	5,694	3,109	-
45 to 50	604	17	5,267	3,698	500	16.8	4,360	3,061	-
40 to 45	756	14.9	6,592	5,656	623	14.7	5,432	4,661	-
35 to 40	747	12.8	6,514	6,605	574	12.7	5,005	5,076	-
30 to 35	553	10.9	4,822	5,642	437	10.9	3,810	4,459	-
25 to 30	374	9	3,261	4,325	271	8.9	2,363	3,134	-
20 to 25	337	7.3	2,939	4,355	271	7.2	2,363	3,502	-
15 to 20	214	5.6	1,866	3,057	170	5.6	1,482	2,428	-
10 to 15	127	3.9	1,107	1,987	101	3.9	881	1,580	-
5 to 10	110	2.6	959	1,871	84	2.5	732	1,428	-
0 to 5	77	1.2	671	1,414	59	1.2	514	1,084	-
-5 to 0	33	0	288	651	20	0	174	395	-
-10 to -5	20	-1.4	174	422	14	-1.4	122	295	-
-15 to -10	10	-2.6	87	224	9	-2.6	78	202	-
Totals	8,760	-	76,384	46,902	7,201	-	62,790	36,839	31,301

Savings Summary	
Fan Energy Savings (kWh, \$):	13,594 \$1,223
Heating Energy Savings (therm, \$):	10,063 \$8,655
Cooling Energy Savings (kWh, \$):	3,646 \$328
Total Cost Savings (\$):	\$10,206
Estimated BAS Cost	\$26,250
Simple Payback	2.6

Assumptions:
 - Assume that 7 control points are needed per AHU, plus a controller and networking
 - Industry standard of \$1000 per point used for controls costs, plus 25% coverage to cover existing conditions



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-O&M3 Hasbrouck Dining Hall AHU Schedule

AHU details	
Unit:	MZ-1 AC-1 Totals
Motor Nameplate Size	5 10
Calculated Air Flow: (cfm)	7,500 15,000 22,500
% Outdoor Air Flow:	50.0% 50.0% 50%
Fan Static Pressure: (%)	55% 53% 53%
Total Static Pressure: (in)	2.0 2.0 4
Calculated Fan Power: (BHP)	4.5 8.9 13
Calculated Fan Power: (kW)	3.32 6.64 10
Calculated OA Flow: (cfm)	3750 7500 11,250

Heating/Cooling	
Cooling Supply Enthalpy:	25.3 Btu/lb
Heating Supply Temp:	70 °F
Cooling System Efficiency:	0.857 kW/ton
Heating System Efficiency:	78%

Utility Costs	
Natural Gas:	\$0.86 /Therm
Electricity:	\$0.09 / kWh

Operational Hours	
Existing:	6am-12am, 7 days/week
Proposed:	6am-9pm M-F/ Off Sat-Sun

Weather Data		Existing Conditions			Proposed Conditions						
ΔT (°F)	Mid-pt (°F)	Total Run Hours	h (Btu/lb)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Total Run Hours	h (Btu/lb)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)
90 to 95	92.5	12	36.3	120	-	476	12	36.3	120	-	476
85 to 90	87.5	98	37.2	977	-	4,204	98	37.2	977	-	4,204
80 to 85	82.5	311	35.2	3,099	-	11,092	311	35.2	3,099	-	11,092
75 to 80	77.5	391	32.6	3,896	-	10,270	383	32.5	3,817	-	9,922
70 to 75	72.5	579	31	5,770	-	11,859	514	30.7	5,122	-	9,970
65 to 70	67.5	774	28.2	7,713	-	8,017	639	27.7	6,368	-	5,464
60 to 65	62.5	911	25.2	9,078	-	-	745	24.8	7,424	-	-
55 to 60	57.5	885	22.3	8,819	1,723	-	713	22.1	7,105	1,388	-
50 to 55	52.5	837	19.4	8,341	2,282	-	653	19.1	6,507	1,780	-
45 to 50	47.5	604	17	6,019	2,117	-	500	16.8	4,983	1,752	-
40 to 45	42.5	756	14.9	7,534	3,238	-	623	14.7	6,208	2,669	-
35 to 40	37.5	747	12.8	7,444	3,782	-	574	12.7	5,720	2,906	-
30 to 35	32.5	553	10.9	5,511	3,230	-	437	10.9	4,355	2,553	-
25 to 30	27.5	374	9	3,727	2,476	-	271	8.9	2,701	1,794	-
20 to 25	22.5	337	7.3	3,358	2,493	-	271	7.2	2,701	2,005	-
15 to 20	17.5	214	5.6	2,133	1,750	-	170	5.6	1,694	1,390	-
10 to 15	12.5	127	3.9	1,266	1,138	-	101	3.9	1,006	905	-
5 to 10	7.5	110	2.6	1,096	1,071	-	84	2.5	837	818	-
0 to 5	2.5	77	1.2	767	810	-	59	1.2	588	620	-
-5 to 0	-2.5	33	0	329	373	-	20	0	199	226	-
-10 to -5	-7.5	20	-1.4	199	241	-	14	-1.4	140	169	-
-15 to -10	-12.5	10	-2.6	100	129	-	9	-2.6	90	116	-
Totals		8,760	-	87,296	26,852	45,918	7,201	-	71,760	21,091	41,127

Savings Summary	
Fan Energy Savings (kWh, \$):	15,536 \$1,398
Heating Energy Savings (therm, \$):	5,762 \$4,955
Cooling Energy Savings (kWh, \$):	4,791 \$431
Total Cost Savings (\$):	\$6,784
Estimated BAS Cost	\$17,500
Simple Payback	2.6

Assumptions:
 - Assume that 7 control points are needed per AHU, plus a controller and networking
 - Industry standard of \$1000 per point used for controls costs, plus 25% coverage to cover existing conditions



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-O&M3 Haggerty Admin Building AHU Schedule

AHU details			
Unit:	AC-5	AC-6	Totals
Motor Nameplate Size	20	25	
Calculated Air Flow: (cfm)	30,000	37,500	67,500
% Outdoor Air Flow:	50.0%	50.0%	50%
Fan Static Efficiency: (%)	55%	53%	55%
Total Static Pressure: (in)	2.0	2.0	4
Calculated Fan Power: (BHP)	17.8	22.3	40
Calculated Fan Power: (kW)	13.29	16.61	30
Calculated OA Flow: (cfm)	15000	18750	33,750

Heating/Cooling	
Cooling Supply Enthalpy:	25.3 Btu/lb
Heating Supply Temp:	70 °F
Cooling System Efficiency:	0.857 kW/ton
Heating System Efficiency:	78%

Utility Costs	
Natural Gas:	\$0.86 /Therm
Electricity:	\$0.09 /kWh

Operational Hours	
Existing:	6am-12am, 7 days/week
Proposed:	6am-9pm M-F / Off-Sat-Sun

Weather Data	Existing Conditions			Proposed Conditions		
	Total Run Hours	Fan Energy (kWh)	Heating Energy (therm)	Total Run Hours	Fan Energy (kWh)	Heating Energy (therm)
ΔT (°F)	Mid-pits (°F)	h (Btu/lb)	h (Btu/lb)	h (Btu/lb)	h (Btu/lb)	h (Btu/lb)
90 to 95	92.5	36.3	359	12	36.3	359
85 to 90	87.5	37.2	2,930	98	37.2	2,930
80 to 85	82.5	31.1	9,298	311	35.2	9,298
75 to 80	77.5	39.1	1,689	383	32.5	11,450
70 to 75	72.5	57.9	17,310	514	30.7	15,367
65 to 70	67.5	77.4	23,139	639	27.7	19,104
60 to 65	62.5	91.1	27,235	745	24.8	22,273
55 to 60	57.5	88.5	26,458	713	22.1	21,316
50 to 55	52.5	83.7	25,023	653	19.1	19,522
45 to 50	47.5	60.4	17,180	500	16.8	14,948
40 to 45	42.5	75.6	14.9	623	14.7	18,625
35 to 40	37.5	74.7	12.8	574	12.7	17,160
30 to 35	32.5	55.3	10.9	437	10.9	13,065
25 to 30	27.5	37.4	9	271	8.9	8,102
20 to 25	22.5	33.7	7.3	271	7.2	8,102
15 to 20	17.5	21.4	5.6	170	5.6	5,082
10 to 15	12.5	12.7	3.9	101	3.9	3,019
5 to 10	7.5	11.0	2.6	84	2.5	2,511
0 to 5	2.5	7.7	1.2	59	1.2	1,764
-5 to 0	-2.5	3.3	0	20	0	598
-10 to -5	-7.5	20	-1.4	14	-1.4	419
-15 to -10	-12.5	10	-2.6	9	-2.6	269
Totals		8,760	261,889	80,557	137,755	7,201
						215,281
						63,272
						123,382

Savings Summary	
Fan Energy Savings (kWh, \$):	46,608 \$4,195
Heating Energy Savings (therm, \$):	17,285 \$14,865
Cooling Energy Savings (kWh, \$):	14,373 \$1,294
Total Cost Savings (\$):	\$20,353
Estimated BAS Cost	\$17,500
Simple Payback	0.9

Assumptions:
 - Assume that 7 control points are needed per AHU, plus a controller and networking
 - Industry standard of \$1000 per point used for controls costs, plus 25% coverage to cover existing conditions



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-O&M4 Pipe Insulation - Summary

Utility Costs	
Natural Gas:	\$0.858 /therm
Electricity:	\$0.090 /kWh

Heating System Operating (Hours/yr)	8,760
Heating System Efficiency	78%

Pipework Properties					Savings		
Type	Diameter (in.)	Equiv. Pipe Length (ft.)	Fluid Temperature (°F)	Heat Loss Uninsulated (Btu/h)	Heat Loss Insulated (Btu/h)	Heating Energy Savings (Therms)	Annual Energy Cost Savings (\$)
Campuswide 10" Fittings	10	1.83	260	2,434	96	263	\$ 225
Campuswide 8" Fittings	8	0.00	260	0	0	0	\$ -
Campuswide 6" Fittings	6	13.49	260	11,503	534	1,232	\$ 1,056
Campuswide 4" Fittings	4	65.82	260	39,310	96	4,404	\$ 3,777
Campuswide 3" Fittings	3	99.63	260	47,246	96	5,295	\$ 4,541
Campuswide 2.5" Fittings	2.5	27.24	260	10,789	749	1,128	\$ 967
Campuswide 2.0" Fittings	2	127.93	260	42,579	3,313	4,410	\$ 3,782
Campuswide 1.5" Fittings	1.5	60.27	260	16,369	1,392	1,682	\$ 1,442
Campuswide 1.0" Fittings	1	17.51	260	3,405	384	339	\$ 291
Heat Exchangers	Various	28.78	260	80,719	2,650	8,768	\$ 7,519
						27,520	\$ 23,600

Savings Summary	
Electricity Usage (kWh):	0
Gas Savings (Therms):	27,520
Energy Savings (MMBTU Source):	2,881
Cost Savings (\$):	\$ 23,600
Emissions Reduction (lb CO ₂):	335,332
Cost Estimate (\$):	\$ 47,748
Simple payback:	2.02

Assumptions:
 - Insulation quantities based on previous survey provided by SUNY New Paltz, field verified.



Project Name: SUNY New Paltz
 Project Number: 4013032.01
 ECM-O&M4

Pipe Insulation Calculations

Utility Costs	
Natural Gas:	\$0.86 /therm
Electricity:	\$0.09 /kWh

Building	Type of Pipe	Description	Pipe Size (Inches)	Pipe Length (Feet)	Pipe Inside Temperature (°F)	Heating System Operating (Hours/yr)	Bare Pipe Heat Loss (Btu/hr)	Existing Heating Energy (MMBtu)	Required Pipe Insulation (Inches)	Insulated Pipe Heat Loss (Btu/hr)	Proposed Heating Energy (MMBtu)	Heat Loss Savings (Btu/hr)	Saved Heating Energy (MMBtu)
Campus	High Temp HW	Campuswide 10" Fittings	10.00	1.83	260°F	8,760	2434	21	3.5	96	0.84	2338	20
Campus	High Temp HW	Campuswide 8" Fittings	8.00		260°F	8,760	0	0	3.5	0	0	0	0
Campus	High Temp HW	Campuswide 6" Fittings	6.00	13.49	260°F	8,760	11503	101	3	534	5	10968	96
Campus	High Temp HW	Campuswide 4" Fittings	4.00	65.82	260°F	8,760	39310	344	3	2086	11	37224	190
Campus	High Temp HW	Campuswide 3" Fittings	3.00	99.63	260°F	8,760	47246	414	2.5	2829	14	44417	227
Campus	High Temp HW	Campuswide 2.5" Fittings	2.50	27.24	260°F	8,760	10789	95	2	749	7	10040	88
Campus	High Temp HW	Campuswide 2.0" Fittings	2.00	127.93	260°F	8,760	42579	373	2	3313	29	39266	344
Campus	High Temp HW	Campuswide 1.5" Fittings	1.50	60.27	260°F	8,760	16369	143	2	1392	12	14977	131
Campus	High Temp HW	Campuswide 1.0" Fittings	1.00	17.51	260°F	8,760	3405	30	1.5	384	3	3021	26
Campus	High Temp HW	Heat Exchangers	24.00	28.78	260°F	8,760	80719	707	4	2650	23	78069	684
TOTALS				443			294,354	2,228		14,034	0	240,320	0

Assumptions:

- Insulation quantities based on previous survey provided by SUNY New Paltz, field verified.

Project Name: SUNY New Paltz
 Project Number: 4013032.01
 ECM-O&M5 Retrocommissioning

Assumptions	
Annual Savings due to RCX	10.0%
RCX Average Cost (\$/SF)	\$ 0.30

Building	Building Square Footage	Building Type	Existing			Energy Savings Calculations					RCx cost
			Building Annual Electricity Usage (kWh)	Building Annual Heating Usage (therms)	Building Utility Cost (\$)	Area Covered by RCx (SF)	RCx Cost Factor (\$/SF)	Estimated Building Heating Energy Saved (kWh)	Estimated Building Heating Energy Saved (Therms)	Estimated Building Utility Savings	
Athletic Center	61,262	Gym	1,184,803	17,862	\$ 176,038	61,262	\$ 0.50	118,480	1,786	\$ 12,141	\$ 30,631
Beverly Hall	56,394	Dormitory	266,875	45,670	\$ 75,186	56,394	\$ 0.30	26,687	4,567	\$ 6,306	\$ 16,918
Child Care Center	5,906	Day Care	40,110	5,145	\$ 8,758	5,906	\$ 0.30	4,011	515	\$ 800	\$ 1,772
College Hall	106,362	Dormitory	490,083	60,770	\$ 105,210	106,362	\$ 0.30	49,008	6,077	\$ 9,600	\$ 31,909
Coykendall Science Building	83,597	Academic	1,413,204	138,078	\$ 271,518	83,597	\$ 0.50	141,320	13,808	\$ 24,495	\$ 41,799
Deyo Hall	56,394	Dormitory	261,067	45,670	\$ 74,556	56,394	\$ 0.30	26,107	4,567	\$ 6,254	\$ 16,918
Elting Gym	82,730	Gym	462,669	73,749	\$ 113,371	82,730	\$ 0.30	46,267	7,375	\$ 10,467	\$ 24,819
Escopus Hall	69,634	Dormitory	675,772	69,778	\$ 133,053	69,634	\$ 0.30	67,577	6,978	\$ 12,035	\$ 20,890
Haggerty Admin Building	70,778	Offices	1,343,248	115,518	\$ 119,446	70,778	\$ 0.30	134,325	11,552	\$ 21,934	\$ 21,233
Hasbrouck Dining Hall	30,015	Dining	863,901	38,215	\$ 15,307	30,015	\$ 0.30	86,390	3,822	\$ 11,013	\$ 9,005
Humanities/Jacobson Faculty Tower	104,435	Academic	1,062,672	135,365	\$ 231,215	104,435	\$ 0.50	106,267	13,537	\$ 21,124	\$ 52,218
Lecture Center	60,366	Academic	537,693	102,615	\$ 162,684	60,366	\$ 0.30	53,769	10,262	\$ 13,614	\$ 18,110
Lenape Hall	68,035	Dormitory	645,392	68,176	\$ 128,387	68,035	\$ 0.30	64,539	6,818	\$ 11,625	\$ 20,411
Old Main	77,257	Academic	648,092	46,316	\$ 109,934	77,257	\$ 0.30	64,809	4,632	\$ 9,775	\$ 23,177
Parker Theatre	21,057	Academic	221,290	39,269	\$ 60,752	21,057	\$ 0.30	22,129	3,927	\$ 5,349	\$ 6,317
Resnick Engineering Hall	15,755	Academic	306,831	14,363	\$ 94,530	15,755	\$ 0.50	30,683	1,436	\$ 3,979	\$ 7,878
Scaudder Hall	47,404	Dormitory	213,548	31,423	\$ 57,066	47,404	\$ 0.30	21,355	3,142	\$ 4,607	\$ 14,221
Smiley Arts Building/Dorsky Museum	96,706	Academic	1,085,596	97,331	\$ 201,082	96,706	\$ 0.30	108,560	9,733	\$ 18,067	\$ 29,012
Sojourner Truth Library	110,983	Library	327,074	77,629	\$ 101,720	110,983	\$ 0.30	32,707	7,763	\$ 9,586	\$ 33,295
Student Health Center	14,103	Healthcare	177,916	4,250	\$ 22,920	14,103	\$ 0.30	17,792	425	\$ 1,958	\$ 4,231
Student Union Building	103,813	Dining	2,153,042	65,127	\$ 290,025	103,813	\$ 0.50	215,304	6,513	\$ 24,863	\$ 51,907
Vandenberg Hall	88,441	Academic	342,902	71,185	\$ 92,837	88,441	\$ 0.30	34,290	7,118	\$ 9,175	\$ 26,532
Totals	1,987,777							1,762,931	136,350	\$ 274,783	\$ 663,501

Savings Summary	
Site Electricity Savings (kWh):	1,762,931
Site Gas Savings (Therms):	136,350
Energy Savings (MMBTU Source):	34,366
Cost Savings (\$):	\$ 274,783
Emissions Reduction (lb CO ₂):	5,259,112
Cost Estimate (\$):	\$ 915,964
Simple payback:	3.3

Assumptions:
 - Savings values and costs are based on:
 Existing Building Commissioning, published in the ASHRAE Journal, September 2007
 Building Commissioning, published by Evan Mills, Ph.D. Lawrence Berkeley National Laboratory, July 2009
 - Not all buildings are not sub-metered so utility consumption is estimated on a square foot basis
 - RCx cost does not include the costs to make capital improvements, equipment repairs or equipment replacement
 - Scope of RCx would cover all systems, reviewing BAS schedules, sequences, etc. - whole bldg SF
 - The cost estimate in the summary box includes markups for contingency, design, and NYPA project management



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-C1 High Efficiency Lighting & Controls - Summary

Utility Costs	
Electricity:	\$0.09 /kWh

Savings Summary	
Site Electricity Savings (kWh):	344,267
Site Gas Savings (Therms):	0
Energy Savings (MMBTU Source):	3,923
Cost Savings (\$):	\$ 30,826
Emissions Reduction (lb CO2):	702,559
Cost Estimate (\$):	\$ 167,469
Simple payback:	5.4



Project Name: SUNY New Paltz
 Project Number: 4013032.01
 EC&M-C1 High Efficiency Lighting & Controls

Assumptions - One Sensor Savings	
Corridor Savings	25%
Stairwell Savings	95%
Restroom Savings	50%
Work room / Classroom Savings	55%

Utility Costs	
Electricity:	\$0.09 /kWh

Line Item	Building	Floor	Area Description	PRE-INSTALLATION				POST-INSTALLATION				Proposed Annual Hours	Annual kWh Saved				
				Pre Fixt. No.	Pre Fixt. Code	Pre Wats/ Fixt	Pre kW / Space	Existing Control	Post Fixt. No.	Post Fixt. Code	Post Wats/ Fixt			Post kW / Space	Proposed Control	kW Saved	
1	Hasbrouck		Summer Boiler Room	9	F42SE	86	0.77	Light Switch		13	F42LL	32	0.54	Light Switch	0.23	800	187
2	Sigourney Truth Library		Restrooms	13	F41LL	32	0.42	Light Switch		48	CFQ13/1-L	31	0.72	Motion Sensor	0.00	4,992	2,496
3	Old Library		The Cage	48	CFQ13/1-L	15	0.25	Light Switch		8	CFT13/2	31	0.25	Motion Sensor	0.00	8,760	1,977
4	Old Library		Stairwells	8	CFT13/2	15	0.25	Light Switch		4	H50/1	32	0.13	Motion Sensor	0.00	4,992	2,064
5	Old Main		Auditorium	4	H50/1	150	6.80	Light Switch		17	CFT55/1-BX	56	0.95	Motion Sensor	0.47	4,992	2,708
6	Old Main		Auditorium	17	IG00/1	300	5.10	Light Switch		6	CFQ18/1	28	0.16	Light Switch	0.00	4,992	2,321
7	Old Main		Auditorium	6	CFQ18/1	28	0.16	Light Switch		51	CFQ18/1	28	0.16	Motion Sensor	0.00	8,760	428
8	Old Main		Stairwells	51	CFQ18/1	28	1.33	Light Switch		35	CF515/1	15	1.58	Motion Sensor	0.00	4,992	1,035
9	Coykendal		Lecture Hall	35	IG07/1	60	2.10	Light Switch		51	F42LL	60	3.06	Motion Sensor	1.58	8,760	9,304
10	Coykendal	All	Stairwells	51	F42LL	60	3.06	Light Switch		2	CFQ25/2	66	0.13	Motion Sensor	0.00	8,760	438
11	Coykendal	All	Stairwells	2	CFQ25/2	66	0.13	Light Switch		5	F42LL	60	0.30	Motion Sensor	0.00	4,992	1,099
12	Faculty Office Building		Conference Room	5	F42LL	60	0.30	Light Switch		4	CFT13/1	17	0.07	Motion Sensor	0.00	8,760	824
13	Lecture Center	All	Stairwells	4	CFT13/1	17	0.07	Light Switch		15	F46GHL	351	5.27	Motion Sensor	0.00	4,992	566
14	Lecture Center		Classroom 100	15	F46GHL	351	5.27	Light Switch		68	CF515/1	15	1.02	Motion Sensor	0.00	4,992	14,456
15	Lecture Center		Classroom 100	68	CF515/1	15	4.70	Light Switch		8	F43L-H	98	4.70	Motion Sensor	0.00	4,992	2,801
16	Lecture Center		Classroom 102	48	F43L-H	98	4.70	Light Switch		8	CF515/1	15	0.12	Motion Sensor	0.00	4,992	12,915
17	Lecture Center		Classroom 102	8	CF515/1	15	0.12	Light Switch		25	F43L-H	98	2.45	Motion Sensor	0.00	4,992	329
18	Lecture Center		Classroom 104	25	F43L-H	98	2.45	Light Switch		3	CF515/1	15	0.05	Motion Sensor	0.00	4,992	6,727
19	Lecture Center		Classroom 104	3	CF515/1	15	0.05	Light Switch		5	F42LL	60	0.30	Motion Sensor	0.00	8,760	124
20	Van den burg		Stairwells	5	F42LL	60	0.30	Light Switch		2	CF26/4-L	108	0.22	Motion Sensor	0.00	8,760	2,497
21	Van den burg		Stairwells	2	CF26/4-L	108	0.22	Light Switch		3	F44SE	20	0.18	Motion Sensor	0.00	4,992	1,798
22	Van den burg	all	Amper Rm 251	3	F44SE	172	0.52	Light Switch		20	F41LL	32	0.64	Motion Sensor	0.00	8,760	2,172
23	Haggerty Administration		Stairwells	20	F41LL	32	0.64	Light Switch		20	F41LL	32	0.64	Motion Sensor	0.00	8,760	5,328
24	Haggerty Administration		Restrooms	20	F41LL	32	0.64	Light Switch		88	F41LL	32	2.82	Motion Sensor	0.00	8,760	2,803
25	Haggerty Administration	2 thru 9	Corridors	88	F41LL	32	2.82	Light Switch		1	F42LL	60	0.06	Motion Sensor	0.00	4,992	6,167
26	Child Care Center		Gender Neutral Bathroom	1	F42LL	60	0.06	Light Switch		63	200W LED Eq.	75	4.73	Motion Sensor	0.00	8,760	150
27	Student Union		Multi Purpose Room	63	MH200/1	232	14.62	Light Switch		40	F41LL	32	1.28	Motion Sensor	9.89	8,760	11,690
28	Student Union	All	Stairwells	40	F41LL	32	1.28	Light Switch		6	F42LL	32	0.36	Motion Sensor	0.00	8,760	10,652
29	South Classroom	1	Restrooms	6	F42LL	32	0.36	Light Switch		10	F41LL	32	0.32	Motion Sensor	0.00	4,992	899
30	Smiley Arts	1, 2	Restrooms	10	F41LL	32	0.32	Light Switch		24	CF59/1	15	0.22	Motion Sensor	0.00	4,992	799
31	Smiley Arts	All	Stairwells	24	CF59/1	15	0.22	Light Switch		1	CFQ13/1-L	15	0.02	Motion Sensor	0.00	8,760	1,798
32	Humanities	All	Stairwells	1	CFQ13/1-L	15	0.02	Light Switch		15	F44LL	118	1.77	Motion Sensor	0.00	8,760	1,25
33	Humanities	All	Stairwells	15	F44LL	118	1.77	Light Switch		15	F41LL	32	0.03	Motion Sensor	0.00	8,760	14,730
34	Humanities	All	Stairwells	1	F41LL	32	0.03	Light Switch		44	CFT13/2	31	1.36	Motion Sensor	0.00	8,760	266
35	Faculty Tower	All	Stairwells	44	CFT13/2	31	1.36	Light Switch		18	CFQ18/2-L	38	0.68	Motion Sensor	0.00	8,760	11,351
36	Resnick	All	Stairwells	18	CFQ18/2-L	38	0.68	Light Switch		20	F48LL-R	156	3.12	Motion Sensor	0.00	2,080	5,692
37	Maintenance WH	1	Bay Lighting	20	F44SS	188	3.76	Light Switch		801	Total Pre Fixt.	58	Total Post Fixt.	17.30	Total Annual kWh Saved	20,180	
				801		188	3.76			801		156	4.1		17.30	20,180	



Project Name: SUNY New Paltz
 Project Number: 4013032.01
 EC&M-C1 High Efficiency Lighting & Controls

Assumptions - One Sensor Savings	25%
Corridor	95%
Stairwell	

Electricity:	\$0.09	kWh
Utility Costs		

Line Item	Building	Floor	Area Description	PRE-INSTALLATION				POST-INSTALLATION				Proposed Annual Hours	Annual kWh Saved			
				Pre Fixt. No.	Pre Fixt Code	Pre Watts/ Fixt	Pre kW / Space	Existing Control	Post Fixt No.	Post Fixt Code	Post Watts/ Fixt			Post kW / Space	Proposed Control	kWh Saved
1	Bever Hall	B - 3	Corridors	64	CFS9/1	9	0.58	Light Switch	64	CFS9/1	9	0.58	Motion Sensor	0.00	6,570	1,261
2	Bever Hall	B - 3	Corridors	14	CFQ13/1-L	15	0.21	Light Switch	14	CFQ13/1-L	15	0.21	Motion Sensor	0.00	8,760	460
3	Bever Hall	all	Stairwells	26	F41LL	32	0.83	Light Switch	26	F41LL	32	0.83	Motion Sensor	0.00	8,760	6924
4	Bever Hall	all	Stairwells	1	CFT13/1	17	0.02	Light Switch	1	CFT13/1	17	0.02	Motion Sensor	0.00	8,760	438
5	Deyo Hall	B - 3	Corridors	64	CFS9/1	9	0.58	Light Switch	64	CFS9/1	9	0.58	Motion Sensor	0.00	8,760	1,281
6	Deyo Hall	B - 3	Corridors	14	CFQ13/1-L	15	0.21	Light Switch	14	CFQ13/1-L	15	0.21	Motion Sensor	0.00	8,760	460
7	Deyo Hall	all	Stairwells	26	F41LL	32	0.83	Light Switch	26	F41LL	32	0.83	Motion Sensor	0.00	8,760	6,924
8	Doubios Hall	all	Stairwells	1	CFT13/1	17	0.02	Light Switch	1	CFT13/1	17	0.02	Motion Sensor	0.00	8,760	438
9	Doubios Hall	B - 3	Corridors	64	CFS9/1	9	0.58	Light Switch	64	CFS9/1	9	0.58	Motion Sensor	0.00	8,760	1,261
10	Doubios Hall	B - 3	Corridors	14	CFQ13/1-L	15	0.21	Light Switch	14	CFQ13/1-L	15	0.21	Motion Sensor	0.00	8,760	460
11	Doubios Hall	all	Stairwells	26	F41LL	32	0.83	Light Switch	26	F41LL	32	0.83	Motion Sensor	0.00	8,760	6,924
12	Doubios Hall	all	Stairwells	1	CFT13/1	17	0.02	Light Switch	1	CFT13/1	17	0.02	Motion Sensor	0.00	8,760	438
13	Capen Hall	B - 3	Corridors	128	CFS9/1	9	1.15	Light Switch	128	CFS9/1	9	1.15	Motion Sensor	0.00	8,760	2,523
14	Capen Hall	B - 3	Corridors	6	CFQ13/1-L	15	0.09	Light Switch	6	CFQ13/1-L	15	0.09	Motion Sensor	0.00	8,760	197
15	Capen Hall	all	Stairwells	21	F41LL	32	0.67	Light Switch	21	F41LL	32	0.67	Motion Sensor	0.00	8,760	438
16	Scudder Hall	B - 3	Corridors	128	CFS9/1	9	1.15	Light Switch	128	CFS9/1	9	1.15	Motion Sensor	0.00	8,760	5,592
17	Scudder Hall	B - 3	Corridors	6	CFQ13/1-L	15	0.09	Light Switch	6	CFQ13/1-L	15	0.09	Motion Sensor	0.00	8,760	197
18	Scudder Hall	all	Stairwells	21	F41LL	32	0.67	Light Switch	21	F41LL	32	0.67	Motion Sensor	0.00	8,760	438
19	Bliss Hall	B - 3	Corridors	128	CFS9/1	9	1.15	Light Switch	128	CFS9/1	9	1.15	Motion Sensor	0.00	8,760	5,592
20	Bliss Hall	B - 3	Corridors	6	CFQ13/1-L	15	0.09	Light Switch	6	CFQ13/1-L	15	0.09	Motion Sensor	0.00	8,760	197
21	Bliss Hall	all	Stairwells	21	F41LL	32	0.67	Light Switch	21	F41LL	32	0.67	Motion Sensor	0.00	8,760	438
22	Bouton Hall	B - 3	Corridors	114	CFS9/1	9	1.03	Light Switch	114	CFS9/1	9	1.03	Motion Sensor	0.00	8,760	5,592
23	Bouton Hall	B - 3	Corridors	1	CFQ13/1-L	15	0.02	Light Switch	1	CFQ13/1-L	15	0.02	Motion Sensor	0.00	8,760	2,247
24	Bouton Hall	all	Stairwells	20	F41LL	32	0.64	Light Switch	20	F41LL	32	0.64	Motion Sensor	0.00	8,760	438
25	Gage Hall	B - 3	Corridors	114	CFS9/1	9	1.03	Light Switch	114	CFS9/1	9	1.03	Motion Sensor	0.00	8,760	5,326
26	Gage Hall	B - 3	Corridors	1	CFQ13/1-L	15	0.02	Light Switch	1	CFQ13/1-L	15	0.02	Motion Sensor	0.00	8,760	2,247
27	Gage Hall	all	Stairwells	20	F41LL	32	0.64	Light Switch	20	F41LL	32	0.64	Motion Sensor	0.00	8,760	438
28	Lenape	1, 2, 3	Corridors	93	F23LL	52	4.84	Light Switch	93	F23LL	52	4.84	Motion Sensor	0.00	8,760	10,591
29	Lenape	all	Stairwells	54	F41LL	32	1.73	Light Switch	54	F41LL	32	1.73	Motion Sensor	0.00	8,760	14,380
30	Esopus	1, 2, 3	Corridors	183	F23LL	52	9.52	Light Switch	183	F23LL	52	9.52	Motion Sensor	0.00	8,760	20,840
31	Esopus	all	Stairwells	33	F41LL	32	1.06	Light Switch	33	F41LL	32	1.06	Motion Sensor	0.00	8,760	8,788
32	College Hall / Shango	1, 2, 3	Corridors	6	CFQ13/1-L	15	0.09	Light Switch	6	CFQ13/1-L	15	0.09	Motion Sensor	0.00	8,760	197
33	College Hall / Shango	1, 2, 3	Corridors	98	F41LL	32	3.14	Light Switch	98	F41LL	32	3.14	Motion Sensor	0.00	8,760	6,868
34	College Hall / Shango	all	Stairwells	56	F41LL	32	1.79	Light Switch	56	F41LL	32	1.79	Motion Sensor	0.00	8,760	14,913
Total Pre Fixt.				1,573		Total Pre kW	36	Total Post Fixt.	1,573		Total Post kW	36	Total kW Saved		Total Annual kWh Saved	143,986



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-C2 Sitewide Exterior Lighting

Site Data	
Annual Hours of Darkness	4,284 hours

Utility Costs	
Electricity:	\$0.107 /kWh
Natural Gas:	\$0.858 /Therm

Existing Exterior Lighting			Proposed Exterior Lighting							
Lighting Fixture Type	Wattage	Quantity	Total Watts	Annual kWh	Total Cost (\$)	Wattage	Quantity	Total Watts	Annual kWh	Total Cost (\$)
Wall Pack mounted at High Level	295	50	14,750	63,189	\$6,776	92	50	4,600	19,706	\$2,113
Wall Pack mounted at Low Level	138	70	9,660	41,383	\$4,438	46	70	3,220	13,794	\$1,479
Pole Fixture - Acorn Type	188	162	30,456	130,474	\$13,991	35	162	5,670	24,290	\$2,605
Pole Fixture - Moon Type	188	159	29,892	128,057	\$13,732	35	159	5,565	23,840	\$2,556
Pole Fixture - Metal Halide Type	295	58	17,110	73,299	\$7,860	79	58	4,582	19,629	\$2,105
Pole Fixture - Standard Type	465	218	101,370	434,269	\$46,568	155	218	33,790	144,756	\$15,523
Pole Fixture - LED	93	146	13,578	58,168	\$6,238	93	146	13,578	58,168	\$6,238
Totals		863	216,816	928,840	\$99,602			71,005	304,185	\$32,619

Savings Summary	
Site Electricity Savings (kWh):	624,654
Site Gas Savings (Therms):	0
Energy Savings (MMBTU Source):	7,119
Cost Savings (\$):	\$ 66,983
Emissions Reduction (lb CO ₂):	1,274,757
Cost Estimate (\$):	\$ 539,131
Simple payback:	8.0



Project Name:	SUNY New Paltz
Project Number:	4013032.01
ECM-C3	Premium Efficiency Motors/VFD Controls

Utility Costs		
Annual Runtime	3,192	hours
Typical VFD Energy Reduction	68%	
Supply Air	1500	cfm/HP
Outdoor Air	20%	
Heating Space Temp	70	°F
Average Heating Outdoor Air Temp	40	°F
Heating Efficiency	78%	
Annual Heating Season Hours	5,684	hours
Cooling Space Temp	72	°F
Cooling Space Enthalpy	23.2	Btu/lb-da
Average Cooling Outdoor Air Temp	79	°F
Average Cooling Outdoor Air Enthalpy	33.4	Btu/lb-da
Average Cooling Efficiency	1.0	kW/ton
Annual Cooling Season Hours	3,076	hours

Utility Costs		
Electricity:	\$0.090	/kWh
Natural Gas:	\$0.858	/Therm

Equipment Details					Baseline			Proposed			Energy Savings		HVAC OA Savings		
Building	Type	Unit Name	Motor hp	RPM	Motor Efficiency	Motor Energy Usage (kW)	Motor Energy Usage (kWh)	Motor Efficiency	Motor Energy Usage (kW)	Motor Energy Usage (kWh)	Motor Energy Usage (kWh)	Motor Energy Usage (kWh)	Reduction in OA cfm	Heating Savings (Therm)	Cooling Savings (kWh)
Sojourner Truth Library	HVAC	LS-1	5	1,800	84.3%	4.4	14,124	90.3%	4.1	13,185	0.3	938	474	1,135	5,603
Sojourner Truth Library	HVAC	LS-2	10	1,800	87.4%	8.5	27,245	92.4%	8.1	25,771	0.5	1,474	948	2,269	11,207
Sojourner Truth Library	HVAC	LS-3	15	1,800	88.8%	12.6	40,224	93.4%	12.0	38,242	0.6	1,981	1,422	3,404	16,810
Sojourner Truth Library	HVAC	LS-4	15	1,800	88.8%	12.6	40,224	93.4%	12.0	38,242	0.6	1,981	1,422	3,404	16,810
Sojourner Truth Library	HVAC	LS-5	10	1,800	87.4%	8.5	27,245	92.4%	8.1	25,771	0.5	1,474	948	2,269	11,207
Sojourner Truth Library	HVAC	LS-6	3	1,800	83.2%	2.7	8,586	89.8%	2.5	7,955	0.2	631	284	681	3,362
Sojourner Truth Library	PUMP	HW-1	7.5	1,800	86.0%	6.5	36,979	91.8%	6.1	34,643	0.4	2,336	0	0	0
Sojourner Truth Library	PUMP	HW-2	7.5	1,800	86.0%	6.5	36,979	91.8%	6.1	34,643	0.4	2,336	0	0	0
Sojourner Truth Library	PUMP	HW-3	7.5	1,800									0	0	0
Elting Gym	HVAC	AHU-4	20	1,800	89.4%	16.7	53,271	93.4%	16.0	50,990	0.7	2,281	1,896	4,538	22,413
Smiley Arts	HVAC	HV-5	7.5	1,800	86.0%	6.5	20,767	91.8%	6.1	19,455	0.4	1,312	711	1,702	8,405
Smiley Arts	HVAC	HV-6	7.5	1,800	86.0%	6.5	20,767	91.8%	6.1	19,455	0.4	1,312	711	1,702	8,405
Smiley Arts	HVAC	HV-7	7.5	1,800	86.0%	6.5	20,767	91.8%	6.1	19,455	0.4	1,312	711	1,702	8,405
McKenna	HVAC	HV-1	7.5	1,800	86.0%	6.5	20,767	91.8%	6.1	19,455	0.4	1,312	711	1,702	8,405
McKenna	HVAC	HV-2	7.5	1,800	86.0%	6.5	20,767	91.8%	6.1	19,455	0.4	1,312	711	1,702	8,405
McKenna	HVAC	HV-4	7.5	1,800	86.0%	6.5	20,767	91.8%	6.1	19,455	0.4	1,312	711	1,702	8,405
Dorsky	HVAC	SA-1	10	1,800	87.4%	8.5	27,245	92.4%	8.1	25,771	0.5	1,474	948	2,269	11,207
Dorsky	HVAC	AHU-1	10	1,800	87.4%	8.5	27,245	92.4%	8.1	25,771	0.5	1,474	948	2,269	11,207
Dorsky	HVAC	AHU-2	10	1,800	87.4%	8.5	27,245	92.4%	8.1	25,771	0.5	1,474	948	2,269	11,207
Parker Theatre	HVAC	AHU	7.5	1,800	86.0%	6.5	20,767	91.8%	6.1	19,455	0.4	1,312	711	1,702	8,405
Student Union	HVAC	AC-3	15	1,800	88.8%	12.6	40,224	93.4%	12.0	38,242	0.6	1,981	1,422	3,404	16,810
Student Union	HVAC	AC-4	10	1,800	87.4%	8.5	27,245	92.4%	8.1	25,771	0.5	1,474	948	2,269	11,207
Student Union	HVAC	AC-1	20	1,800	89.4%	16.7	53,271	93.4%	16.0	50,990	0.7	2,281	1,896	4,538	22,413
Coykendall	HVAC	AHU-6	5	1,800	84.3%	4.4	14,124	90.3%	4.1	13,185	0.3	938	474	1,135	5,603
Coykendall	HVAC	AHU-4	7.5	1,800	86.0%	6.5	20,767	91.8%	6.1	19,455	0.4	1,312	711	1,702	8,405
Haggerty Admin	HVAC	AC-5 RF	20	1,800	89.4%	16.7	53,271	93.4%	16.0	50,990	0.7	2,281	1,896	4,538	22,413
Haggerty Admin	HVAC	AC-5 SF	7.5	1,800	86.0%	6.5	20,767	91.8%	6.1	19,455	0.4	1,312	711	1,702	8,405
Haggerty Admin	PUMP	HW-1	10	1,800	87.4%	8.5	48,516	92.4%	8.1	45,890	0.5	2,625	0	0	0
Haggerty Admin	PUMP	HW-2	10	1,800									0	0	0
Vandenberg Hall	PUMP	HWP-1	7.5	1,800	86.0%	6.5	36,979	91.8%	6.1	34,643	0.4	2,336	0	0	0
Vandenberg Hall	PUMP	HWP-3	7.5	1,800									0	0	0
Service Building	PUMP	HW-1	15	1,800	88.8%	12.6	71,626	93.4%	12.0	68,098	0.6	3,528	0	0	0
Service Building	PUMP	HW-2	15	1,800									0	0	0
Lenape	PUMP	HW-1	7.5	1,800	86.0%	6.5	36,979	91.8%	6.1	34,643	0.4	2,336	0	0	0
Lenape	PUMP	HW-2	7.5	1,800	86.0%	6.5	36,979	91.8%	6.1	34,643	0.4	2,336	0	0	0
Lenape	PUMP	HW-3	7.5	1,800									0	0	0
Lecture Center	PUMP	HW-1	10	1,800	87.4%	8.5	48,516	92.4%	8.1	45,890	0.5	2,625	0	0	0
Lecture Center	PUMP	HW-2	10	1,800									0	0	0
Athletic Center	PUMP	HW-1	30	1,800	89.4%	25.0	142,291	93.4%	24.0	136,197	1.1	6,094	0	0	0
Athletic Center	PUMP	HW-2	30	1,800									0	0	0
Coykendall Science	PUMP	P-3	10	1,800	87.4%	8.5	48,516	92.4%	8.1	45,890	0.5	2,625	0	0	0
Coykendall Science	PUMP	P-4	10	1,800									0	0	0
Resnick	HVAC	VAV unit	25	1,800	89.4%	20.9	66,589	93.4%	20.0	63,737	0.9	2,852	2,370	5,673	28,016
Totals						325.8	1,278,637		308.5	1,210,656	17.3	67,981	25,644	61,382	303,137

Savings Summary	
Site Electricity Savings (kWh):	371,118
Site Gas Savings (Therms):	61,382
Energy Savings (MMBTU Source):	10,656
Cost Savings (\$):	\$ 85,869
Emissions Reduction (lb CO ₂):	1,505,287
Cost Estimate (\$):	\$ 365,534
Simple payback:	4.3

Assumptions

- (1) VFD Reductions from "Control your energy costs with variable-frequency drives" - Wisconsin Focus on Energy https://focusonenergy.com/sites/default/files/controlingcostsvfd_factsheet.pdf
- (2) Heating Savings based on the following assumptions: 1500 cfm supply air/HP, 20% outdoor air
- (3) Cooling Savings based on the following assumptions: 1500 cfm supply air/HP, 20% outdoor air
- (4) Motor Efficiency Values have been obtained from US DOE's Motormaster International program



Project Name:	SUNY New Paltz
Project Number:	4013032.01
ECM-C4	

Chilled Water Temperature Reset - Summary

Savings Summary	
Estimated Cost to Implement	\$12,425
Site Electric Savings [kWh]	24,231
Site Heating Savings (therm)	-
Total Source Savings (MMBTU)	276
Cost Savings (\$)	\$2,170
Simple Payback [years]	5.73
Emissions Reduction (lb CO ₂):	49,449

Utility Costs	
Electricity:	\$0.090 /kWh
Natural Gas:	\$0.858 /Therm

	Existing Case	Proposed Case	Savings [unit]	Savings [\$]
Electrical Consumption [kwh / yr]	1,575,322.22	1,551,091.23	24,230.99	\$ 2,169.65
Natural Gas Consumption [therms / yr]	-	-		
Implementation Cost [\$]		\$12,425		
Totals				\$ 2,169.65

Building	Prior Existing Conditions		Revised Conditions	
	Yearly Energy Consumption (kWh)	Yearly Energy Cost (\$)	Yearly Energy Consumption (kWh)	Yearly Energy Cost (\$)
Lecture Center	492,500	44,099	487,535	43,654
Old Main Building	185,072	16,571	178,451	15,979
Student Union	417,878	37,417	412,926	36,974
Esopus Residence Hall	213,628	19,128	210,249	18,826
Lenape Residence Hall	213,628	19,128	210,249	18,826
Health Services	52,616	4,711	51,681	4,627
Totals	1,575,322	141,055	1,551,091	138,885



Project Name: SUNY New Paltz
 Project Number: 4013032.01
 ECA/CL-3 Chilled Water Temperature Reset
 Building: Lecture Center

Summary	
Estimated Cost to Implement	\$ 1,500.00
Estimated recurring yearly consumption savings (kWh)	4,964.42
Estimated recurring yearly savings	\$ 444.52
Simple Payback (years)	3.37

	Existing Case	Proposed Case	Savings (unit)	Savings (\$)
Electrical Consumption (kWh/yr)	492,499.56	487,535.14	4,964.42	\$ 444.52
Natural Gas Consumption (therms/yr)	0.0	0.0		
Implementation Cost (\$)		\$ 1,500.00		
Total				\$ 444.52

Calculations Inputs

Cooling Load Profile	Chilled Water Reset Schedule			Return Water Temperature Schedule	
	OAT	Cooling Load	CHWST	CHWST	CHWT
95	140	95	48	48	55
85	700	95	45	48	55

OAT factor of chiller plant	0.5
Plant DP Setpoint (ft)	30
Plant DP Setpoint (ft)	80.5
Existing chilled water temp. setpoint	45
Existing chilled water return temp. (F)	55
% decrease in energy consumption	2.5%
Motor Efficiency	88%
Motor Efficiency	90%

Chiller Part Load Performance		
% Load	Water Flow	kW/ton
100%	0.594	
75%	0.43	
50%	0.32	
25%	0.15	
PLV	0.377	

Calculations

Weather Data		Performance Data			Existing Condition			Recommended Operating Strategy			Estimated Savings				
Bin	DBT	Hours	Estimated Cooling Load (ton)	% Load	Estimated kW/ton	Chilled Water Supply Temp (F)	Chilled Water Return Temp (F)	Chilled Water Supply Temp (F)	Chilled Water Return Temp (F)	Chilled Water Supply Temp. Increase (F)	Net decrease in chiller power consumption (%)	Yearly Energy Consumption (kWh)	Reduction in chiller power consumption (kW)	Pump power reduction in consumption (kW)	Overall Energy Consumption Reduction (kWh)
80 to 85	82.5	12	165	65%	0.65	45	55	45.2	55.0	0	0.4%	4,469	1.65	0.67	11
85 to 90	87.5	98	595	85%	0.50	45	55	45.5	55.0	0	1%	28,270	3.69	1.86	174
90 to 95	92.5	311	625	75%	0.43	45	55	45.8	55.0	0	2%	69,628	4.70	2.84	580
75 to 80	77.5	391	455	65%	0.39	45	55	46.2	55.0	1	3%	88,342	5.14	3.57	614
70 to 75	72.5	579	385	55%	0.35	45	55	46.5	55.0	1	4%	76,804	4.88	4.04	546
65 to 70	67.5	744	315	45%	0.31	45	55	47.2	55.0	2	5%	67,738	4.69	3.47	483
60 to 65	62.5	911	245	35%	0.27	45	55	47.5	55.0	2	6%	57,649	4.52	4.03	413
55 to 60	57.5	885	175	25%	0.24	45	55	47.5	55.0	3	7%	47,672	4.89	3.47	1,257
50 to 55	52.5	837	0	0%	0.00	45	55	47.8	55.0	3	7%	0	0.00	0	0
45 to 50	47.5	750	0	0%	0.00	45	55	48.0	55.0	3	8%	0	0.00	0	0
40 to 45	42.5	756	0	0%	0.00	45	55	48.0	55.0	3	8%	0	0.00	0	0
35 to 40	37.5	747	0	0%	0.00	45	55	48.0	55.0	3	8%	0	0.00	0	0
30 to 35	32.5	553	0	0%	0.00	45	55	48.0	55.0	3	8%	0	0.00	0	0
25 to 30	27.5	374	0	0%	0.00	45	55	48.0	55.0	3	8%	0	0.00	0	0
20 to 25	22.5	214	0	0%	0.00	45	55	48.0	55.0	3	8%	0	0.00	0	0
15 to 20	17.5	214	0	0%	0.00	45	55	48.0	55.0	3	8%	0	0.00	0	0
10 to 15	12.5	127	0	0%	0.00	45	55	48.0	55.0	3	8%	0	0.00	0	0
5 to 10	7.5	110	0	0%	0.00	45	55	48.0	55.0	3	8%	0	0.00	0	0
0 to 5	2.5	33	0	0%	0.00	45	55	48.0	55.0	3	8%	0	0.00	0	0
-5 to 0	-2.5	20	0	0%	0.00	45	55	48.0	55.0	3	8%	0	0.00	0	0
-10 to -5	-7.5	10	0	0%	0.00	45	55	48.0	55.0	3	8%	0	0.00	0	0
-15 to -10	-12.5	10	0	0%	0.00	45	55	48.0	55.0	3	8%	0	0.00	0	0
Total			4,922.00									487,535			4,964

Assumptions:
 - 2.5% decrease in energy consumption per degree Fahrenheit rise in temperature from http://apps1.eere.energy.gov/building/publications/pdfs/alliances/haa_chillers_fs.pdf



Project Name: SUNY New Paltz
 Project Number: 401002.01
 ECM-C4
 Building: Old Main Building

Summary			
Estimated Cost to Implement	\$	1,500.00	
Estimated recurring yearly consumption savings (kWh)		6,620.91	
Estimated recurring yearly savings (\$)	\$	592.84	
Simple Payback (Years)		2.53	
Electrical Consumption			
Existing Case	Proposed Case	Savings (unit)	Savings (\$)
185,072.28	176,451.38	6,620.91	\$ 592.84
Natural Gas Consumption			
0.0	0.0	0.0	
Implementation Cost (\$)			
			\$ 592.84

Calculation Inputs

Cooling Load Profile			
QAT	Cooling Load	Chilled Water Reset Schedule	Return Water Temperature
52.5	250	43	48
85	250	43	48
OAT kickout of chiller plant			
Plant DP Setpoint (psd)		55	
Plant DP Setpoint (ft)		2.5	
Existing chilled water temp. setpoint			
Existing chilled water return temp. (F)		43	
Existing chilled water supply temp. (F)		53	
per 1°F rise in temp.			
Pump efficiency		2.5%	http://apps1.eere.energy.gov/buildings/publications/pdfs/alliances/hea_chillers_is.pdf
Motor Efficiency		90%	

Chiller Part Load Performance		
% Load	kW/Ton	kWh/Ton
100%	0.45	0.45
75%	0.34	0.34
50%	0.34	0.34
25%	0.47	0.47
IPLV: 0.40		

Calculations

Weather Data			Performance Data			Existing Condition			Recommended Operating Strategy			Estimated Savings				
Bin	DBT	Hours	Estimated Cooling Load (ton)	% Load	Estimated kW/Ton	Chilled Water Supply Temp (F)	Chilled Water Return Temp (F)	Chilled Water flow (gpm)	Chilled Water Return Temp (F)	Chilled Water Supply Temp. Increase (F)	Net Decrease in chiller power consumption (%)	Yearly Energy Consumption (kWh)	Reduction in chiller power consumption (kW)	Pumping Penalty (kW)	Overall in reduction consumption (kWh)	Overall Energy Consumption Reduction (kWh)
30 to 95	92.5	12	238	95%	0.59	43	53	570	53.0	570	0%	1,683	0.00	-	0	0
60 to 95	82.5	43	163	75%	0.46	43	53	460	43.4	460	1%	1,433	0.76	0	184	184
75 to 95	72.5	391	163	65%	0.41	43	53	380	44.1	417	3%	25,404	1,778	0.17	1	509
70 to 75	72.5	579	138	55%	0.36	43	53	330	44.8	370	4%	28,031	2,223	0.47	2	885
65 to 70	67.5	774	113	45%	0.37	43	53	270	45.5	318	6%	31,988	2,598	0.84	2	1,343
60 to 65	62.5	885	83	25%	0.42	43	53	198	46.2	246	10%	36,552	2,894	1.18	2	1,530
55 to 60	57.5	885	63	25%	0.47	43	53	150	46.9	198	10%	24,185	2,894	0.82	2	1,330
50 to 55	52.5	837	0	0%	0.00	43	53	0	47.6	54.9	12%	0	0.00	-	0	0
45 to 50	47.5	604	0	0%	0.00	43	53	0	48.0	55.0	13%	0	0.00	-	0	0
40 to 50	42.5	525	0	0%	0.00	43	53	0	48.0	55.0	13%	0	0.00	-	0	0
35 to 45	37.5	747	0	0%	0.00	43	53	0	48.0	55.0	13%	0	0.00	-	0	0
30 to 35	32.5	553	0	0%	0.00	43	53	0	48.0	55.0	13%	0	0.00	-	0	0
25 to 30	27.5	374	0	0%	0.00	43	53	0	48.0	55.0	13%	0	0.00	-	0	0
20 to 25	22.5	237	0	0%	0.00	43	53	0	48.0	55.0	13%	0	0.00	-	0	0
15 to 20	17.5	144	0	0%	0.00	43	53	0	48.0	55.0	13%	0	0.00	-	0	0
10 to 15	12.5	53	0	0%	0.00	43	53	0	48.0	55.0	13%	0	0.00	-	0	0
5 to 10	7.5	110	0	0%	0.00	43	53	0	48.0	55.0	13%	0	0.00	-	0	0
0 to 5	2.5	77	0	0%	0.00	43	53	0	48.0	55.0	13%	0	0.00	-	0	0
-5 to 5	-2.5	110	0	0%	0.00	43	53	0	48.0	55.0	13%	0	0.00	-	0	0
-10 to -5	-7.5	20	0	0%	0.00	43	53	0	48.0	55.0	13%	0	0.00	-	0	0
-15 to -10	-12.5	10	0	0%	0.00	43	53	0	48.0	55.0	13%	0	0.00	-	0	0
												185,072	178,451	6,621	6,621	

Assumptions: -2.5% decrease in energy consumption per degree Fahrenheit rise in temperature from http://apps1.eere.energy.gov/buildings/publications/pdfs/alliances/hea_chillers_is.pdf



Project Name STONY New Plaza
Project Number 401302.01
ECM/C4 Chilled Water Temperature Reset
Building Student Union

Summary	
Estimated Cost to Implement	\$ 1,500.00
Estimated recurring yearly consumption savings (kWh)	4,952.61
Estimated recurring Simple Payback (years)	443.46
	3.38

	Existing Case	Proposed Case	Savings (unit)	Savings (\$)
Electrical Consumption [kWh/yr]	412,025.81	412,025.81	4,952.61	\$ 443.46
Natural Gas Consumption [therms/yr]	n/a	n/a		
Implementation Cost (\$)				
Total				\$ 443.46

Calculation Inputs

Cooling Load Profile		Chilled Water Reset Schedule		Return Water Temperature Schedule	
OAT	Cooling Load	OAT	Cooling Load	CHWST	CHWT
65	130	60	46	44	54
95	600	85	44	46	55

OAT: outside of chiller plant
 Plant DFP Setpoint (DB)
 Existing chilled water temp. setpoint (F)
 Existing chilled water return temp. (F)
 Existing chiller water temp. setpoint (F)
 per 1°F rise in temp.

Pump efficiency: 85%
 Motor Efficiency: 90%

Chiller Part Load Performance		
% Load		kWh/ton
100%	0.59	
75%	0.43	
50%	0.32	
25%	0.44	
PLV	0.37	

Calculations

Bin	Weather Data		Performance Data		Existing Condition		Recommended Operating Strategy		Estimated Savings														
	DBT	Hours	Estimated Cooling Load (ton)	% Load	Estimated kW/Ton	Chilled Water Supply Temp (F)	Chilled Water Return Temp (F)	Chilled Water Flow (gpm)	Chilled Water Supply Temp (F)	Chilled Water Return Temp (F)	Chilled Water Flow (gpm)	Chilled Water Supply Temp (F)	Chilled Water Return Temp (F)	Chilled Water Flow (gpm)	Chilled Water Supply Temp (F)	Chilled Water Return Temp (F)	Chilled Water Flow (gpm)	Net decrease in chiller power consumption (%)	Yearly Energy Consumption (kWh)	Reduction in chiller power consumption (kW)	Pumping Penalty (kW)	Overall Energy Consumption Reduction (kWh)	
80 to 85	82.5	12	570	95%	0.25	44	54	1,224	44.0	54.0	1,224	44.0	54.0	1,224	44.0	54.0	1,224	0%	3,600	0.00	-	0	
85 to 90	87.5	98	510	85%	0.49	44	54	1,080	44.0	54.0	1,080	44.0	54.0	1,080	44.0	54.0	1,080	0%	24,520	0.00	-	0	
90 to 95	92.5	311	450	75%	0.43	44	54	900	44.1	54.1	900	44.1	54.1	900	44.1	54.1	900	0%	59,435	0.00	-	0	
95 to 100	97.5	156	390	65%	0.50	44	54	780	44.2	54.2	780	44.2	54.2	780	44.2	54.2	780	0%	84,686	0.00	-	0	
100 to 105	102.5	570	330	55%	0.34	44	54	732	44.7	54.7	852	44.7	54.7	852	44.7	54.7	852	2%	71,153	2.00	0.33	625	
65 to 70	67.5	774	270	42%	0.35	44	54	648	45.0	54.5	652	45.0	54.5	652	45.0	54.5	652	3%	71,153	2.33	1.09	982	
70 to 75	72.5	911	210	35%	0.39	44	54	504	45.3	54.6	539	45.3	54.6	539	45.3	54.6	539	3%	73,818	2.66	1.10	1,416	
75 to 80	77.5	885	150	25%	0.44	44	54	360	45.6	54.8	391	45.6	54.8	391	45.6	54.8	391	4%	57,298	2.61	0.98	1,442	
80 to 85	82.5	604	0	0%	0.00	44	54	0	46.0	55.0	0	46.0	55.0	0	46.0	55.0	0	5%	0	0.00	-	0	
85 to 90	87.5	756	0	0%	0.00	44	54	0	46.0	55.0	0	46.0	55.0	0	46.0	55.0	0	5%	0	0.00	-	0	
90 to 95	92.5	747	0	0%	0.00	44	54	0	46.0	55.0	0	46.0	55.0	0	46.0	55.0	0	5%	0	0.00	-	0	
95 to 100	97.5	354	0	0%	0.00	44	54	0	46.0	55.0	0	46.0	55.0	0	46.0	55.0	0	5%	0	0.00	-	0	
100 to 105	102.5	327	0	0%	0.00	44	54	0	46.0	55.0	0	46.0	55.0	0	46.0	55.0	0	5%	0	0.00	-	0	
20 to 25	22.5	337	0	0%	0.00	44	54	0	46.0	55.0	0	46.0	55.0	0	46.0	55.0	0	5%	0	0.00	-	0	
15 to 20	17.5	214	0	0%	0.00	44	54	0	46.0	55.0	0	46.0	55.0	0	46.0	55.0	0	5%	0	0.00	-	0	
10 to 15	12.5	127	0	0%	0.00	44	54	0	46.0	55.0	0	46.0	55.0	0	46.0	55.0	0	5%	0	0.00	-	0	
5 to 10	7.5	77	0	0%	0.00	44	54	0	46.0	55.0	0	46.0	55.0	0	46.0	55.0	0	5%	0	0.00	-	0	
0 to 5	2.5	17	0	0%	0.00	44	54	0	46.0	55.0	0	46.0	55.0	0	46.0	55.0	0	5%	0	0.00	-	0	
-5 to 0	-2.5	33	0	0%	0.00	44	54	0	46.0	55.0	0	46.0	55.0	0	46.0	55.0	0	5%	0	0.00	-	0	
-10 to -5	-7.5	20	0	0%	0.00	44	54	0	46.0	55.0	0	46.0	55.0	0	46.0	55.0	0	5%	0	0.00	-	0	
-15 to -10	-12.5	10	0	0%	0.00	44	54	0	46.0	55.0	0	46.0	55.0	0	46.0	55.0	0	5%	0	0.00	-	0	
																				417,676			412,928

Assumptions:
 - 2.5% decrease in energy consumption per degree Fahrenheit rise in temperature from http://apps1.eere.energy.gov/buildings/publications/pdfs/lanonthea_chillers_1a.pdf



Project Name SUNY New Paltz
Project Number 401302.01
ECM/CLC Chilled Water Temperature Reset
Building Esopus Residence Hall

Summary	
Estimated Cost to Implement	\$ 1,500.00
Estimated recurring yearly consumption savings (kWh)	3,376.70
Estimated recurring Simple Payback (years)	302.53
	4.96

	Existing Case	Proposed Case	Savings (units)	Savings (\$)
Electrical Consumption (kWh/yr)	213,627.86	210,249.19	3,378.70	\$ 302.53
Natural Gas Consumption (liters/yr)	n/a	n/a		
Implementation Cost (\$)		\$ 1,500.00		
Payback (years)				\$ 302.53

Calculation Inputs

Cooling Load Profile		Chilled Water Reset Schedule		Return Water Temperature Schedule	
OAT	Cooling Load	OAT	Cooling Load	CHWS	CHWT
55	33	50	46	44	46
95	165	85	44	46	55

Chiller Part Load Performance	
% Load	kW/Ton
100%	1.09
75%	0.79
50%	0.60
25%	0.52
PLV	0.69

http://eps1.eere.energy.gov/buildings/publications/pdfs/alliances/hea_chillers_ls.pdf

Calculations

Weather Data		Performance Data		Existing Condition		Recommended Operating Strategy		Estimated Savings							
Bin	DBT	Hours	Estimated Cooling Load (tons)	% Load	Estimated kW/Ton	Chilled Water Supply Temp (F)	Chilled Water Return Temp (F)	Chilled Water Flow (gpm)	Water Supply Temp Increase (F)	Net decrease in consumption (%)	Yearly Energy Consumption (kWh)	Reduction in chiller power consumption (kW)	Pumping Penalty (kW)	Overall reduction in consumption (kW)	Overall Energy Reduction (kWh)
90 to 95	92.5	12	157	95%	1.03	44	54	376	0	0%	1,343	0.00	-	0	0
85 to 90	87.5	98	140	85%	0.91	44	54	337	0	0%	12,535	0.00	-	0	0
80 to 85	82.5	311	107	65%	0.71	44	54	267	0	0%	10,164	0.00	-	0	0
75 to 80	77.5	301	107	65%	0.71	44	54	267	0	1%	20,885	0.02	0.18	0	290
70 to 75	72.5	579	91	55%	0.64	44	54	226	1	2%	32,931	1.03	0.26	1	447
65 to 70	67.5	774	74	45%	0.64	44	54	178	1	3%	38,866	1.19	0.30	1	690
60 to 65	62.5	911	58	35%	0.73	44	54	139	1	3%	38,612	1.36	0.30	1	862
55 to 60	57.5	845	41	25%	0.82	44	54	107	2	5%	29,079	0.00	0.27	0	92
50 to 55	52.5	837	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0	0
45 to 50	47.5	604	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0	0
40 to 45	42.5	756	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0	0
35 to 40	37.5	471	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0	0
30 to 35	32.5	453	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0	0
25 to 30	27.5	374	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0	0
20 to 25	22.5	337	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0	0
15 to 20	17.5	214	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0	0
10 to 15	12.5	110	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0	0
5 to 10	7.5	67	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0	0
0 to 5	2.5	33	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0	0
-5 to 0	-2.5	33	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0	0
-10 to -5	-7.5	10	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0	0
-15 to -10	-12.5	10	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0	0
											210,249				3,379

Assumptions:
 -2.5% decrease in energy consumption per degree Fahrenheit rise in temperature from http://eps1.eere.energy.gov/buildings/publications/pdfs/alliances/hea_chillers_ls.pdf



Project Name: SUNY New Paltz
 Project Number: 401032.00
 ECL-CL4 Chilled Water Temperature Reset
 Building: Lenape Residence Hall

Summary	
Estimated Cost to Implement	\$ 1,500.00
Estimated recurring yearly consumption savings (kWh)	3,378.70
Estimated recurring energy savings (\$/yr)	\$ 302.53
Simple Payback (Years)	4.96

	Existing Case	Proposed Case	Savings Limit	Savings (\$)
Electrical Consumption (kwh/yr)	213,627.89	210,249.19	3,378.70	\$ 302.53
Natural Gas Consumption (liters/yr)	n/a	n/a		
Concentration Cost (\$)		\$ 1,500.00		
Totals				\$ 302.53

Calculation Inputs

Cooling Load Profile	Chilled Water Reset Schedule		Return Water Temperature Schedule	
	OAT	Cooling Load	CHWS*	CHWT
OAT	55	33	50	54
55	165	48	44	46
OAT lockout of chiller plant				
Plant DP Setpoint (psi)				
Plant DP Setpoint (psi)				
Plant DP Setpoint (psi)				
Existing chilled water return temp. (F)				
% decrease in energy consumption per 1°F rise in temp				
MEWP Efficiency				

Chiller Part Load Performance	
% Load	kWh/Ton
100%	1.09
75%	0.79
50%	0.60
25%	0.83
PLV	0.69

http://apps1.ene.energy.gov/buildings/publications/pdfs/alliances/hea_chillers_t.s.pdf

Calculations

Weather Data		Performance Data		Existing Condition		Recommended Operating Strategy		Estimated Savings						
Bin	DBT	Hours	Estimated Cooling Load (ton)	% Load	Estimated kWh/Ton	Chilled Water Supply Temp (F)	Chilled Water Return Temp (F)	Chilled Water flow (gpm)	Chilled Water Supply Temp. Increase (F)	No decrease in chiller power consumption (%)	Year's Energy Consumption (kWh)	Reduction in chiller power consumption (kW)	Pumping Penalty (kW)	Overall Energy Consumption Reduction (kWh)
90 to 95	52.5	12	157	58%	1.03	44	54	376	0	0%	1,943	0.00	-	0
85 to 90	61.5	39	146	58%	0.79	44	54	237	0	0%	1,745	0.00	-	0
80 to 85	70.5	31	124	75%	0.71	44	54	230	0	0%	30,454	0.82	0.07	88
75 to 80	77.5	391	107	65%	0.64	44	54	257	0	1%	29,911	0.82	0.18	250
70 to 75	84.5	579	91	55%	0.64	44	54	218	1	2%	33,378	1.03	0.26	447
65 to 70	91.5	774	74	45%	0.64	44	54	188	1	3%	38,895	1.19	0.30	680
60 to 65	98.5	885	61	35%	0.64	44	54	159	2	4%	45,176	1.33	0.30	1,042
55 to 60	105.5	885	41	25%	0.62	44	54	107	2	4%	30,029	1.33	0.27	942
50 to 55	112.5	857	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0
45 to 50	119.5	604	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0
40 to 45	126.5	525	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0
35 to 40	133.5	325	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0
30 to 35	140.5	553	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0
25 to 30	147.5	374	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0
20 to 25	154.5	337	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0
15 to 20	161.5	127	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0
10 to 15	168.5	110	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0
5 to 10	175.5	77	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0
0 to 5	182.5	30	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0
-5 to 0	189.5	20	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0
-10 to -5	196.5	10	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0
-15 to -10	203.5	10	0	0%	0.00	44	54	0	2	5%	0	0.00	-	0
Totals											213,628	210,249		3,379

Newlines: -2.5% decrease in energy consumption per degree Fahrenheit rise in temperature from http://apps1.ene.energy.gov/buildings/publications/pdfs/alliances/hea_chillers_t.s.pdf



Project Name: SUNY New Paltz
Project Number: 401002.01
ECM/C4: Chilled Water Temperature Reset
Building: Health Services

Summary	
Estimated Cost to Implement	\$ 1,500.00
Estimated recurring yearly consumption savings (kWh)	935.66
Estimated recurring Simple Payback (years)	83.78
	17.90

	Existing Case	Proposed Case	Savings (unit)	Savings (\$)
Electrical Consumption (kWh/yr)	52,616.18	51,680.52	935.66	\$ 83.78
Natural Gas Consumption (liters/yr)	n/a	n/a		
Implementation Cost (\$)		\$ 1,500.00		
Net Savings				\$ 83.78

Calculation Inputs

Cooling Load Profile		Chilled Water Reset Schedule		Return Water Temperature Schedule	
OAT	Cooling Load	OAT	Cooling Load	CHWST	CHWT
55	5	50	46	44	54
95	25	85	44	46	55

OAT lockout of chiller plant	55
Plant DP Setpoint (psi)	45
Plant DP Setpoint (ft)	103.5
Chiller Setpoint (F)	54
Existing chilled water return temp. (F)	54
% decrease in energy consumption per 1°F rise in temp.	2.6%
Plant efficiency	95%
Power Efficiency	38%

Chiller Part Load Performance	
% Load	100%
	75%
	50%
	25%
IPLV	1.18

Calculations

Bin	Weather Data		Performance Data		Existing Condition		Recommended Operating Strategy		Estimated Savings		Overall Energy Consumption Reduction (kWh)						
	DBT	Hours	Estimated Cooling Load (ton)	% Load	Estimated kW/Ton	Chilled Water Supply Temp (F)	Chilled Water Return Temp (F)	Chilled Water flow (gpm)	Chilled Water Return Temp (F)	Chilled Water flow (gpm)		Temp. Increase (F)	Net decrease in chiller power consumption (%)	Yearly Energy Consumption (kWh)	Reduction in power consumption (kW)	Pumping Penalty (kW)	Overall reduction in power consumption (kWh)
9.0 to 35.0	92.5	12	24	95%	1.18	44	54	57	44.0	54.0	0	0%	335	0.00	-	0	
35.0 to 50.0	87.5	98	21	85%	1.18	44	54	51	44.0	54.0	0	0%	2,450	0.00	-	0	
50.0 to 65.0	82.5	391	16	65%	1.18	44	54	40	44.4	54.2	0	1%	7,408	0.20	0.01	71	
65.0 to 80.0	77.5	579	14	55%	1.18	44	54	33	44.4	54.2	0	1%	9,221	0.20	0.03	69	
80.0 to 95.0	72.5	774	11	45%	1.18	44	54	27	44.7	54.4	1	2%	10,023	0.29	0.04	145	
95.0 to 110.0	67.5	774	11	45%	1.18	44	54	27	45.0	54.5	28	3%	10,244	0.33	0.06	221	
110.0 to 125.0	62.5	885	9	35%	1.18	44	54	22	45.0	54.5	28	3%	10,244	0.33	0.06	221	
125.0 to 140.0	57.5	885	6	25%	1.18	44	54	15	45.6	54.9	16	4%	6,288	0.20	0.04	220	
140.0 to 155.0	52.5	837	0	0%	0.00	44	54	0	45.9	54.9	0	5%	0	0.00	-	0	
155.0 to 170.0	47.5	604	0	0%	0.00	44	54	0	46.0	55.0	0	5%	0	0.00	-	0	
170.0 to 185.0	42.5	709	0	0%	0.00	44	54	0	46.0	55.0	0	5%	0	0.00	-	0	
185.0 to 200.0	37.5	553	0	0%	0.00	44	54	0	46.0	55.0	0	5%	0	0.00	-	0	
200.0 to 215.0	32.5	374	0	0%	0.00	44	54	0	46.0	55.0	0	5%	0	0.00	-	0	
215.0 to 230.0	27.5	337	0	0%	0.00	44	54	0	46.0	55.0	0	5%	0	0.00	-	0	
230.0 to 245.0	22.5	127	0	0%	0.00	44	54	0	46.0	55.0	0	5%	0	0.00	-	0	
245.0 to 260.0	17.5	110	0	0%	0.00	44	54	0	46.0	55.0	0	5%	0	0.00	-	0	
260.0 to 275.0	12.5	77	0	0%	0.00	44	54	0	46.0	55.0	0	5%	0	0.00	-	0	
275.0 to 290.0	7.5	33	0	0%	0.00	44	54	0	46.0	55.0	0	5%	0	0.00	-	0	
290.0 to 305.0	2.5	10	0	0%	0.00	44	54	0	46.0	55.0	0	5%	0	0.00	-	0	
305.0 to 320.0	-2.5	3	0	0%	0.00	44	54	0	46.0	55.0	0	5%	0	0.00	-	0	
320.0 to 335.0	-7.5	1	0	0%	0.00	44	54	0	46.0	55.0	0	5%	0	0.00	-	0	
335.0 to 350.0	-12.5	1	0	0%	0.00	44	54	0	46.0	55.0	0	5%	0	0.00	-	0	
-15.0 to -10.0	-12.5	10	0	0%	0.00	44	54	0	46.0	55.0	0	5%	0	0.00	-	0	
													51,681				936

Assumptions:
 -2.0% decrease in energy consumption per degree Fahrenheit rise in temperature from http://epsst.energeny.gov/buildings/publications/pdfs/eflancechwa_chillers_fs.pdf



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-C5 Demand Controlled Ventilation

Utility Costs	
Electricity:	\$0.090 /kWh
Natural Gas:	\$0.858 /Therm

Building	Existing Conditions		Proposed Conditions			Energy Savings	
	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Electric Energy Savings (kWh)
Elting Gym	32,446	4,515	0	32,446	3,104	0	0
Parker Theater	11,928	4,150	10,547	11,928	2,853	7,251	3,296
Old Library	117,695	16,377	48,571	117,695	11,259	33,393	15,178
Lecture Center	23,857	4,980	5,571	23,857	3,104	0	5,571
Student Union	83,499	6,971	7,721	83,499	4,793	5,308	2,413
McKenna Theater	15,905	2,213	6,564	15,905	1,522	4,513	2,051
Totals	285,330	39,206	78,973	285,330	26,635	50,464	28,509

Savings Summary	
Site Electricity Savings (kWh):	28,509
Site Gas Savings (Therms):	12,571
Energy Savings (MMBTU Source):	1,641
Cost Savings (\$):	\$ 13,334
Emissions Reduction (lb CO ₂):	17,419
Cost Estimate (\$):	\$ 77,308
Simple payback:	5.8

Assumptions:
 - Assume that 7 control points and 3 CO₂ sensors are needed per AHU, plus a controller and Networking



Project Name: SUNY New Paltz
 Project Number: 4013032.01
 ECM+C5 Demand Controlled Ventilation: Elting Gym

AHU details			
Unit:	HV-1	HV-2	Totals
Motor Nameplate Size	5	5	10
Calculated Air Flow: (cfm)	15,300	15,300	30,600
% Outdoor Air Flow:	20%	20%	20%
Fan Static Efficiency: (%)	53%	53%	
Total Static Pressure: (in)	1.50	1.50	
Calculated Fan Power: (BHP)	6.8	6.8	13.6
Calculated Fan Power: (kW)	5.08	5.08	10
Calculated OA Flow: (cfm)	3,060	3,060	6,120
Proposed Average % OA:			14%
Average Heating Efficiency (kW/ton)			78%
Average Cooling Efficiency (kW/ton)			0

Heating/Cooling	
Cooling Space Enthalpy:	25.3 Btu/lb
Heating Space Temp:	70 °F

Utility Costs	
Natural Gas:	\$0.858 /therm
Electricity:	\$0.090 /kWh

Weather Data	Baseline					Proposed					Savings				
	ΔT (°F)	Mid-pits (°F)	h (Btu/lb)	Total Run Hours	Fan Power (kW)	OA Flow (CFM)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Fan Power (kW)	OA Flow (CFM)	Fan Energy (kWh)	Heating Energy (therm)	Electric Energy Savings (kWh)	Heating Energy Savings (therm)
90 to 95	92.5	36.3	4	4	10.16	6,120	41	-	0	10.16	4,208	41	-	0	-
85 to 90	87.5	37.5	60	60	10.16	6,120	610	-	0	10.16	4,208	610	-	0	-
80 to 85	82.5	35.1	199	199	10.16	6,120	2,023	-	0	10.16	4,208	2,023	-	0	-
75 to 80	77.5	32.2	239	239	10.16	6,120	2,429	-	0	10.16	4,208	2,429	-	0	-
70 to 75	72.5	29.9	242	242	10.16	6,120	2,460	-	0	10.16	4,208	2,460	-	0	-
65 to 70	67.5	26.6	294	294	10.16	6,120	2,988	-	0	10.16	4,208	2,988	-	0	-
60 to 65	62.5	23.8	330	330	10.16	6,120	3,354	-	0	10.16	4,208	3,354	-	0	-
55 to 60	57.5	21.6	291	291	10.16	6,120	2,958	308	-	10.16	4,208	2,958	212	-	96
50 to 55	52.5	18.3	288	288	10.16	6,120	2,927	427	-	10.16	4,208	2,927	294	-	133
45 to 50	47.5	16.3	227	227	10.16	6,120	2,307	433	-	10.16	4,208	2,307	298	-	135
40 to 45	42.5	14.4	293	293	10.16	6,120	2,978	683	-	10.16	4,208	2,978	469	-	213
35 to 40	37.5	12.6	191	191	10.16	6,120	1,941	526	-	10.16	4,208	1,941	362	-	164
30 to 35	32.5	10.8	164	164	10.16	6,120	1,667	521	-	10.16	4,208	1,667	358	-	163
25 to 30	27.5	8.8	98	98	10.16	6,120	996	353	-	10.16	4,208	996	243	-	110
20 to 25	22.5	7	99	99	10.16	6,120	1,006	398	-	10.16	4,208	1,006	274	-	125
15 to 20	17.5	5.5	67	67	10.16	6,120	681	298	-	10.16	4,208	681	205	-	93
10 to 15	12.5	3.7	42	42	10.16	6,120	427	205	-	10.16	4,208	427	141	-	64
5 to 10	7.5	2.5	34	34	10.16	6,120	346	180	-	10.16	4,208	346	124	-	56
0 to 5	2.5	1.2	17	17	10.16	6,120	173	97	-	10.16	4,208	173	67	-	30
-5 to 0	-2.5	0.1	6	6	10.16	6,120	61	37	-	10.16	4,208	61	25	-	12
-10 to -5	-7.5	-1.2	1	1	10.16	6,120	10	7	-	10.16	4,208	10	5	-	3
-15 to -10	-12.5	-2.6	6	6	10.16	6,120	61	42	-	10.16	4,208	61	29	-	13
Totals			3,192				32,446	4,515	0			32,446	3,104	0	1,411

Savings Summary	
Site Electricity Savings (kWh, \$):	0 \$0
Site Gas Savings (Therm, \$):	1,411 \$1,210
Total Cost Savings (\$):	\$1,210

Assumptions:
 - Proposed outdoor airflow based on assumed schedule: On 7am-7pm M-F, Off Sat-Sun
 - Savings based on the following assumptions: 1500 cfm supply air/HP, 20% outdoor air
 - Fan speeds can be adjusted in the following manner during occupied hours:

OAT (°F)	Fan Speed
> 80	85%
79 - 70	70%
69 - 40	60%
< 40	50%



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-C5 Demand Controlled Ventilation: Parker Theater

AHU details		AC-4	Totals
Unit:	Motor Nameplate Size	8	8
	Calculated Air Flow: (cfm)	11,250	11,250
	% Outdoor Air Flow:	50%	50%
	Fan Static Efficiency: (%)	53%	
	Total Static Pressure: (in)	1.50	
	Calculated Fan Power: (BHP)	5.0	5.0
	Calculated Fan Power: (kW)	3.74	4
	Calculated OA Flow: (cfm)	5,625	5,625
	Proposed Average % OA:		34%
	Average Heating Efficiency		78%
	Average Cooling Efficiency (kW/ton)		0.857

Heating/Cooling		Btu/lb	'F
Cooling Space Enthalpy:		25.3	
Heating Space Temp:		70	

Utility Costs		therm	kWh
Natural Gas:		\$0.858	
Electricity:		\$0.090	

ΔT (°F)	Weather Data				Baseline				Proposed				Savings		
	Mid-pis (°F)	h (Btu/lb)	Total Run Hours	Fan Power (kW)	OA Flow (CFM)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Fan Power (kW)	OA Flow (CFM)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Electric Energy Savings (kWh)	Heating Energy Savings (therm)
90 to 95	92.5	36.3	4	3.74	5,625	15	-	79	3.74	3,867	15	-	55	25	-
85 to 90	87.5	37.5	60	3.74	5,625	224	-	1,319	3.74	3,867	224	-	907	412	-
80 to 85	82.5	35.1	199	3.74	5,625	744	-	3,513	3.74	3,867	744	-	2,415	1,098	-
75 to 80	77.5	32.2	239	3.74	5,625	893	-	2,966	3.74	3,867	893	-	2,039	927	-
70 to 75	72.5	29.9	242	3.74	5,625	904	-	1,997	3.74	3,867	904	-	1,373	624	-
65 to 70	67.5	26.6	294	3.74	5,625	1,099	-	672	3.74	3,867	1,099	-	462	210	-
60 to 65	62.5	23.8	330	3.74	5,625	1,233	-	-	3.74	3,867	1,233	-	-	-	-
55 to 60	57.5	21.6	291	3.74	5,625	1,087	283	-	3.74	3,867	1,087	195	-	-	89
50 to 55	52.5	18.3	288	3.74	5,625	1,076	393	3.74	3,867	1,076	270	123	-	-	123
45 to 50	47.5	16.3	227	3.74	5,625	848	398	3.74	3,867	848	273	124	-	-	124
40 to 45	42.5	14.4	293	3.74	5,625	1,095	628	3.74	3,867	1,095	431	196	-	-	196
35 to 40	37.5	12.6	191	3.74	5,625	714	483	3.74	3,867	714	332	151	-	-	151
30 to 35	32.5	10.8	164	3.74	5,625	613	479	3.74	3,867	613	329	150	-	-	150
25 to 30	27.5	8.8	98	3.74	5,625	366	324	3.74	3,867	366	223	101	-	-	101
20 to 25	22.5	7	99	3.74	5,625	370	366	3.74	3,867	370	252	114	-	-	114
15 to 20	17.5	5.5	67	3.74	5,625	350	274	3.74	3,867	350	188	86	-	-	86
10 to 15	12.5	3.7	42	3.74	5,625	157	188	3.74	3,867	157	129	59	-	-	59
5 to 10	7.5	2.5	34	3.74	5,625	127	166	3.74	3,867	127	114	52	-	-	52
0 to 5	2.5	1.2	17	3.74	5,625	64	89	3.74	3,867	64	61	28	-	-	28
-5 to 0	-2.5	0.1	6	3.74	5,625	22	34	3.74	3,867	22	23	11	-	-	11
-10 to -5	-7.5	-1.2	1	3.74	5,625	4	6	3.74	3,867	4	4	2	-	-	2
-15 to -10	-12.5	-2.6	6	3.74	5,625	22	39	3.74	3,867	22	27	12	-	-	12
Totals			3,192	-	-	11,928	4,150	10,547	-	-	11,928	2,853	7,251	3,296	1,297

Savings Summary	
Site Electricity Savings (kWh, \$):	\$295
Site Gas Savings (Therm, \$):	\$1,112
Total Cost Savings (\$):	\$1,407

Assumptions:
 - Proposed outdoor airflow based on assumed schedule: On 7am-7pm M-F, Off Sat-Sun
 - Fan speeds can be adjusted in the following manner during occupied hours:
 OAT (°F)

> 80	85%
79 - 70	70%
69 - 40	60%
< 40	50%

AHU details		LS-1	LS-2	LS-3	LS-4	LS-5	Totals
Unit:	Motor Nameplate Size	15	10	15	15	19	74
	Calculated Air Flow: (cfm)	22,500	15,000	22,500	22,500	28,500	111,000
	% Outdoor Air Flow:	20.0%	20.0%	20.0%	20.0%	20.0%	20%
	Fan Static Efficiency: (%)	53%	53%	53%	53%	53%	53%
	Total Static Pressure: (in)	1.50	1.50	1.50	1.50	1.50	1.50
	Calculated Fan Power: (BHP)	10.0	6.7	10.0	10.0	12.7	49
	Calculated Fan Power: (kW)	7.47	4.98	7.47	7.47	9.47	37
	Proposed Average % OA:	4,500	3,000	4,500	4,500	5,700	22,200
	Average Heating Efficiency (kW/ton)						14%
	Average Cooling Efficiency (kW/ton)						78%

Heating/Cooling		Btu/lb	°F
Cooling Space Enthalpy:		25.3	
Heating Space Temp:		70	

Utility Costs		therm	kWh
Natural Gas:		\$0.858	
Electricity:		\$0.090	

Weather Data	Baseline						Proposed						Savings			
	ΔT (°F)	Mkt-pts (°F)	h (Btu/lb)	Total Run Hours	Fan Power (kW)	OA Flow (CFM)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Fan Power (kW)	OA Flow (CFM)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Electric Energy Savings (kWh)	Heating Energy Savings (therm)
90 to 95	92.5	36.3	36.3	4	36.87	22,200	147	-	365	36.87	15,263	147	-	251	114	
85 to 90	87.5	37.5	37.5	60	36.87	22,200	2,212	-	6,076	36.87	15,263	2,212	-	4,178	1,899	
80 to 85	82.5	35.1	35.1	199	36.87	22,200	7,337	-	16,177	36.87	15,263	7,337	-	11,122	5,055	
75 to 80	77.5	32.2	32.2	239	36.87	22,200	8,812	-	13,659	36.87	15,263	8,812	-	9,391	4,268	
70 to 75	72.5	29.9	29.9	242	36.87	22,200	8,923	-	9,197	36.87	15,263	8,923	-	6,323	2,874	
65 to 70	67.5	26.6	26.6	294	36.87	22,200	10,840	-	3,096	36.87	15,263	10,840	-	2,129	968	
60 to 65	62.5	23.8	23.8	330	36.87	22,200	12,168	-	-	36.87	15,263	12,168	-	-	-	
55 to 60	57.5	21.6	21.6	291	36.87	22,200	10,730	1,118	-	36.87	15,263	10,730	769	-	-	349
50 to 55	52.5	18.3	18.3	288	36.87	22,200	10,619	1,549	-	36.87	15,263	10,619	1,065	-	-	484
45 to 50	47.5	16.3	16.3	227	36.87	22,200	8,370	1,570	-	36.87	15,263	8,370	1,079	-	-	491
40 to 45	42.5	14.4	14.4	293	36.87	22,200	10,803	2,477	-	36.87	15,263	10,803	1,703	-	-	774
35 to 40	37.5	12.6	12.6	191	36.87	22,200	7,042	1,908	-	36.87	15,263	7,042	1,312	-	-	596
30 to 35	32.5	10.8	10.8	164	36.87	22,200	6,047	1,890	-	36.87	15,263	6,047	1,300	-	-	591
25 to 30	27.5	8.8	8.8	98	36.87	22,200	3,613	1,280	-	36.87	15,263	3,613	880	-	-	400
20 to 25	22.5	7	7	99	36.87	22,200	2,470	1,445	-	36.87	15,263	2,470	994	-	-	452
15 to 20	17.5	5.5	5.5	67	36.87	22,200	2,470	1,081	-	36.87	15,263	2,470	743	-	-	338
10 to 15	12.5	3.7	3.7	42	36.87	22,200	1,549	742	-	36.87	15,263	1,549	510	-	-	232
5 to 10	7.5	2.5	2.5	34	36.87	22,200	1,254	653	-	36.87	15,263	1,254	449	-	-	204
0 to 5	2.5	1.2	1.2	17	36.87	22,200	627	353	-	36.87	15,263	627	242	-	-	110
-5 to 0	-2.5	0.1	0.1	6	36.87	22,200	221	134	-	36.87	15,263	221	92	-	-	42
-10 to -5	-7.5	-1.2	-1.2	6	36.87	22,200	37	24	-	36.87	15,263	37	16	-	-	7
-15 to -10	-12.5	-2.6	-2.6	6	36.87	22,200	221	152	-	36.87	15,263	221	105	-	-	48
Totals				3,192										33,393	15,178	5,118

Savings Summary	
Site Electricity Savings (kWh, \$):	15,178
Site Gas Savings (Therm, \$):	5,118
Total Cost Savings (\$):	\$5,748

Assumptions:
- Proposed outdoor airflow based on assumed schedule: On 7am-7pm M-F, Off Sat-Sun
- Fan speeds can be adjusted in the following manner during occupied hours:

OAT (°F)	Fan Speed
> 80	85%
79 - 70	70%
69 - 40	60%
< 40	50%



Project Name: SUNY New Paltz
 Project Number: 4013032.01
 ECML-C5 Demand Controlled Ventilation: Lecture Center

AHU details	
Unit:	LC-1 LC-2 LC-3 Totals
Motor Nameplate Size	7.5 7.5 7.5 23
Calculated Air Flow: (cfm)	11,250 11,250 11,250 33,750
% Outdoor Air Flow:	20.0% 20.0% 20.0% 20%
Fan Static Efficiency: (%)	53% 53% 53%
Total Static Pressure: (in)	1.50 1.50 1.50
Calculated Fan Power: (BHP)	3.74 3.74 3.74 7.5
Calculated Fan Power: (kW)	2250 2250 2250 6,750
Proposed Average % OA:	14%
Average Heating Efficiency	78%
Average Cooling Efficiency (kW/ton)	0.38

Heating/Cooling	
Cooling Space Enthalpy:	25.3 Btu/lb
Heating Space Temp:	70 °F
Utility Costs	
Natural Gas:	\$0.858 /therm
Electricity:	\$0.090 /kWh

Weather Data	Baseline					Proposed					Savings					
	ΔT (°F)	Mtd-pts (°F)	h (Btu/lb)	Total Run Hours	Fan Power (kW)	OA Flow (CFM)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Fan Power (kW)	OA Flow (CFM)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Electric Energy Savings (kWh)	Heating Energy Savings (therm)
90 to 95	92.5	36.3	4	7.47	6,750	30	42	7.47	4.641	30	29	13				
85 to 90	87.5	37.5	60	7.47	6,750	448	697	7.47	4.641	448	479	218				
80 to 85	82.5	35.1	199	7.47	6,750	1,487	1,856	7.47	4.641	1,487	1,276	580				
75 to 80	77.5	32.2	239	7.47	6,750	1,786	1,567	7.47	4.641	1,786	1,077	490				
70 to 75	72.5	29.9	242	7.47	6,750	1,809	1,055	7.47	4.641	1,809	725	330				
65 to 70	67.5	26.6	294	7.47	6,750	2,197	355	7.47	4.641	2,197	244	111				
60 to 65	62.5	23.8	330	7.47	6,750	2,466	-	7.47	4.641	2,466	-	-				
55 to 60	57.5	21.6	291	7.47	6,750	2,175	340	7.47	4.641	2,175	234	106				
50 to 55	52.5	18.3	288	7.47	6,750	2,153	471	7.47	4.641	2,153	324	147				
45 to 50	47.5	16.3	227	7.47	6,750	1,697	471	7.47	4.641	1,697	328	149				
40 to 45	42.5	14.4	293	7.47	6,750	2,190	753	7.47	4.641	2,190	518	235				
35 to 40	37.5	12.6	191	7.47	6,750	1,428	580	7.47	4.641	1,428	399	181				
30 to 35	32.5	10.8	164	7.47	6,750	1,226	575	7.47	4.641	1,226	395	180				
25 to 30	27.5	8.8	98	7.47	6,750	732	389	7.47	4.641	732	268	122				
20 to 25	22.5	7	99	7.47	6,750	740	440	7.47	4.641	740	302	137				
15 to 20	17.5	5.5	67	7.47	6,750	501	329	7.47	4.641	501	226	103				
10 to 15	12.5	3.7	42	7.47	6,750	314	226	7.47	4.641	314	155	71				
5 to 10	7.5	2.5	34	7.47	6,750	254	199	7.47	4.641	254	137	62				
0 to 5	2.5	1.2	17	7.47	6,750	127	107	7.47	4.641	127	74	34				
-5 to 0	-2.5	0.1	6	7.47	6,750	45	41	7.47	4.641	45	28	13				
-10 to -5	-7.5	-1.2	1	7.47	6,750	7	7	7.47	4.641	7	5	2				
-15 to -10	-12.5	-2.6	6	7.47	6,750	45	46	7.47	4.641	45	32	14				
Totals			3,192			23,857	4,980				23,857	3,423		3,830	1,741	1,556

Savings Summary	
Site Electricity Savings (kWh, \$):	1,741 \$156
Site Gas Savings (Therm, \$):	1,556 \$1,334
Total Cost Savings (\$):	\$1,490

Assumptions:
 - Proposed outdoor airflow based on assumed schedule: On 7am-7pm M-F, Off Sat-Sun
 - Fan speeds can be adjusted in the following manner during occupied hours:

OAT (°F)	Fan Speed
> 80	85%
79 - 70	70%
69 - 40	60%
< 40	50%



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-C5 Demand Controlled Ventilation: Student Union

AHU details		AC-3	AC-4	AC-9	AC-10	Totals
Unit:		15	5	7.5	30	58
Motor Nameplate Size		15,000	7,500	11,250	45,000	78,750
Calculated Air Flow: (cfm)		12.0%	12.0%	12.0%	12.0%	12%
% Outdoor Air Flow:		53%	53%	53%	53%	
Fan Static Efficiency: (%)		1.50	1.50	1.50	1.50	
Total Static Pressure: (in)		6.7	3.3	5.0	20.0	35
Calculated Fan Power: (BHP)		4.98	2.49	3.74	14.95	26
Calculated Fan Power: (kW)		1800	900	1350	5400	9,450
Proposed Average % OA:						8%
Average Heating Efficiency (kW/ton)						78%
Average Cooling Efficiency (kW/ton)						0.37

Heating/Cooling		Btu/lb	°F
Cooling Space Enthalpy:		25.3	
Heating Space Temp:		70	

Utility Costs		therm	kWh
Natural Gas:		\$0.858	
Electricity:		\$0.090	

Weather Data		Baseline					Proposed					Savings			
ΔT (°F)	Mtd-pts (°F)	h (Btu/lb)	Total Run Hours	Fan Power (kW)	OA Flow (CFM)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Fan Power (kW)	OA Flow (CFM)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Electric Energy Savings (kWh)	Heating Energy Savings (therm)
90 to 95	92.5	36.3	4	26.16	9,450	105	-	58	26.16	6,497	105	-	40	18	-
85 to 90	87.5	37.5	60	26.16	9,450	1,570	-	966	26.16	6,497	1,570	-	664	302	-
80 to 85	82.5	35.1	199	26.16	9,450	5,206	-	2,571	26.16	6,497	5,206	-	1,768	804	-
75 to 80	77.5	32.2	239	26.16	9,450	6,252	-	2,171	26.16	6,497	6,252	-	1,493	678	-
70 to 75	72.5	29.9	242	26.16	9,450	6,330	-	1,462	26.16	6,497	6,330	-	1,005	457	-
65 to 70	67.5	26.6	294	26.16	9,450	7,691	-	492	26.16	6,497	7,691	-	338	154	-
60 to 65	62.5	23.8	330	26.16	9,450	8,632	-	-	26.16	6,497	8,632	-	-	-	-
55 to 60	57.5	21.6	291	26.16	9,450	7,612	476	-	26.16	6,497	7,612	327	-	-	149
50 to 55	52.5	18.3	288	26.16	9,450	7,534	659	-	26.16	6,497	7,534	453	-	-	206
45 to 50	47.5	16.3	227	26.16	9,450	5,938	668	-	26.16	6,497	5,938	459	-	-	209
40 to 45	42.5	14.4	293	26.16	9,450	7,665	1,054	-	26.16	6,497	7,665	725	-	-	329
35 to 40	37.5	12.6	191	26.16	9,450	4,906	812	-	26.16	6,497	4,906	588	-	-	254
30 to 35	32.5	10.8	164	26.16	9,450	4,290	805	-	26.16	6,497	4,290	553	-	-	251
25 to 30	27.5	8.8	98	26.16	9,450	2,564	545	-	26.16	6,497	2,564	375	-	-	170
20 to 25	22.5	7	99	26.16	9,450	2,590	615	-	26.16	6,497	2,590	423	-	-	192
15 to 20	17.5	5.5	67	26.16	9,450	1,753	460	-	26.16	6,497	1,753	316	-	-	144
10 to 15	12.5	3.7	42	26.16	9,450	1,099	316	-	26.16	6,497	1,099	217	-	-	99
5 to 10	7.5	2.5	34	26.16	9,450	889	278	-	26.16	6,497	889	191	-	-	87
0 to 5	2.5	1.2	17	26.16	9,450	445	150	-	26.16	6,497	445	103	-	-	47
-5 to 0	-2.5	0.1	6	26.16	9,450	157	57	-	26.16	6,497	157	39	-	-	18
-10 to -5	-7.5	-1.2	1	26.16	9,450	26	10	-	26.16	6,497	26	7	-	-	3
-15 to -10	-12.5	-2.6	6	26.16	9,450	157	65	-	26.16	6,497	157	45	-	-	20
Totals			3,192			83,499	6,971	7,721			83,499	4,793	5,308	2,413	2,179

Savings Summary	
Site Electricity Savings (kWh, \$):	2,413 \$216
Site Gas Savings (Therm, \$):	2,179 \$1,868
Total Cost Savings (\$):	\$2,084

Assumptions:
 - Proposed outdoor airflow based on assumed schedule: On 7am-7pm M-F, Off Sat-Sun
 - Fan speeds can be adjusted in the following manner during occupied hours:

OAT (°F)	Fan Speed
> 80	85%
79 - 70	70%
69 - 40	60%
< 40	50%



Project Name: SUNY New Paltz
 Project Number: 4013032.01
 ECML-C5

Demand Controlled Ventilation: Elting Gym

AHU details		Totals	
Unit:	HV-1	10	10
Motor Nameplate Size	15,000	15,000	15,000
Calculated Air Flow: (cfm)	20.0%	20%	20%
% Outdoor Air Flow:	53%		
Fan Static Efficiency: (%)	1.50		
Total Static Pressure: (in)	6.7		
Calculated Fan Power: (BHP)	4.98	5	6.7
Calculated Fan Power: (kW)	3,000	3,000	3,000
Calculated OA Flow: (cfm)		14%	
Proposed Average % OA:		78%	
Average Heating Efficiency			
Average Cooling Efficiency (kW/ton)			1

Heating/Cooling	
Cooling Space Enthalpy:	25.3 Btu/lb
Heating Space Temp:	70 °F
Utility Costs	
Natural Gas:	\$0.858 /therm
Electricity:	\$0.090 /kWh

ΔT (°F)	Weather Data				Baseline				Proposed				Savings		
	Mid-pt (°F)	h (Btu/lb)	Total Run Hours	Fan Power (kW)	OA Flow (CFM)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Fan Power (kW)	OA Flow (CFM)	Fan Energy (kWh)	Heating Energy (therm)	Cooling Energy (kWh)	Electric Energy Savings (kWh)	Heating Energy Savings (therm)
9.0 to 9.5	92.5	36.3	4	4.98	3,000	20	-	49	4.98	2,063	20	-	34	15	-
8.5 to 9.0	87.5	37.5	60	4.98	3,000	299	-	821	4.98	2,063	299	-	565	257	-
8.0 to 8.5	82.5	35.1	199	4.98	3,000	992	-	2,186	4.98	2,063	992	-	1,503	683	-
7.5 to 8.0	77.5	32.2	239	4.98	3,000	1,191	-	1,846	4.98	2,063	1,191	-	1,269	577	-
7.0 to 7.5	72.5	29.9	242	4.98	3,000	1,206	-	1,243	4.98	2,063	1,206	-	854	388	-
6.5 to 7.0	67.5	26.6	294	4.98	3,000	1,465	-	418	4.98	2,063	1,465	-	288	131	-
6.0 to 6.5	62.5	23.8	330	4.98	3,000	1,644	-	-	4.98	2,063	1,644	-	-	-	-
5.5 to 6.0	57.5	21.6	291	4.98	3,000	1,450	151	-	4.98	2,063	1,450	104	-	-	47
5.0 to 5.5	52.5	18.3	288	4.98	3,000	1,435	209	-	4.98	2,063	1,435	144	-	-	65
4.5 to 5.0	47.5	16.3	227	4.98	3,000	1,131	212	-	4.98	2,063	1,131	146	-	-	66
4.0 to 4.5	42.5	14.4	293	4.98	3,000	1,460	335	-	4.98	2,063	1,460	230	-	-	105
3.5 to 4.0	37.5	12.6	191	4.98	3,000	952	258	-	4.98	2,063	952	177	-	-	81
3.0 to 3.5	32.5	10.8	164	4.98	3,000	817	255	-	4.98	2,063	817	176	-	-	80
2.5 to 3.0	27.5	8.8	98	4.98	3,000	488	173	-	4.98	2,063	488	119	-	-	54
2.0 to 2.5	22.5	7	99	4.98	3,000	493	195	-	4.98	2,063	493	134	-	-	61
1.5 to 2.0	17.5	5.5	67	4.98	3,000	334	146	-	4.98	2,063	334	100	-	-	46
1.0 to 1.5	12.5	3.7	42	4.98	3,000	209	100	-	4.98	2,063	209	69	-	-	31
.5 to 1.0	7.5	2.5	34	4.98	3,000	169	88	-	4.98	2,063	169	61	-	-	28
0 to .5	2.5	1.2	17	4.98	3,000	85	48	-	4.98	2,063	85	33	-	-	15
-5 to 0	-2.5	0.1	6	4.98	3,000	30	18	-	4.98	2,063	30	12	-	-	6
-10 to -5	-7.5	-1.2	1	4.98	3,000	5	3	-	4.98	2,063	5	2	-	-	1
-15 to -10	-12.5	-2.6	6	4.98	3,000	30	21	-	4.98	2,063	30	14	-	-	6
Totals			3,192			15,905	2,213	6,564			15,905	1,522	4,513	2,051	692


Savings Summary	
Site Electricity Savings (kWh, \$):	2,051 \$184
Site Gas Savings (Therm, \$):	692 \$593
Total Cost Savings (\$):	\$777

Assumptions:
 - Proposed outdoor airflow based on assumed schedule: On 7am-7pm M-F, Off Sat-Sun
 - Fan speeds can be adjusted in the following manner during occupied hours:
 OAT (°F)

> 80	85%
79 - 70	70%
69 - 40	60%
< 40	50%

Project Name:	SUNY New Paltz
Project Number:	4013032.01
ECM-C5	Demand Controlled Ventilation: Occupancy Profile

Building Occupancy Profile					
Hour	Baseline		Proposed		OA CFM
	% Min OA	OA CFM	% Min OA	OA CFM	
7am - 8am	20%		10%		
8am - 9am	20%		10%		
9am - 10am	20%		15%		
10am - 11am	20%		20%		
11am - 12pm	20%		20%		
12pm - 1pm	20%		20%		
1pm - 2pm	20%		20%		
2pm - 3pm	20%		15%		
3pm - 4pm	20%		15%		
4pm - 5pm	20%		10%		
5pm - 6pm	20%		5%		
6pm - 7pm	20%		5%		
Total Hours		12		12	
Avg % OA		20%		14%	



- Min OA is based on assumed typical building occupancy
- OA flow can be further reduced if CO₂ sensors can show no occupancy
- AHUs are assumed to provide consistent levels of OA during occupied hours



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-C6 Kitchen Exhaust Hood Control System

Utility Costs	
Electricity:	\$0.090 /kWh
Natural Gas:	\$0.858 /Therm

Energy Savings Summary				
	Existing Fan Energy (kWh)	Existing Heating Use (Therms)	Proposed Fan Energy (kWh)	Proposed Heating Use (Therms)
Student Union	7,674	5,156	2,632	3,609
Parker Theater	1,517	922	520	645
Hasbrouck Dining	5,581	3,656	1,914	2,559
TOTALS	14,773	9,733	5,067	6,813

- Notes:
- Reduction is based off of a study performed by the Food Service Technology Center
 - 5 degree weather BINs used for calculation and determination of heating required
 - No mechanical cooling is provided to kitchen areas.
 - System cost is based upon estimate from contractor
 - Savings includes VFD fan power reduction as well as heating energy saved.
 - Existing Fan Flow Rate and Static Pressure are assumed values as existing equipment values could not be obtained.
 - Existing flow rate calculated at 1000 CFM per linear foot of hood

Savings Summary	
Site Electricity Savings (kWh):	9,706
Site Gas Savings (Therms):	2,920
Energy Savings (MMBTU Source):	416
Cost Savings (\$):	\$ 3,373
Emissions Reduction (lb CO ₂):	55,386
Cost Estimate (\$):	\$ 21,039
Simple payback:	6.2



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-C6 Kitchen Exhaust Hood Control System
Building Student Union

Assumptions	
Exhaust Fan Flow Rate	2,750 CFM
Exhaust Fan Static Pressure	1.75 in W.G
Exhaust System Efficiency (Motor & Fan)	53%
Boiler Efficiency	78%
Typical Room Temperature Setpoint	70 Deg. F
Reduction due to VFD Usage	30%
Anticipated VFD CFM	1,925

Reduction is based off of a study performed by the Food Service Technology Center

Weather Data			Existing System BIN Analysis					Proposed System BIN Analysis					
Mid-pt	DB (F)	Total Run Hours	Fixed Speed Exhaust Fan HP	Fixed Speed Exhaust Fan kW	Fixed Speed Exhaust Fan kWh	Fixed Speed Heating Load (BTU)	Fixed Speed Heating Load (therms)	Fixed Speed Exhaust HP	VFD Exhaust HP	VFD Exhaust kW	VFD Exhaust Fan kWh	VFD Heating Load (BTU)	VFD Heating Load (therms)
92.5	90 to 95	12	1.43	1.07	12.8	0	0	1.43	0.49	0.37	4.4	0	0
87.5	85 to 90	98	1.43	1.07	104.4	0	0	1.43	0.49	0.37	35.8	0	0
82.5	80 to 85	311	1.43	1.07	331.4	0	0	1.43	0.49	0.37	113.7	0	0
77.5	75 to 80	383	1.43	1.07	408.2	0	0	1.43	0.49	0.37	140.0	0	0
72.5	70 to 75	514	1.43	1.07	547.8	0	0	1.43	0.49	0.37	187.9	0	0
67.5	65 to 70	639	1.43	1.07	681.0	0	0	1.43	0.49	0.37	233.6	0	0
62.5	60 to 65	745	1.43	1.07	794.0	0	0.0	1.43	0.49	0.37	272.3	0	0.0
57.5	55 to 60	713	1.43	1.07	759.9	33,936,058	339.4	1.43	0.49	0.37	260.6	23,755,240	237.6
52.5	50 to 55	653	1.43	1.07	695.9	43,512,404	435.1	1.43	0.49	0.37	238.7	30,458,683	304.6
47.5	45 to 50	500	1.43	1.07	532.9	42,836,538	428.4	1.43	0.49	0.37	182.8	29,985,577	299.9
42.5	40 to 45	623	1.43	1.07	664.0	65,235,288	652.4	1.43	0.49	0.37	227.7	45,664,702	456.6
37.5	35 to 40	574	1.43	1.07	611.7	71,032,500	710.3	1.43	0.49	0.37	209.8	49,722,750	497.2
32.5	30 to 35	437	1.43	1.07	465.7	62,398,558	624.0	1.43	0.49	0.37	159.7	43,678,990	436.8
27.5	25 to 30	271	1.43	1.07	288.8	43,855,096	438.6	1.43	0.49	0.37	99.1	30,698,567	307.0
22.5	20 to 25	271	1.43	1.07	288.8	49,014,519	490.1	1.43	0.49	0.37	99.1	34,310,163	343.1
17.5	15 to 20	170	1.43	1.07	181.2	33,983,654	339.8	1.43	0.49	0.37	62.1	23,788,558	237.9
12.5	10 to 15	101	1.43	1.07	107.6	22,113,173	221.1	1.43	0.49	0.37	36.9	15,479,221	154.8
7.5	5 to 10	84	1.43	1.07	89.5	19,990,385	199.9	1.43	0.49	0.37	30.7	13,993,269	139.9
2.5	0 to 5	59	1.43	1.07	62.9	15,164,135	151.6	1.43	0.49	0.37	21.6	10,614,894	106.1
-2.5	-5 to 0	20	1.43	1.07	21.3	5,521,154	55.2	1.43	0.49	0.37	7.3	3,864,808	38.6
-7.5	-10 to -5	14	1.43	1.07	14.9	4,131,346	41.3	1.43	0.49	0.37	5.1	2,891,942	28.9
-12.5	-15 to -10	9	1.43	1.07	9.6	2,827,212	28.3	1.43	0.49	0.37	3.3	1,979,048	19.8
TOTALS		7,201		1.07	7,674	515,552,019	5,156			0.37	2,632	360,886,413	3,609

Savings Analysis		
	Existing	Proposed
Fan Energy (kWh)	7,674	2,632
Heating Energy (Therms)	5,156	3,609
Totals	5,042	1,547



Project Name:	SUNY New Paltz
Project Number:	4013032.01
ECM-C6	Kitchen Exhaust Hood Control System
Building	Parker Theater

Assumptions	
Exhaust Fan Flow Rate	700 CFM
Exhaust Fan Static Pressure	1.75 in W.G
Exhaust System Efficiency (Motor & Fan)	53%
Boiler Efficiency	80%
Typical Room Temperature Setpoint	70 Deg. F
Reduction due to VFD Usage	30%
Anticipated VFD CFM	490

Reduction is based off of a study performed by the Food Service Technology Center

Mid-pt's	Weather Data			Existing System BIN Analysis						Proposed System BIN Analysis					
	DB (F)	Total Run Hours	Fixed Speed Exhaust Fan HP	Fixed Speed Exhaust Fan kW	Fixed Speed Exhaust Fan kWh	Fixed Speed Heating Load (BTU)	Fixed Speed Heating Load (therms)	Fixed Speed Exhaust HP	VFD Exhaust kW	VFD Exhaust kWh	VFD Heating Load (BTU)	VFD Heating Load (therms)			
92.5	90 to 95	12	0.36	0.27	3.3	0	0	0.36	0.12	0.09	1.1	0	0		
87.5	85 to 90	98	0.36	0.27	26.6	0	0	0.36	0.12	0.09	9.1	0	0		
82.5	80 to 85	310	0.36	0.27	84.1	0	0	0.36	0.12	0.09	28.8	0	0		
77.5	75 to 80	368	0.36	0.27	99.8	0	0	0.36	0.12	0.09	34.2	0	0		
72.5	70 to 75	440	0.36	0.27	119.4	0	0	0.36	0.12	0.09	40.9	0	0		
67.5	65 to 70	504	0.36	0.27	136.7	0	0	0.36	0.12	0.09	46.9	0	0		
62.5	60 to 65	573	0.36	0.27	155.4	0	0.0	0.36	0.12	0.09	53.3	0	0.0		
57.5	55 to 60	531	0.36	0.27	144.0	6,272,438	62.7	0.36	0.12	0.09	49.4	4,390,706	43.9		
52.5	50 to 55	482	0.36	0.27	130.8	7,971,075	79.7	0.36	0.12	0.09	44.8	5,579,753	55.8		
47.5	45 to 50	390	0.36	0.27	105.8	8,292,375	82.9	0.36	0.12	0.09	36.3	5,804,663	58.0		
42.5	40 to 45	476	0.36	0.27	129.1	12,370,050	123.7	0.36	0.12	0.09	44.3	8,659,035	86.6		
37.5	35 to 40	410	0.36	0.27	111.2	12,592,125	125.9	0.36	0.12	0.09	38.1	8,814,488	88.1		
32.5	30 to 35	295	0.36	0.27	80.0	10,454,063	104.5	0.36	0.12	0.09	27.4	7,317,844	73.2		
27.5	25 to 30	193	0.36	0.27	52.4	7,751,363	77.5	0.36	0.12	0.09	18.0	5,425,954	54.3		
22.5	20 to 25	187	0.36	0.27	50.7	8,393,963	83.9	0.36	0.12	0.09	17.4	5,875,774	58.8		
17.5	15 to 20	122	0.36	0.27	33.1	6,052,725	60.5	0.36	0.12	0.09	11.4	4,236,908	42.4		
12.5	10 to 15	74	0.36	0.27	20.1	4,020,975	40.2	0.36	0.12	0.09	6.9	2,814,683	28.1		
7.5	5 to 10	65	0.36	0.27	17.6	3,839,063	38.4	0.36	0.12	0.09	6.0	2,687,344	26.9		
2.5	0 to 5	37	0.36	0.27	10.0	2,360,138	23.6	0.36	0.12	0.09	3.4	1,652,096	16.5		
-2.5	-5 to 0	13	0.36	0.27	3.5	890,663	8.9	0.36	0.12	0.09	1.2	623,464	6.2		
-7.5	-10 to -5	5	0.36	0.27	1.4	366,188	3.7	0.36	0.12	0.09	0.5	256,331	2.6		
-12.5	-15 to -10	7	0.36	0.27	1.9	545,738	5.5	0.36	0.12	0.09	0.7	382,016	3.8		
TOTALS		5,592		0.27	1,517	92,172,938	922		0.09	520	64,521,056	645			

Savings Analysis		
	Existing	Proposed
Fan Energy (kWh)	1,517	520
Heating Energy (Therms)	922	645
Totals	997	277



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-C6 Kitchen Exhaust Hood Control System
Building Hasbrouck Dining

Assumptions	
Exhaust Fan Flow Rate	2,000 CFM
Exhaust Fan Static Pressure	1.75 in W.G
Exhaust System Efficiency (Motor & Fan)	53%
Boiler Efficiency	80%
Typical Room Temperature Setpoint	70 Deg. F
Reduction due to VFD Usage	30%
Anticipated VFD CFM	1,400

Reduction is based off of a study performed by the Food Service Technology Center

Weather Data		Existing System BIN Analysis						Proposed System BIN Analysis					
Mid-pts	DB (F)	Total Run Hours	Fixed Speed Exhaust Fan HP	Fixed Speed Exhaust Fan kW	Fixed Speed Exhaust Fan kWh	Fixed Speed Heating Load (BTU)	Fixed Speed Heating Load (therms)	Fixed Speed Exhaust HP	VFD Exhaust kW	VFD Exhaust kWh	VFD Heating Load (BTU)	VFD Heating Load (therms)	
92.5	90 to 95	12	1.04	0.78	9.3	0	0	1.04	0.36	0.27	3.2	0	
87.5	85 to 90	98	1.04	0.78	76.0	0	0	1.04	0.36	0.27	26.1	0	
82.5	80 to 85	311	1.04	0.78	241.1	0	0	1.04	0.36	0.27	82.7	0	
77.5	75 to 80	383	1.04	0.78	296.9	0	0	1.04	0.36	0.27	101.8	0	
72.5	70 to 75	514	1.04	0.78	398.4	0	0	1.04	0.36	0.27	136.6	0	
67.5	65 to 70	639	1.04	0.78	495.3	0	0	1.04	0.36	0.27	169.9	0	
62.5	60 to 65	745	1.04	0.78	577.4	0	0.0	1.04	0.36	0.27	198.1	0	
57.5	55 to 60	713	1.04	0.78	552.6	24,063,750	240.6	1.04	0.36	0.27	189.6	16,844,625	
52.5	50 to 55	653	1.04	0.78	506.1	30,854,250	308.5	1.04	0.36	0.27	173.6	21,597,975	
47.5	45 to 50	500	1.04	0.78	387.5	30,375,000	303.8	1.04	0.36	0.27	132.9	21,262,500	
42.5	40 to 45	623	1.04	0.78	482.9	46,257,750	462.6	1.04	0.36	0.27	165.6	32,380,425	
37.5	35 to 40	574	1.04	0.78	444.9	50,368,500	503.7	1.04	0.36	0.27	152.6	35,257,950	
32.5	30 to 35	437	1.04	0.78	338.7	44,246,250	442.5	1.04	0.36	0.27	116.2	30,972,375	
27.5	25 to 30	271	1.04	0.78	210.0	31,097,250	311.0	1.04	0.36	0.27	72.0	21,768,075	
22.5	20 to 25	271	1.04	0.78	210.0	34,755,750	347.6	1.04	0.36	0.27	72.0	24,329,025	
17.5	15 to 20	170	1.04	0.78	131.8	24,097,500	241.0	1.04	0.36	0.27	45.2	16,868,250	
12.5	10 to 15	101	1.04	0.78	78.3	15,680,250	156.8	1.04	0.36	0.27	26.9	10,976,175	
7.5	5 to 10	84	1.04	0.78	65.1	14,175,000	141.8	1.04	0.36	0.27	22.3	9,922,500	
2.5	0 to 5	59	1.04	0.78	45.7	10,752,750	107.5	1.04	0.36	0.27	15.7	7,526,925	
-2.5	-5 to 0	20	1.04	0.78	15.5	3,915,000	39.2	1.04	0.36	0.27	5.3	2,740,500	
-7.5	-10 to -5	14	1.04	0.78	10.9	2,929,500	29.3	1.04	0.36	0.27	3.7	2,050,650	
-12.5	-15 to -10	9	1.04	0.78	7.0	2,004,750	20.0	1.04	0.36	0.27	2.4	1,403,325	
TOTALS		7,201		0.78	5,581	365,573,250	3,656		0.27	1,914	255,901,275	2,559	

Savings Analysis		
	Existing	Proposed
Fan Energy (kWh)	5,581	1,914
Heating Energy (Therms)	3,656	1,097
Totals	3,667	1,097



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-C7 Condensing Boilers

Savings Summary	
Site Electricity Savings (kWh):	0
Site Gas Savings (Therms):	26,773
Energy Savings (MMBTU Source):	2,803
Cost Savings (\$):	\$ 22,959
Emissions Reduction (lb CO ₂):	326,227
Cost Estimate (\$):	\$ 404,210
Simple payback:	17.6



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-C7 Condensing Boiler - Day Care Center

Baseline Equipment	
# Boilers:	1
Boiler Input:	300 MBH
Boiler Efficiency:	78%

Proposed Equipment	
# Condensing Boilers:	1
Condensing Boiler Input:	300 MBH
Average Boiler Efficiency:	90%

Utility Costs	
Natural Gas:	\$0.858/therm

Weather Data		Baseline			Proposed			Savings		
Avg.	ΔT	Total hours	Heating Load (MBH)	Fraction of Annual Peak Load	Boiler Efficiency	Boiler Input (therm)	Boiler Efficiency	Boiler Input (therm)	Gas Input (therm)	Gas Input (\$)
57.5	55 to 60	885	8	3.4%	78%	92	94.6%	75	16	\$14
52.5	50 to 55	837	24	10.3%	78%	260	94.0%	216	44	\$38
47.5	45 to 50	604	40	17.2%	78%	312	93.4%	261	51	\$44
42.5	40 to 45	756	56	24.1%	78%	547	92.8%	460	87	\$75
37.5	35 to 40	747	73	31.0%	78%	695	92.1%	589	107	\$92
32.5	30 to 35	553	89	37.9%	78%	629	91.5%	536	93	\$80
27.5	25 to 30	374	105	44.8%	78%	503	90.9%	432	71	\$61
22.5	20 to 25	337	121	51.7%	78%	523	90.3%	452	71	\$61
17.5	15 to 20	214	137	58.6%	78%	376	89.7%	327	49	\$42
12.5	10 to 15	127	153	65.5%	78%	250	89.1%	219	31	\$27
7.5	5 to 10	110	169	72.4%	78%	239	88.4%	211	28	\$24
2.5	0 to 5	77	186	79.3%	78%	183	87.8%	163	20	\$18
-2.5	-5 to 0	33	202	86.2%	78%	85	87.2%	76	9	\$8
-7.5	-10 to -5	20	218	93.1%	78%	56	86.6%	50	6	\$5
-12.5	-15 to -10	10	234	100.0%	78%	30	86.0%	27	3	\$2
Total						4,259		3,649	610	\$523

Savings Summary	
Energy Savings (therm):	610
Energy Savings (\$):	\$523



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-C7 Condensing Boiler - Student Health Center

Baseline Equipment	
# Boilers:	1
Boiler Input:	789 MBH
Boiler Efficiency:	78%

Proposed Equipment	
# Condensing Boilers:	1
Condensing Boiler Input:	800 MBH
Average Boiler Efficiency:	90%

Utility Costs	
Natural Gas:	\$0.858/therm

Weather Data		Baseline			Proposed			Savings		
Avg.	ΔT	Total hours	Heating Load (MBH)	Fraction of Annual Peak Load	Boiler Efficiency	Boiler Input (therm)	Boiler Efficiency	Boiler Input (therm)	Gas Input (therm)	Gas Input (\$)
57.5	55 to 60	885	21	3.4%	78%	241	94.6%	198	42	\$36
52.5	50 to 55	837	64	10.3%	78%	683	94.0%	567	116	\$100
47.5	45 to 50	604	106	17.2%	78%	822	93.4%	686	135	\$116
42.5	40 to 45	756	149	24.1%	78%	1,440	92.8%	1,211	229	\$197
37.5	35 to 40	747	191	31.0%	78%	1,829	92.1%	1,548	281	\$241
32.5	30 to 35	553	233	37.9%	78%	1,655	91.5%	1,410	245	\$210
27.5	25 to 30	374	276	44.8%	78%	1,323	90.9%	1,135	188	\$161
22.5	20 to 25	337	318	51.7%	78%	1,375	90.3%	1,188	187	\$161
17.5	15 to 20	214	361	58.6%	78%	990	89.7%	861	129	\$111
12.5	10 to 15	127	403	65.5%	78%	657	89.1%	575	82	\$70
7.5	5 to 10	110	446	72.4%	78%	628	88.4%	554	74	\$64
2.5	0 to 5	77	488	79.3%	78%	482	87.8%	428	54	\$46
-2.5	-5 to 0	33	531	86.2%	78%	224	87.2%	201	24	\$20
-7.5	-10 to -5	20	573	93.1%	78%	147	86.6%	132	15	\$12
-12.5	-15 to -10	10	615	100.0%	78%	79	86.0%	72	7	\$6
Total						11,200		9,597	1,604	\$1,376

Savings Summary	
Energy Savings (therm):	1,604
Energy Savings (\$):	\$1,376



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-C7 Condensing Boiler - Lenape

Baseline Equipment	
# Boilers:	2
Boiler Input:	2,520 MBH
Boiler Efficiency:	78%

Proposed Equipment	
# Condensing Boilers:	2
Condensing Boiler Input:	2,520 MBH
Average Boiler Efficiency:	90%

Utility Costs	
Natural Gas:	\$0.858/therm

Weather Data		Baseline			Proposed			Savings		
Avg.	ΔT	Total hours	Heating Load (MBH)	Fraction of Annual Peak Load	Boiler Efficiency	Boiler Input (therm)	Boiler Efficiency	Boiler Input (therm)	Gas Input (therm)	Gas Input (\$)
57.5	55 to 60	885	136	3.4%	78%	1,538	94.6%	1,268	270	\$232
52.5	50 to 55	837	407	10.3%	78%	4,364	94.0%	3,621	743	\$637
47.5	45 to 50	604	678	17.2%	78%	5,249	93.4%	4,384	865	\$742
42.5	40 to 45	756	949	24.1%	78%	9,197	92.8%	7,733	1,464	\$1,256
37.5	35 to 40	747	1,220	31.0%	78%	11,684	92.1%	9,890	1,794	\$1,539
32.5	30 to 35	553	1,491	37.9%	78%	10,572	91.5%	9,009	1,563	\$1,341
27.5	25 to 30	374	1,762	44.8%	78%	8,450	90.9%	7,250	1,200	\$1,030
22.5	20 to 25	337	2,033	51.7%	78%	8,785	90.3%	7,589	1,196	\$1,026
17.5	15 to 20	214	2,304	58.6%	78%	6,323	89.7%	5,499	823	\$706
12.5	10 to 15	127	2,576	65.5%	78%	4,194	89.1%	3,673	521	\$447
7.5	5 to 10	110	2,847	72.4%	78%	4,015	88.4%	3,541	474	\$407
2.5	0 to 5	77	3,118	79.3%	78%	3,078	87.8%	2,734	344	\$295
-2.5	-5 to 0	33	3,389	86.2%	78%	1,434	87.2%	1,283	151	\$130
-7.5	-10 to -5	20	3,660	93.1%	78%	938	86.6%	845	93	\$80
-12.5	-15 to -10	10	3,931	100.0%	78%	504	86.0%	457	47	\$40
Total						71,545		61,301	10,244	\$8,789

Savings Summary	
Energy Savings (therm):	10,244
Energy Savings (\$):	\$8,789



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-C7 Condensing Boiler - College Hall

Baseline Equipment	
# Boilers:	1
Boiler Input:	750 MBH
Boiler Efficiency:	85%

Proposed Equipment	
# Condensing Boilers:	1
Condensing Boiler Input:	800 MBH
Average Boiler Efficiency:	90%

Utility Costs	
Natural Gas:	\$0.858/therm

Weather Data		Baseline			Proposed			Savings		
Avg.	ΔT	Total hours	Heating Load (MBH)	Fraction of Annual Peak Load	Boiler Efficiency	Boiler Input (therm)	Boiler Efficiency	Boiler Input (therm)	Gas Input (therm)	Gas Input (\$)
57.5	55 to 60	885	22	3.4%	85%	229	94.6%	206	23	\$20
52.5	50 to 55	837	66	10.3%	85%	649	94.0%	587	62	\$53
47.5	45 to 50	604	110	17.2%	85%	781	93.4%	711	70	\$60
42.5	40 to 45	756	154	24.1%	85%	1,369	92.8%	1,254	115	\$98
37.5	35 to 40	747	198	31.0%	85%	1,739	92.1%	1,604	135	\$116
32.5	30 to 35	553	242	37.9%	85%	1,573	91.5%	1,461	112	\$96
27.5	25 to 30	374	286	44.8%	85%	1,257	90.9%	1,176	82	\$70
22.5	20 to 25	337	330	51.7%	85%	1,307	90.3%	1,231	77	\$66
17.5	15 to 20	214	374	58.6%	85%	941	89.7%	892	49	\$42
12.5	10 to 15	127	418	65.5%	85%	624	89.1%	596	28	\$24
7.5	5 to 10	110	462	72.4%	85%	597	88.4%	574	23	\$20
2.5	0 to 5	77	506	79.3%	85%	458	87.8%	443	15	\$13
-2.5	-5 to 0	33	550	86.2%	85%	213	87.2%	208	5	\$5
-7.5	-10 to -5	20	594	93.1%	85%	140	86.6%	137	3	\$2
-12.5	-15 to -10	10	638	100.0%	85%	75	86.0%	74	1	\$1
Total						10,647		9,941	706	\$606

Savings Summary	
Energy Savings (therm):	706
Energy Savings (\$):	\$606



Project Name: SUNY New Paltz
Project Number: 4013032.01
ECM-C7 Condensing Boiler - Esopus

Baseline Equipment	
# Boilers:	2
Boiler Input:	3,348 MBH
Boiler Efficiency:	78%

Proposed Equipment	
# Condensing Boilers:	2
Condensing Boiler Input:	2,000 MBH
Average Boiler Efficiency:	90%

Utility Costs	
Natural Gas:	\$0.858/therm

Weather Data		Baseline			Proposed			Savings		
Avg.	ΔT	Total hours	Heating Load (MBH)	Fraction of Annual Peak Load	Boiler Efficiency	Boiler Input (therm)	Boiler Efficiency	Boiler Input (therm)	Gas Input (therm)	Gas Input (\$)
57.5	55 to 60	885	180	3.4%	78%	2,043	94.6%	1,684	359	\$308
52.5	50 to 55	837	540	10.3%	78%	5,798	94.0%	4,811	987	\$847
47.5	45 to 50	604	900	17.2%	78%	6,973	93.4%	5,824	1,149	\$986
42.5	40 to 45	756	1,261	24.1%	78%	12,219	92.8%	10,274	1,945	\$1,669
37.5	35 to 40	747	1,621	31.0%	78%	15,523	92.1%	13,140	2,384	\$2,045
32.5	30 to 35	553	1,981	37.9%	78%	14,045	91.5%	11,969	2,076	\$1,781
27.5	25 to 30	374	2,341	44.8%	78%	11,226	90.9%	9,632	1,594	\$1,368
22.5	20 to 25	337	2,701	51.7%	78%	11,672	90.3%	10,083	1,589	\$1,364
17.5	15 to 20	214	3,062	58.6%	78%	8,400	89.7%	7,306	1,094	\$938
12.5	10 to 15	127	3,422	65.5%	78%	5,572	89.1%	4,880	692	\$594
7.5	5 to 10	110	3,782	72.4%	78%	5,334	88.4%	4,704	630	\$540
2.5	0 to 5	77	4,142	79.3%	78%	4,089	87.8%	3,632	457	\$392
-2.5	-5 to 0	33	4,502	86.2%	78%	1,905	87.2%	1,704	201	\$172
-7.5	-10 to -5	20	4,863	93.1%	78%	1,247	86.6%	1,123	124	\$106
-12.5	-15 to -10	10	5,223	100.0%	78%	670	86.0%	608	62	\$53
Total						95,053		81,443	13,610	\$11,677

Savings Summary	
Energy Savings (therm):	13,610
Energy Savings (\$):	\$11,677




Project Name:	SUNY New Paltz
Project Number:	4013032.01
ECM-C7	

SUNY New Paltz
4013032.01

Condensing Boiler - Boiler Efficiency Calculation

Avg Temp in bin	Fraction of Peak Heating Load	Supply Water T	Return Water T	Condensing Mode	Boiler Thermal Efficiency
60	0%	86	84	y	95.3%
48	17%	102	95	y	94.0%
35	34%	118	107	y	91.8%
21	54%	137	120	y	88.7%
7.5	72%	154	132	n	87.6%
-7.5	93%	174	145	n	87.0%
-12.5	100%	180	150	n	86.8%





Project Name:	SUNY New Paltz
Project Number:	4013032.01
ECM-C8	Chiller Replacement

Chiller Part Load Efficiency		
% Load	Existing (kW/ton)	New (kW/ton)
100%	0.788	0.415
75%	0.667	0.294
50%	0.599	0.226
25%	0.756	0.383

Assumptions	
Chiller % Load	Temp (°F)
85%	92
0%	55

Peak Tonnage	
Existing (tons)	New (tons)
250	250

Utility Costs	
Electricity:	\$0.11/kWh

Weather Data		Load data		Existing Chiller		New Chiller		Savings				
Avg.	ΔT	Total (hrs)	% Cooling Load	Cooling Load (tons)	% Load	kW/ton	Cooling Energy (kWh)	% Load	kW/ton	Cooling Energy (kWh)	Energy Savings (kWh)	Energy Savings (\$)
92.5	90-95	12	86%	215.4	86%	0.721	1,864	86%	0.348	900	964	\$103
87.5	85-90	98	75%	186.7	75%	0.666	12,187	75%	0.293	5,364	6,823	\$732
82.5	80-85	305	63%	157.9	63%	0.635	30,583	63%	0.262	12,615	17,968	\$1,927
77.5	75-80	375	52%	129.2	52%	0.603	29,245	52%	0.230	11,169	18,075	\$1,938
72.5	70-75	552	40%	100.5	40%	0.661	36,652	40%	0.288	15,958	20,694	\$2,219
67.2	65-70	700	28%	70.1	28%	0.737	36,167	28%	0.364	17,873	18,295	\$1,962
62.5	60-65	771	17%	43.1	17%	0.805	26,750	17%	0.432	14,362	12,387	\$1,328
Total			-	-	-	-	173,447	-	-	78,241	95,206	\$ 10,209

Savings Summary	
Site Electricity Savings (kWh):	95,206
Site Gas Savings (therms)	0
Energy Savings (MMBTU Source)	1,085
Emission Reduction	194,291
Total Savings (\$):	\$10,209
Estimated Total Project Cost:	\$421,053
Simple Payback (years):	41.2

- From Cost Estimate Sheet

Assumptions:

(1) Chiller operate on days where temperature will reach at least 60°F. Assume chiller does not run when temperature below 55°F.

Appendix 5 – Energy Modeling

Required in the sample report in the RFP, may not use

Appendix 6 – Schematics

Required in the sample report in the RFP, may not use

Appendix 7 – Spec Sheets

Required in the sample report in the RFP, may use sparingly

